










Attachment D - Drawing  
RFx 3000022956

**Louisiana State Police  
Region 3 Headquarters**

5903 Coliseum Blvd.  
Alexandria, LA 71303

**LED EXTERIOR LIGHTING UPGRADES**

-  Replace **six** poles with **25'** poles
-  Replace **one** pole with a **15'** pole
  - 3 - Valmont DS330-500Q250-D5-FP BK-FBC-LAB
  - 2 - Valmont DS330-500Q250-D2-FP BK-FBC-LAB
  - 1 - Valmont DS330-500Q250-D1-FP BK-FBC-LAB
  - 1 - Valmont DS330-500Q150-D5-FP BK-FBC-LAB
- Include two fixtures per pole for a total of **14** fixtures (Keystone KT-ALED140PS-M2-OSB-PMA-8CSB-VDIM-P)
-  Remove **one** existing pole (no replacement at this location)
-  Replace **seven** wall pack light fixtures with Keystone KT-WPLED20-S1-8CSB-VDIM-B
-  Replace **three** wall pack light fixtures (LED) facing downward with Keystone KT-WPLED60-M2-850-VDIM
-  Add **three** wall pack lights (LED) facing downward with Keystone KT-WPLED60-M2-850-VDIM
-  Replace **two** flood lights with Keystone KT-FLED15-R1A-UNV-8CSB-VDIM
-  Replace **five** recessed porch lights with LEDvance LEDMD6R2A1200ST9SC3
-  Replace **five** canopy fixtures with LEDvance CANOPY3A/055UNV750/10S5/BZ


CLECO Power Company rebate incentives must be included in the bid.

- At the time of site visits, copies of the previous 12 months of CLECO invoices will be provided in order for the bidder to confirm the past year of KW usage and factor in eligible rebate incentives from CLECO.


HeliPad

Storage  
Bldg


Radio  
Bldg.



GARAGE



MAIN BUILDING



C  
A  
R  
P  
O  
R  
T  
5  
L  
I  
G  
H  
T  
S



5 recessed porch lights



NOT TO SCALE

SIGN



Portable  
Bldg