

Purchasing Office

P.O. Box 2052
Thibodaux, LA 70310
985.448.4038
Fax: 448.4921



**ADDENDUM NO 1
FOR
NICHOLLS STATE UNIVERSITY
THIBODAUX, LOUISIANA
05/19/2016
PAGE 1 OF 1**

Bid SB01704—Water Treatment Services Bid Due at 3:00 PM on 06/07/2016

Purpose of Addendum:

Provide revised page 5 of specification indicating the list of building hvac system.

Please remove existing page 5 of specification and replace with the attached revised page 5.

A handwritten signature in cursive script that reads "Terry G. Dupre".

Terry G. Dupre
Director of Purchasing and
Support Services Administration

NICHOLLS STATE UNIVERSITY
Thibodaux, Louisiana
WATER TREATMENT CONTRACT SPECIFICATIONS
Page 5 of 5

<u>CLOSED COOLING/HEATING</u> <u>RECIRCULATING SYSTEMS</u>	<u>TYPE</u>	<u>TONS</u> <u>OPERATING</u>	<u>TOWER</u>	<u>NOTES</u>
Galliano Hall (Cafeteria)	4 Pipe	150	N	
Student Union *	4 Pipe	180	Y	
Talbot Hall*	4 Pipe	300	N	
Ellender Library *	4 Pipe	400	Y	
Stopher Gym	4 Pipe	220	N	
Shaver Gym	4 Pipe	40	N	
Polk Hall	4 Pipe	200	N	
Peltier Hall with Peltier Loop	4 Pipe	1280	Y (2 towers)	
Powell Hall	4 Pipe		N	
Beauregard Hall	4 Pipe		N	
White Hall	4 Pipe	40	N	
Elkins Hall	4 Pipe	240	N	
Picciola Hall	4 Pipe	40	N	
Barker Building	4 Pipe	40	N	
Gouaux Hall	4 Pipe	350	Y	
Ellender Dorm	4 Pipe	200	N	
Lindsley Hall	4 Pipe	50	N	
Ayo Hall	4 Pipe	300	Y	
Duhe' Bldg (Houma)	4 Pipe	40	N	
Recreation Center	4 Pipe		N	
Lanny Ledet Culinary Bldg.	4 Pipe		N	