



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

July 28, 2016

ADDENDUM # 3

Bid No.: 50-0116930

Bid Opening Date: 08/04/2016

For: Labor, equipment & materials necessary to remove existing, furnish and install HVAC system for Lapalco Headstart.

Answering questions:

Question #1: Is work to be performed during normal business hours or is night/weekend work hours required?

Answer: Work can be performed during normal business hours, weekends or nights.

Question #2: During system down times to change from old equipment to new equipment, is temporary AC required?

Answer: Temporary AC is required in the main area. No temporary AC is required in the classrooms.

Question # 3: Who can I contact to make another site visit?

Answer: They are free to enter the site anytime from 8:30 to 4:30 Monday thru Friday, as long as they sign in at the front desk.

Sincerely,

Donna Reamey

Donna Reamey, Buyer II
Jefferson Parish Purchasing Department

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form as indicated. Failure to do so will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.