



September 1, 2016

ADDENDUM NO. 1

TO: ALL BIDDERS AND PLAN-HOLDERS

SUBJECT: **SB# 1679 - GREENWOOD COMMUNITY PARK PEDESTRIAN BRIDGE
13350 HIGHWAY 19, BAKER, LA 70714**

***The bid opening date has changed!**

***NEW BID OPENING DATE: Thursday September 15, 2016 at 2:00 p.m.**

(ORIGINAL BID OPENING DATE: Thursday, September 8, 2016 at 2:00 p.m.)

The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract document:

COMMENTS & QUESTIONS:

1. Is there any other access besides the gravel path from the parking lot?

No, there is not another access route to the construction site.

2. Does an alternate bridge manufacturer need to be approved prior to the bid?

Approval for an alternate manufacturer should be requested and approved before the bid to guarantee approval. An alternate manufacturer may be submitted for approval after the bid, but may or may not be accepted.

3. How many trees can be removed along the bank?

BREC would like to save as many trees as possible, but some trees may need to be removed to allow for construction. However, the contractor must coordinate with BREC prior to the removal of any trees, and should only remove the trees that are absolutely necessary to make way for construction.

4. Can the trees removed be composted on site?

Yes, any felled trees can be cut up and composted on site in the natural wooded areas as long as those natural areas are not damaged in the process.

5. What is the total height of the footing?

Sheet 4 of the Construction Plans indicate 2 feet plus “see vendor drawings”. It is intended that the footing be flush with the walking surface of the bridge, therefore the total height will vary with the “see vendor drawings” dimension based on the selected bridge.

6. What is the project budget?

The budget has yet to be determined but will be read aloud at the bid opening. The engineers estimated cost for construction is \$125,000.

7. Clarification.

The proposed bridge length is 65 feet as shown in the plans and not 60 feet as described in the advertisement.

8. Access.

Site access is a challenging part of this job. Contractor should review General Note #1 on Sheet 2 of the Construction Plans prior to bidding.

9. Safety.

Greenwood Community Park is an open and active park and safety is a big concern from BREC’s perspective, especially around the access points near the playground. The contractor will need to take the appropriate measures to make sure that the construction zone is appropriately flagged and/or fenced off for public safety.

ATTACHMENTS TO ADDENDUM NO.1 – August 29, 2016

1. Pre-bid Sign-in Sheet



PRE-BID CONFERENCE
ATTENDANCE REGISTER

PROJECT: Greenwood Community Park Pedestrian Bridge

LOCATION: Greenwood Community Park -Pro Shop
13350 Highway 19, Baker, LA 70714

DATE/TIME:

NAME	REPRESENTING	ADDRESS	TELEPHONE/FAX NO.	EMAIL
1. CARL DUCOTE	COASTAL MEGA WORKS	1821 PINESTANG RD. PINEYUNG MS 39466	504 738 1793	50050 COX COASTALMEGA.COM
2. BRIAN KILGEN	LA CONTRACTING	1645 St. Patrick Hwy Thibodaux, LA 70301	504-430-3213	Brian KID LA-CONT , com
3. BRAD WALLACE	BREC			
4.				
5.				
6.				
7.				
8.				