

October 14, 2016

SB 1683 INDEPENDENCE PARK PLAYGROUND

7500 Independence Boulevard, Baton Rouge, LA 70806

Addendum No. 2

The following items shall be considered part of the Contract Documents for the above referenced project and shall take precedence over any conflicting statements contained therein. Replace, revise, and/or add to all other specifications, notes, schedules, drawings, details, elevations, sections as required.

General Contractors are cautioned to bring to the attention of all subcontractors any changes which may affect their work.

The contractor shall acknowledge receipt of this addendum on the Louisiana Uniform Public Work Bid Form included in the Contract Documents.

PART – 1 General:

- The Pre-Bid Meeting was held on October 5, 2016. See attached sign-in sheet and meeting notes. ***This was inadvertently left out of Addendum No. 1*
- Contractor Questions:
 - Clarify steel coating: hot-dipped galvanized or powder coated.
 - ANSWER: Pavilion steel members are to be powder-coated. All other steel components on site furnishings that are called to be galvanized shall follow the materials specification under 129300 Site Furnishings, Part 2 Products, 2.1 Materials, A.1
 - Does the Pavilion slab size match the roof line or extend past?
 - ANSWER: all pavilion slabs are to extend 24" past the roof line on all sides, see attached sheet.
 - Is everything to be demolished to be hauled off site or is BREC salvaging any items?
 - ANSWER: Yes, everything called to be removed is to be hauled off site properly. BREC will not salvage any items.
 - Does the flagpole include the flag?
 - ANSWER: No, the flag will be provided and installed by BREC at a later date.

PART – 2 Drawings:

- Replace Sheet C-2.1 – Pavilion slab size clarification

PART – 3 Specifications:

- Section 129300 Site Furnishings – delete 2.7, C. The model for each pavilion is listed under D and E for each size structure.
- Section 129300 Site Furnishings – on the pavilion cut sheet attachment change the wind load from 100 mph to 110 mph.



THE RECREATION AND PARK COMMISSION
FOR THE PARISH OF EAST BATON ROUGE

SB 1683 INDEPENDENCE PARK PLAYGROUND

Pre-Bid Meeting – Notes

Date: October 5, 2016

Time: 9am

Location: Project Site - 7500 Independence Boulevard, Baton Rouge, LA 70806

I. General Information

- a. Bid Date is October 18, 2016 at 2pm
- b. Owner/Architect – BREC Planning and Engineering Department
- c. Contract Time - 120 days
- d. Liquidated Damages - \$200.00 per day
 - i. It was noted that this will be changed to \$500/day in Addendum No. 1.

II. Prior to start of construction BREC will:

- a. remove trees and stumps marked with white paint. Tree removal will not be part of the bid.
- b. prune/limb trees as needed.
- c. remove any site furnishings that we wish to keep.

III. On Site Review/Discussion

- a. An addendum will be issued by the end of the week that will include modifications to the list of Alternates as well as other clarifications.
- b. Notice was made of the grade changes around large live oak trees – care must be taken so that there is not too much cut or fill done within the dripline of the trees.
- c. The sidewalk surrounding the restroom building does not seem to be attached to the building slab. Therefore, a sawcut will not be necessary in this location. *this will be stated in Addendum No. 1.

PRE-BID CONFERENCE **ATTENDANCE REGISTER**



PROJECT: SB 1683 Independence Park Playground

LOCATION: Independence Park (East Airport Rd @ Independence Blvd.)
7500 Independence Blvd., Baton Rouge, LA 70806

DATE/TIME: Wednesday, October 5, 2016; 9:00 am

NAME	REPRESENTING	ADDRESS	TELEPHONE/FAX NO.	EMAIL
1. Milton Morel	GM Builders	16254 Woodville Dr., Prairieville	225-755-2664/225-755-2665	milton@gmbuildersbr.com
2. Lee Boyd	SiElle Constructors	40416 William Ficklin Road, Gonzales	225-505-6097/225-751-2159	lee.boyd@sielleconstructors.com
3. Byron Law	Law Industries, LLC	7547 Town South Ave, BR	225-436-0048 / 225-663-8859	byron@lawindustries.com
4. Angela Carrington	Sienna Construction	8966 Interline Rd, Baton Rouge	225-456-5466	mspanno@siennaconstruction.net
5.				
6.				
7.				
8.				