

**OFFICE OF PURCHASING
O'KEEFE ADMINISTRATION BUILDING**

501 City Park Avenue, Bldg 37
New Orleans, LA 70119
(504) 762-3027 FAX: (504) 762.3089
www.dcc.edu

Addendum No: (1)

Bid No: R0013035
Bid Name: Concrete Repair & Replacement
Opening Date: October 21st, 2016 at 2:00PM CST

Addendum No: 1
Date Issued: October 13th 2016

This addendum is hereby officially made a part of the referenced solicitation. The questions submitted have been clarified as follows.

1. The concrete replacement of walkway at the Building 1 Fitness center is a wash gravel. Will the concrete repairs in this area be matched? Can normal concrete be used. Broom finish is to be used
2. The Building one fitness center repairs, can the concrete be removed from joint to joint instead of saw cutting? No. Saw cut as shown
3. The area between the bookstore and library. Is this area replacement or new concrete? New concrete
4. Can the repair work be done on the weekend? Yes
5. What is the required thickness of the concrete? 5"
6. Is geotextile Fabric required under base material of sidewalk? No
7. How many inches of sand (4-6" is typical) is required under paving? The bid should be based on 4" If more is needed it will be treated as an unforeseen condition.

**OFFICE OF PURCHASING
O'KEEFE ADMINISTRATION BUILDING**

501 City Park Avenue, Bldg 37
New Orleans, LA 70119
(504) 762-3027 FAX: (504) 762.3089
www.dcc.edu

8. They refer to a drawing on page 17 note 1.08 for temporary fence. Do not see a drawing in bid packet. If there's a drawing please send me a copy. Do we put temporary fencing on all site work?
The fence will need to be used where concrete is being broken and removed. The contractor will need locate the fence to keep faculty, staff and students safe.
9. Reference drawing sheet on page 28 note 3.2 Joints, see D. How far do the expansion joints go from each other, and do we put joint sealant on top? Can it be treated wood ?
Joints are 20' o.c. no wood to be used, Contractor to use closed cell expansion material.
10. Page 16 item 1.01 Scope notes using 6" by 6" wire mesh and doweling pins. What ga. wire and size dowel pins?
6x6 W1.4/W1.4 WWF – Dowels to be #6
11. Under general conditions, references using filling materials. Is that for filling if needed when concrete is removed, or do we dig down and remove the existing dirt? Then fill with crushed concrete or river sand as a base? Also it shows Geotextile fabric, is that to be used under the new concrete?
Refer to questions 6 and 7above
12. During the walk through, the location of the new sidewalk was not sure. There's a tree that could be in the way. As discussed, will the tree be removed by the University if needed ?
Site will be marked. No tree's will be in the contractors path
13. After new sidewalk is installed and the form boards are removed, do we backfill on both sides of the sidewalk ? Do we install sod on top ?
Use existing dirt on sides of sidewalk
14. The handrails on building 4. Do we remove them and leave them off? I believe building code may require handrails to be re-installed.
Handrails are not to be reinstalled

**OFFICE OF PURCHASING
O'KEEFE ADMINISTRATION BUILDING**

501 City Park Avenue, Bldg 37
New Orleans, LA 70119
(504) 762-3027 FAX: (504) 762.3089
www.dcc.edu

15. The existing concrete by building 1 is pea gravel washout. During the walk through we were told to just go back with a broom finish. Just checking to make sure. Broom finish is to be used
16. Are there liquidated damages or penalties per day for this project if completed late? Is there a bond required? No & no

Acknowledgement: Acknowledgement of this addendum must be noted on the bid form where indicated. *If your bid has already been submitted, please sign below where indicated and fax this form to 504-762-3089 or mail to the address stated in the General Conditions section of the bid documents. Whether by fax or mail, this form needs to be received prior to the opening date and time indicated in the bid documents. **Failure to acknowledge the addenda on the bid form or by mailing or faxing this form will cause your bid to be rejected.***

The below signed acknowledges receipt of this addendum

Company: _____ Signature: _____
Printed
Name _____