



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

November 02, 2016

ADDENDUM # 1

Bid No.: 50-00117913

Bid Opening Date: November 08, 2016

For: FURNISH LABOR, MATERIALS AND EQUIPMENT TO PERFORM ROOF REPAIRS AT BRIDGE CITY PLAYGROUND FOR THE JEFFERSON PARISH DEPARTMENT OF PARKS AND RECREATION

CLARIFICATIONS of SPECIFICATIONS:

QUESTION: What type of roofing system needs repair and what is the square footage?

ANSWER: Roof material 1" to 1/12 density lapolla polyurethane form with a lapolla white top coat. This will apply on both metal and flat roof. The square footage for the metal roof is 9000 sq. ft and 2700 sq. ft. for the flat roof.

QUESTION: Can I bid on this job with a license in Building Construction?

ANSWER: The job should be specified as Building Construction and/or Roofing and Sheet Metal, Siding.

ADDITIONAL SPECIFICATIONS:

Approximately 390 feet of 6 inch gutter will need to be replaced around the perimeter of the roof.

15-4 inch downspouts will be needed to replace existing downspouts.

Sincerely,

Donna M. Evans, Buyer II
Jefferson Parish Purchasing Department



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form as indicated. Failure to do so will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.