



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

October 25, 2016

ADDENDUM # 1

Bid No.: 50-00117955

Bid Opening Date: October 27, 2016
Extended Bid Opening: November 10, 2016

**For: ONE YEAR CONTRACT TO SUPPLY HEAVY WALL PVC SEWER PIPE FOR THE JEFFERSON
PARISH DEPARTMENT OF PUBLIC WORKS- SEWERAGE**

CLARIFICATIONS of SPECIFICATIONS:

DESCRIPTION SHOULD READ: ONE YEAR CONTRACT FOR SUPPLY OF SDR 35 FITTINGS AND
FLEXIBLE COUPLING FOR THE DEPARTMENT OF SEWERAGE

SDR 35 Fittings and Flexible Coupling

Contract

Items Included In This Contract:

1. SDR 35 Fittings (4" through 15")
2. Shielded Repair Couplings (4" through 15")
3. Expandable "T" Cone Pipe Plugs (4" & 6")
4. PVC Backflow Preventer/Backwater Valve



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

Contract Terms:

This is a one year contract for supply of SDR 35 fittings and flexible coupling for the Department of Sewerage, and all Jefferson Parish agencies and municipalities.

Warranty:

Products shall be warranted that they are manufactured in accordance with the applicable material specifications and are free from defects in workmanship and materials for one year after delivery. Any defective items sold under this contract shall be replaced at no cost to the purchaser.

General Specifications:

This specification is prepared for a one (1) year contract for a supply of SDR 35 fittings and flexible coupling for the Parish of Jefferson, Department of Sewerage, East and West Bank.

The quantities shown on the proposal guide are approximate quantities to be acquired by Jefferson Parish over a one (1) year period. Actual usage will be on an "as needed" basis.

Bid delivery shall include all freight and delivery costs to Jefferson Parish warehouse locations on the East and West Banks of Jefferson Parish.

All technical and product literature must be submitted with the bid. Failure to honor such request will result in the bid being considered non-responsive.



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

Technical Specifications:

I. SDR 35 PVC Sewer Fittings:

SDR 35 PVC gravity sewer fittings shall be available in 4" through 15" and shall meet all the requirements of ASTM D 3034 "type PSM poly (vinyl chloride) (PVC) sewer pipe and fittings".

II. Shielded Repair Couplings:

Shielded repair couplings (4" through 15") shall be designed for making sewer connections, repairs and fittings insertions. These shall be suitable for connecting plain end of any material combinations of clay, concrete, cast iron, plastic, etc. with stainless steel shear rings and "nut and bolt clamp design. Shielded repair couplings shall be "Fernco's 5000 Series Strong Back RC Couplings" or "Mission Rubbers' ARC". ASTM C1173-08.

III. Expandable "T" Cone Pipe Plugs (4" & 6"):

Expandable "T" cone pipe plugs shall provide tight positive seal in gravity (non-pressure) sewer pipes and fittings (steel, cast/ductile iron, clay, and plastic). Expandable "T" cone pipe plugs shall consist of a rigid plug and sealing ring (no metal parts):

- **Rigid Plugs:**
Rigid plugs shall be made of reinforced polypropylene material for all sizes.
- **Sealing Ring:**
Sealing rings shall be made of polyurethane material for 4" - 6" sizes.



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

Expandable "T" cone pipe plugs shall meet or exceed all applicable requirements of ASTM D-412, D-575, D-624, D-676, and D-792.

Expandable "T" cone pipe plugs shall be made by "ETCO Specialty Products, Inc." or an approved equal.

IV. PVC Backflow Preventer/Backwater Valve (4" & 6"):

Flapper - The backwater valve shall have removable quick action flapper to allow unrestricted uni-directional flow with elastomeric gasket in the flapper to ensure a watertight seal.

Access Cap – Access cap shall be threaded and shall have neoprene gasket and shall provide a positive seal. Threaded access cap shall be designed for hand tightening.

Valve Hub – Valve hub outlets shall fit 2", 3", 4", or 6" sewer pipe. There shall be an arrow on top of the valve hub pointing in the direction of the flow.

Backwater valve shall meet all applicable requirements of ASTM D 2661, ASTM D 2665, and ASME 112.14.1 and shall be manufactured by National Diversified Sales, Inc. or an approved equal.



JEFFERSON PARISH

Department of Purchasing

Michael S. Yenni
Parish President

Brenda J. Campos
Director

Sincerely,

A handwritten signature in black ink that reads "Donna M. Evans". The signature is written in a cursive style and is positioned above a horizontal line.

Donna M. Evans, Buyer II
Jefferson Parish Purchasing Department

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form as indicated. Failure to do so will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.