



ADDENDUM II
November 8, 2016

Cleaning, Waterproofing and Painting Exterior
Betty E. Smith Nursing Building

Bid Due Date:

November 14, 2016 @ 2:00 p.m.

1. Grambling State University will be responsible for the removal of plants that intertwine around wrought iron fencing in courtyard.
2. 100% re-caulking on exterior window frames.
3. Bid should exclude flood insurance.
4. Paint color: Sherwin Williams #SW7725 "Yearling". The paint product is a high build, water based, elastomeric coating, 100% acrylic, waterproofing coating.

Sign and return with bid:
