

**OFFICE OF PURCHASING
O'KEEFE ADMINISTRATION BUILDING**
501 City Park Avenue, Bldg 37
New Orleans, LA 70119
(504) 762-3027 FAX: (504) 762.3089
www.dcc.edu

Addendum No: (1)

Bid No: R0013132
Bid Name: Chiller Maintenance
Opening Date: November 17th, 2016 at 2:00PM CST

Addendum No: 1
Date Issued: November 9th, 2016

This addendum is hereby officially made a part of the referenced solicitation. The questions submitted have been clarified as follows.

1. Does the bid require that the successful bidder provide refrigerant? Yes
2. Specification clarification: Pump strainers are to be cleaned annually as opposed to semi annually
3. Specification clarification: Water cooled chiller condensers and evaporators are to be cleaned annually as opposed to semi-annually

Acknowledgement: Acknowledgement of this addendum must be noted on the bid form where indicated. *If your bid has already been submitted, please sign below where indicated and fax this form to 504-762-3089 or mail to the address stated in the General Conditions section of the bid documents. Whether by fax or mail, this form needs to be received prior to the opening date and time indicated in the bid documents. **Failure to acknowledge the addenda on the bid form or by mailing or faxing this form will cause your bid to be rejected.***

The below signed acknowledges receipt of this addendum

Company: _____ Signature: _____
Printed Name _____