



October 25, 2021

ADDENDUM NO: 01

Your reference is invited to solicitation 000550 which is scheduled to open November 9, 2021 @ 9:00am for 800 KW INSTALL


The following QUESTION was submitted:

1. Will aluminum wire be allowed for the temporary feeds to the 800amp breaker?

ANSWER:

1. Temporary feeder, 400A, from Panel DE that is used to temporarily feed Panel DA, DB and DC can be aluminum Type W.
2. Temporary feeder, 800A, from the existing 750KW generator to Panel GDP can be aluminum Type W.

This addendum is officially made a part of the above referenced Solicitation and should be attached to the bidder's proposal or otherwise acknowledged therein.


Margaret McIntyre
Procurement Specialist