



# JEFFERSON PARISH

## DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG  
PARISH PRESIDENT

RENNY SIMNO  
DIRECTOR

April 22, 2022

### ADDENDUM # 2

**Bid Number: 50-00137795**

**Bid Opening Date: May 5, 2020**

**For: One Time Purchase of Various Electrical Supplies, Damaged During Hurricane Ida for the Jefferson Parish Department of Parks and Recreation, Bridge City Playground**

---

**Clarification:**

Question: What is the voltage of the fixtures?

Answer: **The voltage of the fixtures is 480 Volts.**

Question: What is the amperage of the Circuit Breakers?

Answer: **The Circuit Breaker amperage is 20 amps.**

Question: Should Item No. 0050 part number be EDB24020 instead of EO824020?

Answer: **Yes, Item No. 0050 part number should be EDB24020.**

Sincerely,

A handwritten signature in cursive script that reads "Mark Buttery".

---

Mark Buttery  
Buyer I

**Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.**

**This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.**