



# JEFFERSON PARISH

## DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG  
PARISH PRESIDENT

RENNY SIMNO  
DIRECTOR

August 4, 2022

### ADDENDUM # 2

Bid Number: 50-00139054

Receipt Date: August 11, 2022  
Postponed to Date: N/A

**Description of Bid: Labor & Materials Necessary to Remove, Replace & Install a new roof on the sign & signal building for The Jefferson Parish Traffic Engineering Department**

---

#### **Q&A:**

A few questions about above mentioned project. It appears that the specs **7.3 Roof Replacement** are a combination of two different systems, TPO and SBS.

1. I believe the intentions is to cover all 3 buildings with GAF 60 mil TPO, is that correct? (1 building complete removal to metal deck and 2 buildings recover system) **Yes**
2. There is no product “GAF 60 mil TPO modified asphalt base membrane”, modified asphalt base membrane is what roofers refer to as SBS. Which can be torch welded and or set in hot asphalt. **GAF 60 mil TPO**
3. Spec says to install 1-layer base sheet and 1-layer cap sheet with all laps torched, TPO is 1 layer set in adhesive or mechanically attached, with all laps heat welded. (This qualifies for specified 20-year NDL Warranty) **TPO to be mechanically attached and heat welded**
4. Section 4.0-Scope: list Line item 1 and Line item 2, Page 7 of the bid form is listing Line Items 1-2 and 3, is this correct? **Yes**

JOSEPH S. YENNI BUILDING - 1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242  
OFFICE 504.364-2678

GENERAL GOVERNMENT BUILDING - 200 DERBIGNY ST - SUITE 4400 - GRETNA, LA 70053 - PO BOX 9 - GRETNA - LA 70054  
OFFICE 504.364.2678

EMAIL: [PURCHASING@JEFFPARISH.NET](mailto:PURCHASING@JEFFPARISH.NET)

WEBSITE: [WWW.JEFFPARISH.NET](http://WWW.JEFFPARISH.NET)



# JEFFERSON PARISH

## DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG  
PARISH PRESIDENT

RENNY SIMNO  
DIRECTOR

**\*\*\* THE DEADLINE FOR QUESTIONS HAS PASSED\*\*\***

**\*\*\*REMEMBER TO ACKNOWLEDGE THIS ADDENDUM ON YOUR BID SUBMISSION.\*\*\***

Sincerely,

Shanna Folsie, Buyer II  
Jefferson Parish Purchasing Department

**Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.**

**This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.**

JOSEPH S. YENNI BUILDING - 1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242  
OFFICE 504.364-2678

GENERAL GOVERNMENT BUILDING - 200 DERBIGNY ST - SUITE 4400 - GRETNA, LA 70053 - PO BOX 9 - GRETNA - LA 70054  
OFFICE 504.364.2678

EMAIL: [PURCHASING@JEFFPARISH.NET](mailto:PURCHASING@JEFFPARISH.NET)

WEBSITE: [WWW.JEFFPARISH.NET](http://WWW.JEFFPARISH.NET)