



“RE-BUILDING THE CITY’S WATER SYSTEMS FOR THE 21ST CENTURY”

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

July 15, 2022

Addendum No. 1

Your reference is directed to **Contract 1418 – Packaged Auxiliary Electrical Equipment Procurement** for the Sewerage and Water Board of New Orleans which is due at **11:00 a.m. Local time on August 19, 2022.**

This Addendum consists of 5 Pages and 8 Attachment(s).

This addendum provides for the following:

A1.1. Volume 1, Procurement and Contracting Documents, Specification Section 00 45 54;

ADD Attachment 1 00.45.54_Conflict of Interest Disclosure Affidavit, Attachment 2 00.45.54_Convicted Felon Affidavit, and Attachment 3 00.45.54_Non-Solicitation Affidavit to Volume 1, Procurement and Contracting Documents immediately after page 1418 VOL 1 SHT 39 of 157, Section 00 45 54, Affidavit of Noncollusion.

A1.2. Volume 1, Procurement and Contracting Documents, Specification Section 00 21 13, Instructions to Bidders, Paragraph 16.1;

DELETE items 16.1.1 through 16.1.5, and REPLACE with the following items updated to include the three added affidavits:

“16.1.1. Louisiana uniform Public Work Bid Form, Additional Requirements, Bidder Declaration, Guarantees, and Emergency Procedures.

16.1.2. Louisiana Uniform Public Work Bid Form, Affidavit

16.1.3. Voluntary Extensions of the Award of Contract

16.1.4. Affidavit of Noncollusion

16.1.5. Conflict of Interest Disclosure Affidavit

16.1.6. Convicted Felon Affidavit

16.1.7. Non-Solicitation Affidavit

16.1.8. Economically Disadvantaged Business Participation Summary Sheet”

A1.3. Volume 1, Procurement and Contracting Documents, Specification Section 00 21 13, Instructions to Bidders;

ADD the following paragraph after Paragraph 24:

“25. BID PROTESTS

25.1 Any formal protest which is to be made by an aggrieved Proposer must be submitted in writing to the Procurement Director, Cashanna K. Moses at cmoses@swbno.org according to Sewerage and Water Board of New Orleans Policy 83(R): Procedural Rules for Bid Appeals.”

- A1.4. Volume 1, Procurement and Contracting Documents, Specification Section 00 21 13, Instructions to Bidders, Paragraph 20;

ADD the following sentence to the end of the paragraph:

“The Fee Schedule is subject to change and Contractor is responsible for any deviations from this Fee Schedule.”

- A1.5. Volume 2, Specifications and References, Specification Section 01 11 01, Summary of Work, Paragraph 1.03 Project Considerations;

DELETE the last sentence of Paragraph 1.03.A. The paragraph is revised as follows:

“A. Construction of the Utility Rack will run concurrent with other onsite construction and equipment supply activities.”

- A1.6. Volume 2, Specifications and References, Specification Section 01 31 13, Project Coordination, Paragraph 1.01 Submittals;

ADD the following paragraph:

“B. Action

1. Contamination Mitigation Plan: Submit detailed plan including all equipment, materials, and labor necessary to protect the existing water treatment process and potable water system.
2. Outage and Shut Down Requests: Submit utility outage and shut down requests 14 days ahead of required outage or shut down.
3. Influent Channel Loading Work Plan: Submit a detailed plan including all equipment, materials, and calculations documenting the sequence of proposed loads on the existing C-Basin Influent Channel.”

- A1.7. Volume 2, Specifications and References, Specification Section 01 31 13, Project Coordination, Paragraph 1.02.A.1;

ADD the following item after 1.02.A.1.e:

“f. Contract 1376 Highlift project.”

- A1.8. Volume 2, Specifications and References, Specification Section 01 31 13, Project Coordination, Paragraph 3.04.B;

ADD the following item after 3.04.B.4:

“5. No storage will be allowed in the C7 basin area once the 1415 project commences.”

- A1.9. Volume 2, Specifications and References, Specification Section 01 31 13, Project Coordination, Paragraph 3.04.C;

REPLACE Paragraph 3.04.C.3 with the following:

“3. Details of the existing water treatment plant influent channels running parallel to Segment B of the Utility Rack are included in Volume 4, Reference Drawings, 11786-W-50, C Basin Modifications, pages

1418 VOL 4 SHT 14 through SHT 23 of 186. The concrete roof of the channel has a load capacity of 250 pounds per square foot. If Contractor plans to utilize this area for construction equipment or materials, a detailed plan must be submitted for review and approval by the Owner and Engineer prior to placement of any equipment or materials on the concrete channels. For bidding purposes, the following equipment, which have been evaluated to the allowable loading requirements, are listed for consideration:

- a. SpyderCrane URW376
- b. Genie Self-Propelled Articulating Booms Z-40/23N & Z-40/23N RJ
- c. Genie Telehandler GTH-636
- d. John Deere TE 4x2 Electric Utility Vehicle
- e. Lincoln Electric Multi-Process Powerhouse Vantage 500”

- A1.10. Volume 2, Specifications and References, Specification Section 01 31 13, Project Coordination, Paragraph 3.04.E;

ADD Paragraph 3.04.E.6 as follows:

“6. Additional vibration monitoring is required during construction activities in Segment D. In addition to the vibration monitoring requirements listed in Section 31 62 16, Steel Piles, Paragraph 3.09, Contractor must monitor vibration levels at approved locations along Spruce Street and Leonidas Street.”

- A1.11. Volume 2, Specifications and References, Specification Section 01 45 33, Special Inspection, Observation, and Testing;

REVISE Paragraph 1.03.A.4 as follows: “Special Inspector: Qualified person who will demonstrate competence to the satisfaction of the building official for inspection of a particular type of construction or operation requiring Special Inspection.”

REVISE Paragraph 1.04.A.3 as follows: “Architectural, Mechanical, and Electrical Components subject to Special Inspection under IBC Section 1705.11.5 and 1705.11.6 for Seismic Resistance: None required.”

REVISE Paragraph 1.04.C as follows: “Special Inspection and associated testing of shop fabrication and field construction will be performed by an approved accredited independent agency. Contractor will secure and pay for the services of the agency to perform Special Inspection and associated testing.”

- A1.12. Volume 2, Specifications and References, Specification Section 01 88 15, Anchorage and Bracing;

REVISE Paragraph 1.06.A as follows: “Contractor and supplier responsibilities to accommodate shop fabrication related special inspections and testing are provided in Project’s Statement of Special Inspections on the Drawings and Section 01 45 33, Special Inspection, Observation, and Testing.”

- A1.13. Volume 2, Specifications and References, Specification Section 05 05 23, Welding;

REVISE Paragraph 1.02.I as follows: “Special Inspection: Nondestructive examination including MT, PT, UT, and RT. Special Inspection personnel are retained by the Contractor. See additional requirements in Section 01 45 33, Special Inspection, Observation, and Testing.”

- A1.14. Volume 2, Specifications and References, Specification Section 05 12 00, Supply and Fabrication of Structural and Miscellaneous Steel;

DELETE the last sentence of Paragraph 2.01.B

DELETE the last sentence of Paragraph 2.02.G Handrails and Guardrails.

DELETE the last sentence of Paragraph 2.02.H Ladders.

REVISE Paragraph 2.03.A as follows: “All structural steel members, steel plate, grating, stair treads, handrails, guard rails, and ladders shall be galvanized.”

A1.15. Volume 2, Specifications and References, Specification Section 05 50 00, Metal Fabrications;

REVISE Paragraph 2.10.B as follows: “An independent testing agency shall be retained by Contractor and approved by Engineer to inspect and test hot-dip galvanized fabricated items in accordance with ASTM A123/A123M and ASTM A153/A153M.”

A1.16. Volume 2, Specifications and References, Specification Section 09 90 01 Painting and Protective Coatings;

INSERT new Paragraph 3.06.D as follows:

“System No. 9B Steel Pipe Piles:

Surface Prep.	Paint Material	Min. Coats, Cover
SP10	Fast Set Polyurethane – Poly-Cote 110 or Equiv.	1 coat, 100 MDFT

”

DELETE Supplement 2, Painting Schedule, and REPLACE it with the Attached 09 90 01 Painting and Protective Coatings, Supplement 2, Rev 1.

A1.17. Volume 2, Specifications and References, Specification Section 31 62 16 Steel Piles;

REVISE Paragraph 2.07.A as follows: “As shown and described on the Contract Drawings.”

A1.18. Volume 3, Contract Drawings;

DELETE Drawing D1.10, Rev 0 Demolition Plan – Existing Mud Line and ADD Attached Drawing D1.10, Rev 1 Demolition Plan – Existing Mud Line.

DELETE Drawing D1.11, Rev 0 Mud Line Pipe Demolition Plan and ADD Attached Drawing D1.11, Rev 1 Mud Line Pipe Demolition Plan.

DELETE Drawing D1.12, Rev 0 Mud Line Pipe Relocation Plan and ADD Attached Drawing D1.12, Rev 1 Mud Line Pipe Relocation Plan.

DELETE Drawing D1.13, Rev 0 Mud Line Pipe Demolition Sections and ADD Attached Drawing D1.13, Rev 1 Mud Line Pipe Demolition Sections.

A1.19. This Addendum includes the following attachments (not included in the page count):

- a. Attachment 1 – 00.45.54_Conflict of Interest Disclosure Affidavit
- b. Attachment 2 – 00.45.54_Convicted Felon Affidavit
- c. Attachment 3 – 00.45.54_Non-Solicitation Affidavit
- d. Attachment 4 – 09.90.01_PaintingProtectiveCoatings_Supp2_Rev1
- e. Attachment 5 – D1.10, Rev 1 Demolition Plan – Existing Mud Line
- f. Attachment 6 – D1.11, Rev 1 Mud Line Pipe Demolition Plan

- g. Attachment 7 – D1.12, Rev 1 Mud Line Pipe Relocation Plan
- h. Attachment 8 – D1.13, Rev 1 Mud Line Pipe Demolition Sections

The changes, additions, and/or deletions included herein are hereby made part of the Contract Documents for the CP-1418 Utility Rack project, as fully and completely as if the same were set forth therein. The bidder shall acknowledge receipt thereof on the Form of Proposal.

*** END OF ADDENDUM ***

