

March 8, 2023

TITLE 38 ADDENDUM NO. 5

PROPOSAL FOR FURNISHING ALL LABOR, MATERIALS, EQUIPMENT, TRANSPORTATION, SUPERVISION, PERMITS, ETC. NECESSARY FOR RENOVATIONS TO WOMEN'S LOCKER ROOM AT CAJUNDOME, LOCATED ON THE UL LAFAYETTE CAMPUS, LAFAYETTE, LOUISIANA.

Due March 14, 2023 2:00 PM Solicitation No. 23222

The following is to be made part of the original specifications as though issued at the same time and shall be incorporated integrally therewith. This addendum shall be acknowledged on the BID FORM when submitted to the Purchasing Department prior to the bid due date/time.

Item No. 1 – CHANGES/CLARIFICATIONS TO THE CONTRACT DOCUMENTS.

The Solicitation Number, Bid Number, File Number for this project is 23222. Any reference to any other bid or project number is to be disregarded. 23222 is the number assigned to this project by the University of Louisiana at Lafayette and the number that shall be referenced on your bid submission.

Item No. 2 – Attached is the Sign-in Sheet of attendees at the Pre-Bid Conference which was held at 10:00 AM on February 14, 2023, at the Cajundome which is associated with Addendum 4. It was inadvertently left out of the post.

Item No. 3 – CLARIFICATIONS AND/OR ADDITIONS OF SPECIFIED AND/OR DRAWINGS DESIGNATED ELECTRICAL ITEMS.

**New Women's Basketball Office Suite
at the Cajundome for the
University of Louisiana at Lafayette
Lafayette, Louisiana**

NOTICE TO BIDDERS:

This Addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract Documents, this Addendum shall govern and take precedence.

Bidders are hereby notified that they shall make any necessary adjustments in their estimates on account of this Addendum. It will be construed that each Bidder's Proposal is submitted with full knowledge of all modifications and supplementary data specified herein.

ELECTRICAL ITEMS

AD5.1: For Clarifications and/or Additions of specified and/or drawings designated Electrical Items, Note the following:

1. The following questions were submitted to the Project Design Team:
 - a. Reference Sheet E3.3 At existing panel '2H2', we are to provide a 100A breaker for the new panel CP. Please advise if a new circuit breaker in '2H2' is required to service the new transformer T-ULW - if yes, what size

Response: Yes, provide a 70A/3P, 480V, C.B. in Panel '2H2'.

- b. Sheet E3.1 shows O in ceiling, would this be WAP's?

Response: Yes, the O with WAP inside it are WAP's.

- c. This same page, Note 5 calls for HDMI inputs. Sheet E3.1 shows the locations with dual data outlets next to each one. In Note 5, it calls for a single port data jack and a Cat6 going to the data rack, are these for the HDMI? Do we still install the dual Cat6 outlet next to each HDMI? Sorry, I am confused as to where the HDMI inputs will go to and if you are asking for Cat6 to be used for the HDMI feeds?

Response: The intent of Note 5 is as follows – At each TV monitor is a 120V power outlet, a single CAT 6 data drop which is homerun to the data rack. An HDMI jack shall be mounted with power and data at each TV at the mounting height shown. An HDMI cable will be connected from jack to TV. An HDMI jack located on the wall at normal height will be connected to the jack behind the TV. The user will be able to plug in an HDMI cable at the lower jack to project to the TV.

Item No. 4 – PRIOR APPROVALS:

AD5.2: Approved Equals: Subject to compliance with the provisions of the Contract Documents, Drawings and Specifications the following manufacturers may be substituted for those named in the Specifications. Contractor shall note that prior approval is by manufacturer's name only. The Contractor shall ensure that the products used in preparation of his proposal and proposed to be used on this project, is equivalent to that specified in appearance, performance, size, installation type, and shape. Any material found to not be equivalent to that specified will be rejected. Prior approval of one manufacturer does not automatically prior approve any subsidiary company, parent company and/or sister company and their associated products.

Division 26 - Electrical

265100 Lighting Fixtures

<u>Type</u>	<u>Mfg</u>	<u>Description</u>
A	SIGNIFY	2FPZ38L835-2-DS-UNV-DIM
B	SIGNIFY	2FGXG45L835-2-RS-UNV-DIM
C	SIGNIFY	6RN / C6LXX835
D	WAC LIGHTING	LED-TCO-XX-RGB
X	SIGNIFY	CEE1RWA
X2	SIGNIFY	CEE2RWA

This is a public works bid. The addendum **MUST** be acknowledged with your bid on the BID FORM. For questions related to bidding these projects, please contact the UL Lafayette Purchasing Department at bids@louisiana.edu or 337.482.2955.

Marie C. Frank, MPA, CPPB
Assistant Vice President for Administration & Finance
University of Louisiana at Lafayette
Department of Purchasing

**NEW WOMEN'S BASKETBALL OFFICE SUITE
AT THE CAJUNDOME FOR THE UNIVERSITY OF LOUISIANA AT LAFAYETTE
Project No. 22006**

**Pre-Bid Conference
February 14, 2023
9:00 AM at the Cajundome (10:00 AM) START**

SIGN-IN SHEET

NAME	COMPANY	PHONE NUMBER / E-MAIL
Gene Sellers	TSG	(337) 232-0778 gene@tsgarchitecture.com
MARK BERGERON	TSG	(337) 232-0778 mabe@tsgarchitecture.com
Tom Van Dervent	ADG	337-234-5710 tvandervent@adginc.org
Patrick Piccrotti	ADG	PPiccrotti@adginc.org (337) 234-5710
Jimmy Bayard	Sibley	337-298-1915 Jimmy@SibleyConstruction.com
Beau Sibley	Sibley	337-581-0256 beausibley@sibleyconstruction.com
Christian Fulman	Sibley Construction	318-773-9605
Blayson Abshire	Sibley construction	
J.P. UNDERWOOD	SIBLEY CONSTR.	JPC@SIBLEYCONSTRUCTION.com 337-296-5950
Sean Derbigny	PIVOTAL	(25) 928-5569 Bids@pivotalperforms.com
Richard Beauregard	Jefferson Spilly	(318)-304-1972 Richie5.JSI@gmail.com
Ryan Roussel	Rudick	337-552-1885 rroussel@rudickgroup.com
Ken Savage	UL Lafayette	337-482-2001 KIMM.H.SAVAGE@ul.louisiana.edu

SIGN-IN SHEET

NAME	COMPANY	PHONE NUMBER / E-MAIL
DAVID BROUSSARD	AER PLUS	337-486-2941 DAVID@AERPLUSHVAC.NET
Lance Guillon	Chris' Electrical	337-981-0671 lanceg.ces@gmail.com
KEITH ISTRE	SKEETER CONTRACTORS	keith@skeetercontractors.com
Adam Fuselier	Master Builders	337-237-7176 adamf@mbsbuilds.com
John A. Dugas	University of Louisiana	337-654-3858 John.Dugas@Louisiana.edu
Scott Hebert	UL	337-482-2001 scott.hebert@Louisiana.edu
Gib Holland	Coastal Custom Builders	5093 fal commercial builders 337-288-1623 gmail.com
Ronald Ball	ULL	225-405-8089 RONALD.BALL@LOUISIANA.EDU
Mary Jo Adams	ULL	Mary.adams@Louisiana.edu
Chris Esparg	E+L Const. Group	337-224-1148 cespargo@elconstructiongroup.com
Amy FRANSEN	NRK Construction	225-933-6680 AMY@NRKCONSTRUCTION.COM
Kasey Kay	PERC Development	832-610-0135 Kasey.Kay@percdevelopment.com
Pat Ballard	PERC Development	337-296-6487 pat.ballard@percdevelopment.com
Brandon Simoneaux	Ashley Smith Construction, LLC	504-313-1589 brandon.s.as@GMAIL.COM
TRAVIS Long	Ashley Smith Construction	504-313-1589 TLong@ashleysmithconstruction.com
Joshua Gotte	Southern tile Co.	337-319-6388 souttile@netscape.net

SIGN-IN SHEET

NAME	COMPANY	PHONE NUMBER / E-MAIL
Chad Trahan	Southern Technologies	337.260.3486 Chad@southtnttechnologies.org
Abigail Richards	Skeeter	337-532-1096 Richardsa@skeetercontractors.com