July 19, 2023

Please find the following addendum to the below-mentioned **Quote**.

Addendum No.: 1 Quote#: 23-15-1

Project Name: Safe Haven ADA Handrails – Quads B & C

Quote Due Date: July 27, 2023

GENERAL INFORMATION:

Sign in sheet mandatory site visit (attached)

QUESTIONS AND ANSWERS:

Question 1. We are referring to the replacement of two forty-foot wooden ramps on the east side of building C. Understanding the scope of work is to repair, refurbish, and repaint the metal handrails while also making them ADA compliant, the spacing of the rails do not appear to be in compliance and some sections are showing significant weathering. The metal handrails on the wood supports need to be extended outward to be compliant with the ADA. Should the contractor exclude the wood sections, on removing and replacing the wood sections, or replace them with metal handrails to comply with ADA standards?

Answer 1. Yes, the handrails should comply with ADA standards. Remove wood sections and replace with metal to meet compliance

ATTAHCMENTS:

Sign in sheet mandatory site visit.pdf

End of Addendum #1

Safe Haven Campus 23365 S Robin Rd Mandeville, LA 70470

Mandatory Site Visit Sign In Sheet

Safe Haven ADA Handrails Quads B & C

| Name | Company | Email | Phone | Time In | Time Out |
|----------------|----------------------|-----------------------------|----------------------------|-----------|----------|
| 1 Shawn Carter | Pivotal | Bils & pivotal performs.com | ^ | 10:59 | 11:50 |
| 2 Reid Brasugy | Red Ox Construction | libreid@redoxemstruct.com | 985-400-4011 | 1.30-11 | 11:50 |
| 3 Model Tread | Garrison factical | Maneral & garassa intermial | | 5:50 1058 | 11;51 |
| Billy DAVAULT | Garrison tactical | billy@gasrisontocticalse | 337 rukes. Com 764-2678 | 9:30 | 11:51 |
| 5 JIM DEWITT | STP | JIDEWITT @ STPHOV. O RU | \$85-858-2792 | 9:30 | |
| 6 Shawn Hoover | STP : | 3) hoover@ Stpgov. org | 985-898-2520 | 7:30 | |
| Hurley LeuIs | Heils Enterpose inc | HL Offeils enterprise. Com | 985 4743457 | 10:57 | 11.20 |
| · Blaze Keller | Webb-Rise Saley | blace Quebbrite Safety | 225-509-7233 | 11:00 | 11:49 |
| ° CHRIS LENTEK | VIRIDIS CONSTRUCTION | chris eviridisac.com | 504-493-3899 | 10:58 | 11:50 |
| 10 | | | | | |
| 11 | | ; | | | |
| 12 | | | | | |
| 13 | | | | , | |