



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

September 11, 2023

ADDENDUM # 1

Bid Number: 50-00143002

Bid Opening Date: September 14, 2023 at 2:00 pm cst

Description of Bid: Supply and Install a Fully Integrated Building Management System (BMS) at the Jefferson Parish Emergency Operation and Communication Center

CLARIFICATION:

- Question:** on page 2 of 8 under Section 7.0 General Description/Locations: "Note" says "unless specifically noted to remain, all controls and devices shall be replaced." Are you expecting all controls hardware to be replaced? Or are you specifying the replacement of one obsolete MEC and the computer for software? There are 4 large controllers and 83 terminal unit controllers installed onsite. Does this bid specify that all of that should be replaced?

Answer: The MEC, computer, and software shall be replaced. Any controllers that will not integrate with the new Building Management System shall be replaced with new equipment also.

Sincerely,

A handwritten signature in black ink that reads "Doris Abraham".

Doris Abraham
Purchasing Specialist II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.