



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

October 19, 2023

Please find the following addendum to the below mentioned BID.

Addendum No.: 1

Bid#: 23-39-2

Project Name: Berry Todd Rd Bridge

Bid Due Date: Wednesday, October 25, 2023

QUESTIONS & ANSWERS:

Question 1: Will the concrete will be subject to resistivity testing by the state?

Answer 1: Resistivity testing will not be required for the concrete.

<< End of Addendum # 1 >>