

JEFFERSON PARISH

DEPARTMENT OF PURCHASING

RENNY SIMNO DIRECTOR

October 13, 2023

ADDENDUM #1

Bid Number: <u>50-00143335</u> Bid Opening Date: October 26, 2023

Description of Bid: <u>Labor, materials and all equipment necessary to clean, coat, layout, paint and stripe the seventh floor concrete of the parkiung Garage for Jefferson Parish General Services.</u>

Answer vendor questions.

1. Specification section 7.7 – Traffic Membrane Installation – this section stated one base coat and one top coat (2 coat system). Since this is a vehicular membrane system, the system will require one base coat, one intermediate coat, and one top coat (3 coat system). Please confirm that a three coat system shall be included in the bid.

Answer: Per section 7.7 you Master seal base coat(1) you have Master seal 940/941 (2) and master seal tc225 top coat (3).

2. At the perimeter of the parking deck and along one side of the ramp, there is a gap between the existing slab and the precast perimeter wall. Please confirm that this gap is to remain open.

Answer: Yes.

3. Please confirm that the generator located within the fenced in area is to remain in place and that the traffic coating will be installed around the base of this unit and not under the unit.

Answer: Yes.

Sincerely

Donna Reamey ^{*} Purchasing Specialist II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

JOSEPH S. YENNI BUILDING-1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242 OFFICE 504.364-2678