



# The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

October 13, 2023

## Addendum No. 3

Your reference is directed to the Request for Quotation for **2023-SWB-79 – Saltwater Intrusion Emergency 2023 - Algiers Intake Mitigation (Rebid)** for the Sewerage and Water Board of New Orleans proposals that are due on **October 16, 2023, at 11:00 a.m. (CST)**.

This addendum provides for the following:

- 1. Answer to question.**
- 2. Voluntary Extensions of the Award Form.** Required at bid submission. Failure to submit form will deem your bid submission non-responsive.

---

### Question

- Neither connector E22 nor L8 is available in ASTM A572 Grade 60. Can you please advise if ASTM A572, Grade 50 is acceptable?  
***ASTM A572, Grade 50 is acceptable for the E22 or L8 connectors.***

---

*The changes, additions, and/or deletions included herein are hereby made part of the solicitation documents for 2023-SWB-79 for Request for Quotation for Saltwater Intrusion Emergency 2023 - Algiers Intake Mitigation (Rebid), as fully and completely as if the same were set forth therein. The proposer shall be responsible for having knowledge of all addendums issued for this RFQ. Failure to comply with the revisions in this and all addendums may deem your bid submission non-responsive.*

This addendum consists of 2 pages.

**End of Addendum**



# **The Sewerage & Water Board OF NEW ORLEANS**

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

## **VOLUNTARY EXTENSIONS OF THE AWARD**

If this bid is determined to be the lowest responsive and responsible bid, Bidder agrees to bid extension of the award date by up to two (2) thirty (30) day periods.

**AGREED:**

---

**NAME OF BIDDER (TYPE OR PRINT)**

---

**SIGNATURE OF BIDDER**

---

**COMPANY NAME**

---

**DATE**

**\*\*\* END OF SECTION \*\*\***