

**STATE OF LOUISIANA
SOWELA TECHNICAL COMMUNITY COLLEGE
ADDENDUM 3**

PURCHASING AGENT: Susan Tucek

EMAIL: susan.tucek@sowela.edu

BID NUMBER

80880

BID OPENING DATE/TIME: 01/29/24 10:00 AM		PRE-BID SITE VISIT 12/21/23 & 01/11/24 10:00 AM			
VENDOR NAME		DELIVER BID BEFORE OPENING DATE/TIME TO: SOWELA TECHNICAL COMMUNITY COLLEGE SUSAN TUCEK 3820 SEN J B JOHNSTON AVENUE LAKE CHARLES, LA 70615 INVOICE TO: ACCOUNTS PAYABLE SOWELA TECHNICAL COMMUNITY COLLEGE PO BOX 16950 LAKE CHARLES, LA 70616-6950			
SIGNATURE:					
DATE:					
LINE NO	COMMODITY/SERVICE DESCRIPTION	QUANTITY ORDERED	UNIT	UNIT PRICE	EXTENDED AMOUNT
	ADDENDUM 3 IS TO EXTEND THE BID OPENING DATE AND TIME TO FEBRUARY 23, 2024 AT 10 AM. THIS ADDENDUM IS ALSO TO ANSWER THE FOLLOWING QUESTIONS: 1 DOES THE DAVIS BACON APPLY TO THIS PROJECT? YES 2 WHAT IS THE TAX STATUS OF THIS PROJECT? TAX EXEMPT				
CONTINUED ON NEXT PAGE					

LINE NO	COMMODITY/SERVICE DESCRIPTION				
	<p>SHEET E2, 2A, KEYNOTE 3: QUANTITY AND TYPE OF LIGHTS SHOWN ON PLANS. DELETE REQUIREMENT TO VERIFY NUMBER OF LIGHTS PRIOR TO BID.</p> <p>SHEET E2, 2B, KEYNOTE 4: QUANTITY AND TYPE OF LIGHTS SHOWN ON PLANS. DELETE REQUIREMENT TO AND VERIFY NUMBER OF LIGHTS PRIOR TO BID.</p> <p>SHEETS MP0.1 AND MP0.2: EACH PHASING AREA SHALL BE FULLY CLEANED PRIOR TO MOVING TO THE NEXT PHASE OF CONSTRUCTION.</p> <p>SHEETS MP1.1A, 1.1B, 1.2A, 1.2B: NEW CONDENSATE DRAIN LINES SHALL BE INSTALLED PRIOR TO DEMOLITION OF EXISTING FAN CONDENSATE DRAIN LINES IN ORDER TO MAINTAIN COOLING, ESPECIALLY IN AREAS WHERE THE EXISTING FAN COIL UNITS ARE TO REMAIN.</p> <p>AT CONTRACTOR'S OPTION, NEW VALVES FOR PIPING 3 IN AND BELOW MAY BE BALL VALVES IN LIEU OF BUTTERFLY VALVES.</p> <p>SHEET M2.1B: REFER TO REVISED SHEET M2.1B-R THIS ADDENDUM FOR SUPPLY AIR ADDED TO IDF 118.</p> <p>SHEET M2.2B: REFER TO REVISED SHEET M2.1B-R THIS ADDENDUM FOR SUPPLY AIR ADDED TO MDF 209.</p> <p>SHEET M3.1: REFER TO REVISED SHEET M3.1R FOR I SUPPLY AND RETURN GRILLES.</p>				