



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

February 6, 2024

Please find the following addendum to the below-mentioned BID.

Addendum No.: 1

Bid#: 24-1-2

Project Name: Safe Haven Water Utility Improvements

Bid Due Date: February 15, 2024

GENERAL INFORMATION:

1. A pre-bid meeting was held on January 25, 2024. A copy of the sign-in sheet is attached.

QUESTIONS & ANSWERS:

QUESTION 1: Where is the electrical rack and equipment to be located?

ANSWER 1: The location of the electrical equipment is shown on Sheet C1.3 on the “Chemical Building Detail” for each of the wells.

QUESTION 2: You are asking for a 100/3 SN ATS but do not show any generator connections. Will the generator work be done by others?

ANSWER 2: The generators are not a part of this project.

ATTACHMENTS:

1. Pre-Bid Meeting sign-in sheet

End of Addendum #1

