

JEFFERSON PARISH

DEPARTMENT OF PURCHASING

RENNY SIMNO DIRECTOR

March 21, 2024

ADDENDUM # 2

Bid Number: 50-00144505 Bid Opening Date: March 26, 2024 at 2:00 pm

Description of Bid: Labor, Materials and Equipment Necessary to Replace Roof Top HVAC Units for the Jefferson Parish Library Department, Lafitte Library

Clarification

Q1: We have a question in regards to Section 7.5 of Bid# 50-00144505(below). We were under the understanding after leaving the pre-bid meeting that the building does not currently have any FMS system in place. If this is correct, should we simply disregard section 7.5?

SECTION 7.5 – DDC CONTROLS SCOPE:

Design and install new 3D graphics for rooftop units. Map all relevant points to the graphics for the newly installed rooftop unit to the existing Desigo FMS (facility management system). The successful bidder must coordinate with Siemens (proprietary) to map all relevant points to the graphics for the newly installed rooftop units.

A1: The build does employ a facility management system. Desigo is a proprietary program used by Siemens. As stated, is Section 7.5 the mapping of relevant points must be coordinated with Siemens.

Sincerely,

Mark Buttery

Purchasing Specialist II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

EMAIL: Purchasing@jeffparish.net website: www.jeffparish.net