

JEFFERSON PARISH

DEPARTMENT OF PURCHASING

RENNY SIMNO DIRECTOR

April 4, 2024

ADDENDUM # 1

Bid Number: 50-00144666 Receipt Date: April 23, 2024

<u>Labor, Materials & Equipment necessary to furnish & install Aluminum Bleachers at various playground locations for the Jefferson Parish Recreation Department</u>

Clarification & Revision

1) QUESTION: Hoping for some clarification on line item #3 on the upcoming aluminum bleacher bid for Jefferson Parish. The bleacher for Kings Grant Playground appears to be listed as a "non-elevated bleacher" but also calls for 30" elevation right below. Can you please confirm which model of NRS bleacher is being called for at Kings Grant Playground so we can price out accordingly?

ANSWER: Install one (1) National Recreation Systems, Inc. (or approved equal) 30" elevated 5 rows X 55'-6" long bleacher at KINGS GRANT PLAYGROUND football field, left side of Pressbox.

*** REVISED SPECIFICATION SHEET ATTACHED ***

PLEASE SUBMIT ALL QUESTIONS IN EMAIL FORM. DEADLINE FOR WRITTEN INQUIRIES IS APRIL 12, 2024 BY 4:30 P.M.

*** THE LAST ADDENDUM WILL BE POSTED NO LATER THAN APRIL 18, 2024 BY 2:00 P.M.***

***REMEMBER TO ACKNOWLEDGE THIS ADDENDUM BY NUMBER ON YOUR RFP SUBMISSION. ***

Shanna Folse, Purchasing Specialist II
Jefferson Parish Purchasing Department

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

EMAIL: PURCHASING@JEFFPARISH.NET WEBSITE: WWW.JEFFPARISH.NET

- All hardware to be Hot Dipped Galvanized in nature
- Owner will remove and dispose of all bleachers
- 2.) <u>LINE ITEM #2</u>- Install six (6) National Recreation Systems, Inc. (or approved equal) 5 row x 15 foot-long, (42) seating capacity non-elevated bleacher with groundsills and auger anchors at OAKDALE PLAYGROUND, 1 set of bleachers at Field #3; 1st and 3rd baseline, Field #7; 3rd baseline, Soccer Field #8 1st & 3rd baselines and Field #1; 1st baseline.
 - Aluminum angle frame
 - Understructure to be 2" X 2" X 3/16" and 1 ½" X 1 ½" X 3/16", 6061 T-6 welded aluminum angle
 - 2 X 10 anodized aluminum seat plank with poly end caps
 - Double mill finished aluminum foot plank with aluminum end cap
 - 1 X 6 mill riser rows, 2-4, (2) 1 X 6 top row risers
 - (1) 36inch vertical aisle and handrail (on one end)
 - Chain link guardrail system
 - All hardware to be Hot Dipped Galvanized in nature
 - Owner will remove and dispose of all bleachers
- 3.) <u>LINE ITEM #3</u>- Install one (1) National Recreation Systems, Inc. (or approved equal) 30" elevated 5 rows X 55'- 6" long bleacher at KINGS GRANT PLAYGROUND football field, left side of Pressbox.
 - Aluminum angle understructure w/8" rise /24" run.
 - 30" elevation, 63" clear front walkway
 - 2 x 10 anodizes aluminum seat plank with poly end caps
 - Double 2 x 10 mill finish aluminum seat plank w/ end caps
 - 1 x 65 riser rows 1-4 and (2) 1 x 6 top row risers mill finish
 - (2)4' x 6" wide vertical aisle with mid aisle handrail
 - 2 sets of entry stairs
 - Chain link guardrail system

Exact Location of each bleacher to be installed will be determined by the owner

REVISED PER ADDENDUM #1