



# The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

May 1, 2024

## Addendum No. 4

Your reference is directed to the Invitation to Bid for: **2024-SWB-16 Contract 1452 Structural and Filter Rehabilitation in Sycamore Filter Gallery Filters #19, 20, 25, 26 & 28** for the Sewerage and Water Board of New Orleans, which proposals are due on **May 6, 2024**, at **11:00 a.m.** CST.

This addendum provides additions to the specification:

Section 011000 – Summary: Paragraph 1.6 – Work Sequence:

C. Filters #19 and 25 are out of service. Contractor shall prioritize replacement of valves, actuators, and filter media in these out-of-service filters prior to work on active filters. It is the intent of this contract to regain use of inactive filters prior to shutting down filters that are currently active.

*The changes, additions, and/or deletions included herein are hereby made part of the solicitation documents for 2024-SWB-16 Contract 1452 Structural and Filter Rehabilitation in Sycamore Filter Gallery Filters #19, 20, 25, 26 & 28, as fully and completely as if the same were set forth therein. The bidder shall be responsible for having knowledge of all addendum issued for this ITB.*

This addendum consists of one (1) page.  
\*\*\* END OF ADDENDUM \*\*\*