



# JEFFERSON PARISH

## DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG  
PARISH PRESIDENT

RENNY SIMNO  
DIRECTOR

May 14, 2024

### ADDENDUM # 1

**Bid Number: 50-00145129**

**Bid Opening Date: May 23, 2024 at 2:00 pm**

**Description of Bid: Labor, Materials and Equipment Necessary to Provide Tank Cleaning, sludge Removal, Dewatering and Hauling for the Department of Sewerage**

---

#### Clarification

**Q1:** Under equipment, the specs call for a trailer dewatering system. Will Jefferson Parish allow mechanical dewatering with a belt press or centrifuge?

**A1: Vendor may quote on using different equipment, provided description of the equipment and photo are submitted with bid.**

**Q2:** Please clarify under Section 2.1, A,3 "Weekly project size shall be no less than 250 gallons".

**A2: There was an error in the specs and it should read "weekly project size shall be no less than 250,000 gallons".**

**Q3:** Will the parish provide current TCLP's for each plant?

**A3: TCLP's must be obtained by Public Records Request. Visit [www.jeffparish.net](http://www.jeffparish.net) select I Want To tab on top of page then select Submit Public Records Request <https://jeffersonparishla.nextrequest.com/>**

**Q4:** Will the parish provide the required electrical service requirements?

**A4: Awarded contractor shall provide their own power.**

**Q5:** Will the parish consider allowing a separate mobilization/demobilization for each plant?

**A5: This will be at the contractor's discretion.**

**Q6:** Can you provide the physical addresses of each plant?

**A6:** EB Plant: #2 Humane Way, Harahan, LA 70123

**Bridge City Plant:** 1400 Hwy. 90 West, Bridge City, LA 70094

**Marrero Plant:** 6250 Lapalco Blvd, Marrero, LA 70072

**Harvey Plant:** 2343 Paillet St., Harvey, LA 70058

**Q7:** When were the tanks last cleaned?

**A7:** Marrero Plant around 2015; Harvey Plant around 2016; Bridge City, not cleaned since put into operation around 1987-88; Eastbank Plant, over 5 year ago.

**Q8:** Site Visits

**A8:** Site Visits available upon request. Email: [DToups@jeffparish.net](mailto:DToups@jeffparish.net) for more information.

Sincerely,



---

Mark Buttery  
Purchasing Specialist II

**Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.**

**This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.**