



# The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

May 17, 2024

## Addendum No. 1

Your reference is directed to the Invitation to Bid for: **2024-SWB-22 Maintenance and Repair of Algiers Water Tower** for the Sewerage and Water Board of New Orleans, which proposals are due on **May 29, 2024**, at **11:00 a.m.** CST.

This addendum provides Revisions to Section 7.

1. Revisions to Technical Specifications, Section 7 **Painting** , **Subsections a-g**, Page 11 and 12

### 7. Painting

- a. Coatings shall be in strict compliance with D102-21: AWWA STANDARD FOR COATING STEEL WATER-STORAGE TANKS
- b. First (Primer) Coat shall be Tnemec Series 91 H<sub>2</sub>O Hydro-Zinc, thickness 2.5-3.5 dry mils.
- c. After completion of blast-cleaning and applying the first coat, all pits shall be filled with Tnemec Series 215 Pit Filler or equal.
- d. Stripe coat shall be applied by contractor to interior weld seams and nuts and bolts and ladder using Tnemec Series 21 Epoxoline or equal.
- e. Intermediate coat shall be Series 21 Epoxoline beige 5.0-7.0 dry mils.
- f. Finish coat shall be Series 21 Epoxoline 5.0-7.0 dry mils.
- g. Upon completion of the blast-cleaning and three (3) coat paint system, all weld seams shall be caulked using Sika Flex One or equal.

*The changes, additions, and/or deletions included herein are hereby made part of the solicitation documents for 2024-SWB-12 Contract 1457 Maintenance and Repair of Algiers Water Tower, as fully and completely as if the same were set forth therein. The bidder shall be responsible for having knowledge of all addendum issued for this ITB.*

This addendum consists of two (1) pages.

**\*\*\* END OF ADDENDUM \*\*\***