

JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG Parish President RENNY SIMNO DIRECTOR

May 22, 2024

## ADDENDUM # 2

Bid Number: 50-00144944

Bid Opening Date: June 6, 2024 at 2 p.m.

## Remove Existing, Supply and Install New Boilers at the Jefferson Parish Correctional Center

## **CLARIFICATIONS:**

- <u>Q1</u>. Lead time for boilers is 9-11 weeks currently. Will this be taken into consideration of the 30 days to complete work? Will this 30 days be extended or will time start once equipment arrives?
- <u>A1</u>. Notice to Order will be given at the pre-construction meeting, then once equipment arrives a 30 day Notice to Proceed is given.
- **<u>Q2</u>**. Per the manufacture's spec (Rite boilers), they require circulator pumps for each boiler on the leaving side. Will there be any addendum requiring this?
- <u>A2.</u> The boilers have one (1) primary pump and one (1) secondary pump located inside the mechanical room that are not being replaced.

Bid opening date will remain the same, June 6, 2024. Be sure to acknowledge Addendum No. 2 on the Signature Page of the Bid Form.

Sincerely. Iraham / ALTO(

Doris Abraham Purchasing Specialist II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

JOSEPH S. YENNI BUILDING -1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242 OFFICE 504.364-2678