



LOUISIANA TECH
UNIVERSITY.

Purchasing

ADDENDUM #2

June 26, 2024

RE: Bid Number: 50012-571-25 for Elevator Preventative Maintenance, Repair, and Emergency Services

- Sealed Bids are still due at 2:00PM on Wednesday, July 3, 2024 in the Office of Purchasing located in Keeny Hall room 408 (208 Keeny Circle, Ruston, LA 71272)
- **Questions and Answers:**
 - Bid Tabulation from the last Bid Opening for Elevator Maintenance & Repair at Louisiana Tech University (Bid No. 50012-432-19, June 20, 2019) OR – The "per month" price that Louisiana Tech University is currently paying for Elevator Maintenance & Repair Services.
 - **The current cost per month is \$15,945.00.**
 - Will the expired full load five-year traction tests at Wyly Tower be completed prior to the award?
 - **No**
 - Can you share the most recent QEI reports for the elevator portfolio?
 - **Please see attached**

All other specifications remain unchanged.

Sincerely,

Zynthia L. Rhodes
Assistant Director of Purchasing
Louisiana Tech University
(318) 257-4205
zrhodes@latech.edu

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Tech Pointe
500 W. Arizona
Ruston, LA 71270

Location ID:

731002-98

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0250

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 4000

Inspector Notes:

Testing Results: Relief (psi): 550, Working (psi): 200,

Inspection Start Time: 12:30:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 2/4/2011

Plunger Gripper?

Speed: 125

Inspection End Time: 1:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: Schindler

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

Inspector Comments

Corrected?

1.3 Operating control devices

2.14.7.1.3 - Repair in car emergency lights

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0250 Device Type: Hydraulic Elevator Date: 11/7/2023 Inspection Type: Category 1 Test
 Firm #: 33 Code Edition: Location Contact Name: JOE PEEL
 Inspected By: Voiles, Jeff || Signature: Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Thomas Assembly Center
Bulldog Drive
Ruston, LA 71270

Location ID:

731002-78

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0251

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2100

Inspector Notes:

Testing Results: Relief (psi): 300, Working (psi): 155,

Inspection Start Time: 2:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 6/6/1980

Plunger Gripper?

Speed: 100

Inspection End Time: 2:30:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Dover

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	2.14.7.1.3 - Repair in car emergency light 2.27.1 - Repair In car alarm bell	No
5.1 Pit access; lighting; stop switch; and condition	2.2.4.2 - Extend elevator pit ladder 48 inches above floor sill for proper access	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0251

Device Type: Hydraulic Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM							
2.1 Access to machinery space	X			3.32 Speed Test			X
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels	X		
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment	X			4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal			X	4.10 Emergency doors in blind hoistways			X
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.30 Hydraulic power unit	X			5 PIT			
2.31 Relief valves	X			5.1 Pit access, lighting, stop switch & condition			X
2.32 Control valve	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.33 Tanks	X			5.4 Normal terminal stopping devices	X		
				5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy			X	5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
				5.17 Plunger gripper			X
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04			X
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Tolliver Hall
Arizona Ave
Ruston, LA 71270

Location ID:

731002-42

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0252

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 4500

Inspector Notes:

Testing Results: Relief (psi): 700, Working (psi): 220,

Inspection Start Time: 12:30:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 2/2/2002

Plunger Gripper?

Speed: 100

Inspection End Time: 1:30:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Otis

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

5.1 Pit access; lighting; stop switch; and condition

1.3 Operating control devices

Inspector Comments

3.18.3.7 - Remove oil from elevator pit

2.14.7.1.3 - Repair in car emergency lights

2.27.1- Repair in car emergency bell

Corrected?

No

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0252

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition			X
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

University Hall
Keeny Circle
Ruston, LA 71270

Location ID:

731002-58

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspection Start Time: 4:30:00 PM

Inspection End Time: 5:00:00 PM

Inspector: Voiles, Jeff ||

Inspection Type: Category 1 Test

Inspection Result: Passed - Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0253

Device Type: Hydraulic Elevator

of Landings: 2

Due Month: November

Device Use: Passenger

Device Designation: #1

Code Edition:

Installation Date: 6/5/2010

Device Manufacturer: Schindler

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 2500

Speed: 125

Inspector Notes:

Testing Results: Relief (psi): 620, Working (psi): 240,

Violation Information:

Previous Violations

Previous Violation

Inspector Comments

Corrected?

2.1 Access to machine space

A17.1- 2.7.1.1 Patch holes and provide fire proofing in elevator machine room

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0253 **Device Type:** Hydraulic Elevator **Date:** 11/8/2023 **Inspection Type:** Category 1 Test
Firm #: 33 **Code Edition:** **Location Contact Name:** JOE PEEL
Inspected By: Voiles, Jeff || **Signature:** **Location Contact Signature:**

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM							
2.1 Access to machinery space		X		3.32 Speed Test			X
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels	X		
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment	X			4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal			X	4.10 Emergency doors in blind hoistways			X
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.30 Hydraulic power unit	X			5 PIT			
2.31 Relief valves	X			5.1 Pit access, lighting, stop switch & condition	X		
2.32 Control valve	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.33 Tanks	X			5.4 Normal terminal stopping devices	X		
2.36 Hydraulic cylinders	X			5.5 Traveling cables	X		
2.37 Pressure switch	X			5.6 Governor-rope tension devices			X
2.38 Roped water hydraulic elevators			X	5.7 Car frame and platform	X		
2.39 Low oil protection	X			5.8 Car and counterweight safeties and guiding members			X
2.40 Maintenance records	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.41 Hydraulic control	X			5.12 Car buffers	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.13 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.14 Guiding members [rails, rollers, slides]	X		
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.15 Overspeed valve			X
3 TOP OF CAR							
3.1 Top-of-car stop switch	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3.2 Car top light and outlet	X			5.17 Plunger gripper			X
3.3 Top-of-car operating device	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.6 Final and emergency terminal stopping devices	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.7 Top-of-car operating device	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.5 A 17.1-2000/644-00			X
				6.6 A 17.1-2004/644-04			X
				6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Wyly Tower Of Learning
Railroad Ave
Ruston, LA 71270

Location ID:
731002-75

Location Contact Information:
Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0104

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 12:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 5/3/2000

Capacity: 3000

Inspection End Time: 1:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 6

Device Designation: #4

Device Manufacturer: Schindler

Speed: 450

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 2.14.7.1.3 Repair, emergency lighting located inside of elevator's	No
1.18 Restricted opening of car or hoistway doors	8.6.4.13 - Repair Car door restrictor	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide cartop hand rails	No
3.13 Windows; projections; recesses; and setbacks	2.1.6.2 - Provide bevels on ledges located in elevator hoistway	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct size diameter hobble cable on the hoist rope shackles	No
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide a Guard on Elevator hoist machine	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0104

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR				OK NG N/A			
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X		
1.2 Stop Switches	X			3.8 Top emergency exit	X		
1.3 Operating control devices		X		3.9 Floor and emergency identification numbering	X		
1.4 Sills and car floor	X			3.10 Hoistway construction	X		
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X		
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X		
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks		X	
1.8 Door closing force	X			3.14 Hoistway clearances	X		
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X		
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X		
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X		
1.12 Car enclosure	X			3.18 Car frame and stiles	X		
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X		
1.14 Ventilation	X			3.20 Governor rope	X		
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X		
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X		
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X		
1.18 Restricted opening of car or hoistway doors		X		3.27 Crosshead data plate and rope data tags	X		
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29 Counterweight safeties			X
2 MACHINE ROOM				OK NG N/A			
2.1 Access to machinery space	X			3.30 Speed Test	X		
2.2 Headroom	X			3.33 Compensating ropes and chains	X		
2.3 Lighting and receptacles	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.4 Machinery space	X			4 OUTSIDE HOISTWAY			
2.5 Housekeeping	X			4.1 Car platform guard	X		
2.6 Ventilation	X			4.2 Hoistway doors	X		
2.7 Fire extinguisher	X			4.3 Vision panels	X		
2.8 Pipes, wiring, and ducts	X			4.4 Hoistway door-locking devices	X		
2.9 Guarding of exposed auxiliary equipment		X		4.5 Access to hoistway	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.6 Power closing of hoistway doors	X		
2.11 Disconnecting means and control	X			4.7 Sequence operation	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.8 Hoistway enclosure	X		
2.13 Governor, overspeed switch, and seal	X			4.9 Elevator parking devices	X		
2.14 Code data plate	X			4.10 Emergency doors in blind hoistways			X
2.15 Static control	X			4.12 Standby power selection switch	X		
2.16 Overhead beam and fastenings	X			5 PIT			
2.17 Drive machine brake	X			5.1 Pit access, lighting, stop switch & condition	X		
2.18 Traction-drive machines	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.19 Gears, bearings, and flexible couplings	X			5.3 Final and emergency terminal stopping devices	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.4 Normal terminal stopping devices	X		
2.21 Belt- or chain-drive machine		X		5.5 Traveling cables	X		
2.22 Motor generator		X		5.6 Governor-rope tension devices	X		
2.23 Absorption of regenerated power	X			5.7 Car frame and platform	X		
2.24 AC drives from a DC source	X			5.8 Car and counterweight safeties and guiding members	X		
2.25 Traction sheaves	X			5.9 Buffers and emergency terminal speed-limiting devices	X		
2.26 Secondary and deflector sheaves	X			5.10 Compensating chains, ropes & sheaves	X		
2.27 Rope fastenings	X			5.12 Car buffers	X		
2.28 Terminal stopping devices	X			5.13 Guiding members [rails, rollers, slides]	X		
2.29 Car and counterweight safeties	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.40 Maintenance records	X			6 FIREFIGHTERS' SERVICE (FEO)			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.1 A17.1b-1973 through A17.1b-1980			X
3 TOP OF CAR				OK NG N/A			
3.1 Top-of-car stop switch	X			6.2 17.1-1981 through A17.1b-1983			X
3.2 Car top light and outlet	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.4 Top-of-car clearance, refuge space, and standard railing		X		6.5 A 17.1-2000/644-00			X
3.5 Normal terminal stopping devices	X			6.6 A 17.1-2004/644-04			X
3.6 Final and emergency terminal stopping devices	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Wyly Tower Of Learning
Railroad Ave
Ruston, LA 71270

Location ID:

731002-75

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0105

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 11:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 8/3/2000

Capacity: 3000

Inspection End Time: 12:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 6

Device Designation: #5

Device Manufacturer: Schindler

Speed: 450

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- Repair emergency lighting, located inside of elevator	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide cartop handrails	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct diameter hobble cable for hoist rope shackles	No
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide guards on the elevator hoist machine	No
3.9 Floor and emergency identification numbering	2.29.2 - Provide floor numbers at each landing located inside of hoistway on hoistway doors	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0105

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A		
1.1 Door reopening device	X				
1.2 Stop Switches	X				
1.3 Operating control devices		X			
1.4 Sills and car floor	X				
1.5 Car lighting and receptacles	X				
1.6 Car emergency signal	X				
1.7 Car door or gate	X				
1.8 Door closing force	X				
1.9 Power closing of doors or gates	X				
1.10 Power opening of doors or gates	X				
1.11 Car vision panels and glass car doors	X				
1.12 Car enclosure	X				
1.13 Emergency exit	X				
1.14 Ventilation	X				
1.15 Signs and operating device symbols	X				
1.16 Rated load, platform area, and data plate	X				
1.17 Standby power operation	X				
1.18 Restricted opening of car or hoistway doors	X				
1.19 Car ride	X				
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		
2 MACHINE ROOM	OK	NG	N/A		
2.1 Access to machinery space	X				
2.2 Headroom	X				
2.3 Lighting and receptacles	X				
2.4 Machinery space	X				
2.5 Housekeeping	X				
2.6 Ventilation	X				
2.7 Fire extinguisher	X				
2.8 Pipes, wiring, and ducts	X				
2.9 Guarding of exposed auxiliary equipment		X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X				
2.11 Disconnecting means and control	X				
2.12 Controller wiring, fuses, grounding, etc.	X				
2.13 Governor, overspeed switch, and seal	X				
2.14 Code data plate	X				
2.15 Static control	X				
2.16 Overhead beam and fastenings	X				
2.17 Drive machine brake	X				
2.18 Traction-drive machines	X				
2.19 Gears, bearings, and flexible couplings	X				
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X		
2.21 Belt- or chain-drive machine		X			
2.22 Motor generator		X			
2.23 Absorption of regenerated power	X				
2.24 AC drives from a DC source	X				
2.25 Traction sheaves	X				
2.26 Secondary and deflector sheaves	X				
2.27 Rope fastenings	X				
2.28 Terminal stopping devices	X				
2.29 Car and counterweight safeties	X				
2.40 Maintenance records	X				
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		
3 TOP OF CAR	OK	NG	N/A		
3.1 Top-of-car stop switch	X				
3.2 Car top light and outlet	X				
3.3 Top-of-car operating device	X				
3.4 Top-of-car clearance, refuge space, and standard railing		X			
3.5 Normal terminal stopping devices	X				
3.6 Final and emergency terminal stopping devices	X				
3.7 Car leveling and anticreep devices	X				
3.8 Top emergency exit	X				
3.9 Floor and emergency identification numbering			X		
3.10 Hoistway construction	X				
3.11 Hoistway smoke control	X				
3.12 Pipes, wiring, and ducts	X				
3.13 Windows, projections, recesses, and setbacks	X				
3.14 Hoistway clearances	X				
3.15 Multiple hoistways	X				
3.16 Traveling cables and junction boxes	X				
3.17 Door and gate equipment	X				
3.18 Car frame and stiles	X				
3.19 Guide rails, fastenings, and equipment	X				
3.20 Governor rope	X				
3.21 Governor releasing carrier	X				
3.22 Wire rope fastening and hitch plate	X				
3.23 Suspension compensation and governor systems	X				
3.27 Crosshead data plate and rope data tags	X				
3.28 Counterweight and counterweight buffer	X				
3.29 Counterweight safeties				X	
3.30 Speed Test	X				
3.33 Compensating ropes and chains	X				
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)					X
4 OUTSIDE HOISTWAY	OK	NG	N/A		
4.1 Car platform guard	X				
4.2 Hoistway doors	X				
4.3 Vision panels	X				
4.4 Hoistway door-locking devices	X				
4.5 Access to hoistway	X				
4.6 Power closing of hoistway doors	X				
4.7 Sequence operation	X				
4.8 Hoistway enclosure	X				
4.9 Elevator parking devices	X				
4.10 Emergency doors in blind hoistways					X
4.12 Standby power selection switch	X				
5 PIT	OK	NG	N/A		
5.1 Pit access, lighting, stop switch & condition	X				
5.2 Bottom clearance, runby & minimum refuge space	X				
5.3 Final and emergency terminal stopping devices	X				
5.4 Normal terminal stopping devices	X				
5.5 Traveling cables	X				
5.6 Governor-rope tension devices	X				
5.7 Car frame and platform	X				
5.8 Car and counterweight safeties and guiding members	X				
5.9 Buffers and emergency terminal speed-limiting devices	X				
5.10 Compensating chains, ropes & sheaves	X				
5.12 Car buffers	X				
5.13 Guiding members [rails, rollers, slides]	X				
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)					X
6 FIREFIGHTERS' SERVICE (FEO)	OK	NG	N/A		
6.1 A17.1b-1973 through A17.1b-1980					X
6.2 17.1-1981 through A17.1b-1983					X
6.3 A17.1-1984 through A17.1a-1988 and A17.3					X
6.4 A17.1b-1989 through A17.1d-2000	X				
6.5 A 17.1-2000/644-00					X
6.6 A 17.1-2004/644-04					X
6.7 A17.1-2007/B44-07					X
6.8 A17.1-2010/B44-10					X
6.9 A17.1-2013/B44-13					X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

<p>Location Address: Wyly Tower Of Learning Railroad Ave Ruston, LA 71270</p>	<p>Location ID: 731002-75</p>	<p>Location Contact Information: Name: JOE PEEL Title: Phone: +13182573267 Email: JPEEL@LATECH.EDU</p>
--	--	---

Inspection Information:

<p>Inspection Date: 11/8/2023 Inspector: Voiles, Jeff Re-Inspection Required: No Device ID: T0106 Due Month: November Code Edition: Cat 5 Required? Inspector Notes: Testing Results:</p>	<p>Inspection Start Time: 10:00:00 AM Inspection Type: Category 1 Test Generator Test Performed: No Device Type: Traction Elevator Device Use: Passenger Installation Date: 5/3/2000 Capacity: 3000</p>	<p>Inspection End Time: 11:00:00 AM Inspection Result: Passed - Violations Re-Inspection Maint Co Required: No # of Landings: 6 Device Designation: #6 Device Manufacturer: Schindler Speed: 450</p>
---	--	---

Violation Information:

<u>Previous Violations</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 2.4.7.1.3 Repair emergency lighting, located inside of elevator	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide cartop hand rails	No
1.18 Restricted opening of car or hoistway doors	8.6.4.13 - Provide car door restrictor	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct diameter hobble cable on the hoist rope shackles	No
2.13 Governor; overspeed switch; and seal	8.11.1.6 - Provide correct dated five-year no load test tag on the governor	No
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide a Guard on the elevator hoist machine sheave	No
3.9 Floor and emergency identification numbering	2.29.2 - Provide floor numbers at each landing located inside of hoistway on the hoistway doors	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0106

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A				
1 INSIDE OF CAR				OK NG N/A				OK NG N/A			
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X						
1.2 Stop Switches	X			3.8 Top emergency exit	X						
1.3 Operating control devices		X		3.9 Floor and emergency identification numbering			X				
1.4 Sills and car floor	X			3.10 Hoistway construction	X						
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X						
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X						
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks	X						
1.8 Door closing force	X			3.14 Hoistway clearances	X						
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X						
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X						
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X						
1.12 Car enclosure	X			3.18 Car frame and stiles	X						
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X						
1.14 Ventilation	X			3.20 Governor rope	X						
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X						
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X						
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X						
1.18 Restricted opening of car or hoistway doors		X		3.27 Crosshead data plate and rope data tags	X						
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X						
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29 Counterweight safeties			X				
2 MACHINE ROOM				3.30 Speed Test				OK NG N/A			
2.1 Access to machinery space	X			3.33 Compensating ropes and chains	X						
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X				
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY							
2.4 Machinery space	X			4.1 Car platform guard	X						
2.5 Housekeeping	X			4.2 Hoistway doors	X						
2.6 Ventilation	X			4.3 Vision panels	X						
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X						
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X						
2.9 Guarding of exposed auxiliary equipment		X		4.6 Power closing of hoistway doors	X						
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X						
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X						
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X						
2.13 Governor, overspeed switch, and seal		X		4.10 Emergency doors in blind hoistways			X				
2.14 Code data plate	X			4.12 Standby power selection switch	X						
2.15 Static control	X			5 PIT							
2.16 Overhead beam and fastenings	X			5.1 Pit access, lighting, stop switch & condition	X						
2.17 Drive machine brake	X			5.2 Bottom clearance, runby & minimum refuge space	X						
2.18 Traction-drive machines	X			5.3 Final and emergency terminal stopping devices	X						
2.19 Gears, bearings, and flexible couplings	X			5.4 Normal terminal stopping devices	X						
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5 Traveling cables	X						
2.21 Belt- or chain-drive machine		X		5.6 Governor-rope tension devices	X						
2.22 Motor generator		X		5.7 Car frame and platform	X						
2.23 Absorption of regenerated power	X			5.8 Car and counterweight safeties and guiding members	X						
2.24 AC drives from a DC source	X			5.9 Buffers and emergency terminal speed-limiting devices	X						
2.25 Traction sheaves	X			5.10 Compensating chains, ropes & sheaves	X						
2.26 Secondary and deflector sheaves	X			5.12 Car buffers	X						
2.27 Rope fastenings	X			5.13 Guiding members [rails, rollers, slides]	X						
2.28 Terminal stopping devices	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X				
2.29 Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)							
2.40 Maintenance records	X			6.1 A17.1b-1973 through A17.1b-1980			X				
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.2 17.1-1981 through A17.1b-1983			X				
3 TOP OF CAR				6.3 A17.1-1984 through A17.1a-1988 and A17.3				OK NG N/A			
3.1 Top-of-car stop switch	X			6.4 A17.1b-1989 through A17.1d-2000	X						
3.2 Car top light and outlet	X			6.5 A 17.1-2000/644-00			X				
3.3 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X				
3.4 Top-of-car clearance, refuge space, and standard railing		X		6.7 A17.1-2007/B44-07			X				
3.5 Normal terminal stopping devices	X			6.8 A17.1-2010/B44-10			X				
3.6 Final and emergency terminal stopping devices	X			6.9 A17.1-2013/B44-13			X				

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Wyly Tower Of Learning
Railroad Ave
Ruston, LA 71270

Location ID:
731002-75

Location Contact Information:
Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0107

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 8:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 3/3/2000

Capacity: 3000

Inspection End Time: 9:00:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 6

Device Designation: #7

Device Manufacturer: Schindler

Speed: 450

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide a Guard on elevator hoist Machine sheave	No
2.13 Governor; overspeed switch; and seal	8.11.1.6 - Provide a correct dated five-year full load test tag on governor	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide cartop hand rails	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct size hobble cable on the hoist rope shackles	No
3.9 Floor and emergency identification numbering	2.29.2 - Provide floor numbers at each landing located in hoistway on hoistway doors	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0107

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK N G N/A				OK N G N/A		
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X		
1.2 Stop Switches	X			3.8 Top emergency exit	X		
1.3 Operating control devices	X			3.9 Floor and emergency identification numbering		X	
1.4 Sills and car floor	X			3.10 Hoistway construction	X		
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X		
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X		
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks	X		
1.8 Door closing force	X			3.14 Hoistway clearances	X		
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X		
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X		
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X		
1.12 Car enclosure	X			3.18 Car frame and stiles	X		
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X		
1.14 Ventilation	X			3.20 Governor rope	X		
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X		
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X		
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X		
1.18 Restricted opening of car or hoistway doors	X			3.27 Crosshead data plate and rope data tags	X		
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		3.29 Counterweight safeties			X
2 MACHINE ROOM				3.30 Speed Test	X		
2.1 Access to machinery space	X			3.33 Compensating ropes and chains	X		
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels	X		
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment		X		4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal		X		4.10 Emergency doors in blind hoistways			X
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.15 Static control	X			5 PIT			
2.16 Overhead beam and fastenings	X			5.1 Pit access, lighting, stop switch & condition	X		
2.17 Drive machine brake	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.18 Traction-drive machines	X			5.3 Final and emergency terminal stopping devices	X		
2.19 Gears, bearings, and flexible couplings	X			5.4 Normal terminal stopping devices	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5 Traveling cables	X		
2.21 Belt- or chain-drive machine		X		5.6 Governor-rope tension devices	X		
2.22 Motor generator		X		5.7 Car frame and platform	X		
2.23 Absorption of regenerated power	X			5.8 Car and counterweight safeties and guiding members	X		
2.24 AC drives from a DC source	X			5.9 Buffers and emergency terminal speed-limiting devices	X		
2.25 Traction sheaves	X			5.10 Compensating chains, ropes & sheaves	X		
2.26 Secondary and deflector sheaves	X			5.12 Car buffers	X		
2.27 Rope fastenings	X			5.13 Guiding members [rails, rollers, slides]	X		
2.28 Terminal stopping devices	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.29 Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)			
2.40 Maintenance records	X			6.1 A17.1b-1973 through A17.1b-1980			X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		6.2 17.1-1981 through A17.1b-1983			X
3 TOP OF CAR				6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.1 Top-of-car stop switch	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.2 Car top light and outlet	X			6.5 A 17.1-2000/644-00			X
3.3 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.4 Top-of-car clearance, refuge space, and standard railing		X		6.7 A17.1-2007/B44-07			X
3.5 Normal terminal stopping devices	X			6.8 A17.1-2010/B44-10			X
3.6 Final and emergency terminal stopping devices	X			6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address: Wyly Tower Of Learning Railroad Ave Ruston, LA 71270	Location ID: 731002-75	Location Contact Information: Name: JOE PEEL Title: Phone: +13182573267 Email: JPEEL@LATECH.EDU
--	----------------------------------	--

Inspection Information:

Inspection Date: 11/8/2023	Inspection Start Time: 9:00:00 AM	Inspection End Time: 10:00:00 AM
Inspector: Voiles, Jeff	Inspection Type: Category 1 Test	Inspection Result: Passed - Violations
Re-Inspection Required: No	Generator Test Performed: No	Re-Inspection Maint Co Required: No
Device ID: T0108	Device Type: Traction Elevator	# of Landings: 6
Due Month: November	Device Use: Passenger	Device Designation: #8
Code Edition:	Installation Date: 10/3/2000	Device Manufacturer: Schindler
Cat 5 Required?	Capacity: 3000	Speed: 450
Inspector Notes:		
Testing Results:		

Violation Information:

<u>Previous Violations</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 2.14.7.1.3 Repair emergency lighting located inside of elevator	No
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide a Guard on the elevator hoist machine sheave	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide cartop hand rails	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct size hobble cable on hoist rope shackles	No
2.13 Governor; overspeed switch; and seal	8.11.1.6 - Provide a correct dated five year full load test tag on the governor	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0108

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1	INSIDE OF CAR	OK	NG	N/A		OK	NG	N/A
1.1	Door reopening device	X			3.7	Car leveling and anticreep devices	X	
1.2	Stop Switches	X			3.8	Top emergency exit	X	
1.3	Operating control devices		X		3.9	Floor and emergency identification numbering	X	
1.4	Sills and car floor	X			3.10	Hoistway construction	X	
1.5	Car lighting and receptacles	X			3.11	Hoistway smoke control	X	
1.6	Car emergency signal	X			3.12	Pipes, wiring, and ducts	X	
1.7	Car door or gate	X			3.13	Windows, projections, recesses, and setbacks	X	
1.8	Door closing force	X			3.14	Hoistway clearances	X	
1.9	Power closing of doors or gates	X			3.15	Multiple hoistways	X	
1.10	Power opening of doors or gates	X			3.16	Traveling cables and junction boxes	X	
1.11	Car vision panels and glass car doors	X			3.17	Door and gate equipment	X	
1.12	Car enclosure	X			3.18	Car frame and stiles	X	
1.13	Emergency exit	X			3.19	Guide rails, fastenings, and equipment	X	
1.14	Ventilation	X			3.20	Governor rope	X	
1.15	Signs and operating device symbols	X			3.21	Governor releasing carrier	X	
1.16	Rated load, platform area, and data plate	X			3.22	Wire rope fastening and hitch plate	X	
1.17	Standby power operation	X			3.23	Suspension compensation and governor systems	X	
1.18	Restricted opening of car or hoistway doors	X			3.27	Crosshead data plate and rope data tags	X	
1.19	Car ride	X			3.28	Counterweight and counterweight buffer	X	
1.20	Earthquake inspection and tests (seismic risk zone 2 or greater)		X		3.29	Counterweight safeties		X
2	MACHINE ROOM				3.30	Speed Test	X	
2.1	Access to machinery space	X			3.33	Compensating ropes and chains	X	
2.2	Headroom	X			3.34	Earthquake inspection and tests (seismic risk zone 2 or greater)		X
2.3	Lighting and receptacles	X			4	OUTSIDE HOISTWAY		
2.4	Machinery space	X			4.1	Car platform guard	X	
2.5	Housekeeping	X			4.2	Hoistway doors	X	
2.6	Ventilation	X			4.3	Vision panels	X	
2.7	Fire extinguisher	X			4.4	Hoistway door-locking devices	X	
2.8	Pipes, wiring, and ducts	X			4.5	Access to hoistway	X	
2.9	Guarding of exposed auxiliary equipment		X		4.6	Power closing of hoistway doors	X	
2.10	Numbering of elevators, machines, controllers & disconnect switches	X			4.7	Sequence operation	X	
2.11	Disconnecting means and control	X			4.8	Hoistway enclosure	X	
2.12	Controller wiring, fuses, grounding, etc.	X			4.9	Elevator parking devices	X	
2.13	Governor, overspeed switch, and seal		X		4.10	Emergency doors in blind hoistways		X
2.14	Code data plate	X			4.12	Standby power selection switch	X	
2.15	Static control	X			5	PIT		
2.16	Overhead beam and fastenings	X			5.1	Pit access, lighting, stop switch & condition	X	
2.17	Drive machine brake	X			5.2	Bottom clearance, runby & minimum refuge space	X	
2.18	Traction-drive machines	X			5.3	Final and emergency terminal stopping devices	X	
2.19	Gears, bearings, and flexible couplings	X			5.4	Normal terminal stopping devices	X	
2.20	Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5	Traveling cables	X	
2.21	Belt- or chain-drive machine		X		5.6	Governor-rope tension devices	X	
2.22	Motor generator		X		5.7	Car frame and platform	X	
2.23	Absorption of regenerated power	X			5.8	Car and counterweight safeties and guiding members	X	
2.24	AC drives from a DC source	X			5.9	Buffers and emergency terminal speed-limiting devices	X	
2.25	Traction sheaves	X			5.10	Compensating chains, ropes & sheaves	X	
2.26	Secondary and deflector sheaves	X			5.12	Car buffers	X	
2.27	Rope fastenings	X			5.13	Guiding members [rails, rollers, slides]	X	
2.28	Terminal stopping devices	X			5.16	Earthquake inspection and tests (seismic risk zone 2 or greater)		X
2.29	Car and counterweight safeties	X			6	FIREFIGHTERS' SERVICE (FEO)		
2.40	Maintenance records	X			6.1	A17.1b-1973 through A17.1b-1980		X
2.42	Earthquake inspection and tests (seismic risk zone 2 or greater)		X		6.2	17.1-1981 through A17.1b-1983		X
3	TOP OF CAR				6.3	A17.1-1984 through A17.1a-1988 and A17.3		X
3.1	Top-of-car stop switch	X			6.4	A17.1b-1989 through A17.1d-2000	X	
3.2	Car top light and outlet	X			6.5	A 17.1-2000/644-00		X
3.3	Top-of-car operating device	X			6.6	A 17.1-2004/644-04		X
3.4	Top-of-car clearance, refuge space, and standard railing		X		6.7	A17.1-2007/B44-07		X
3.5	Normal terminal stopping devices	X			6.8	A17.1-2010/B44-10		X
3.6	Final and emergency terminal stopping devices	X			6.9	A17.1-2013/B44-13		X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Wyly Tower Of Learning
Railroad Ave
Ruston, LA 71270

Location ID:
731002-75

Location Contact Information:
Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0109

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 1:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 2/3/2000

Capacity: 3000

Inspection End Time: 2:00:00 PM

Inspection Result: Failed - Violations

Re-Inspection Maint Co Required: No

of Landings: 9

Device Designation: #1

Device Manufacturer: Schindler

Speed: 450

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	2.27.1.13 - Repair in car phone	No
1.18 Restricted opening of car or hoistway doors	8.6.4.13 - Repair car door restrictor	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide cartop handrails	No
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide a Guard on Elevator hoist Machine sheave	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct size hobble cable on hoist rope shackles	No
5.1 Pit access; lighting; stop switch; and condition	2.2.4.2 - Provide ladder in elevator pit	No
3.9 Floor and emergency identification numbering	2.29.2 - Provide floor numbers at each landing for elevators #1 #2 and #3, locate the numbers inside the hoistway on hoistway doors	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0109

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR				OK NG N/A			OK NG N/A
1.1 Door reopening device	X						X
1.2 Stop Switches	X						X
1.3 Operating control devices		X					X
1.4 Sills and car floor	X						X
1.5 Car lighting and receptacles	X						X
1.6 Car emergency signal	X						X
1.7 Car door or gate	X						X
1.8 Door closing force	X						X
1.9 Power closing of doors or gates	X						X
1.10 Power opening of doors or gates	X						X
1.11 Car vision panels and glass car doors	X						X
1.12 Car enclosure	X						X
1.13 Emergency exit	X						X
1.14 Ventilation	X						X
1.15 Signs and operating device symbols	X						X
1.16 Rated load, platform area, and data plate	X						X
1.17 Standby power operation	X						X
1.18 Restricted opening of car or hoistway doors		X					X
1.19 Car ride	X						X
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X				X
2 MACHINE ROOM							
2.1 Access to machinery space	X						X
2.2 Headroom	X						X
2.3 Lighting and receptacles	X						X
2.4 Machinery space	X						X
2.5 Housekeeping	X						X
2.6 Ventilation	X						X
2.7 Fire extinguisher	X						X
2.8 Pipes, wiring, and ducts	X						X
2.9 Guarding of exposed auxiliary equipment		X					X
2.10 Numbering of elevators, machines, controllers & disconnect switches	X						X
2.11 Disconnecting means and control	X						X
2.12 Controller wiring, fuses, grounding, etc.	X						X
2.13 Governor, overspeed switch, and seal	X						X
2.14 Code data plate	X						X
2.15 Static control	X						X
2.16 Overhead beam and fastenings	X						X
2.17 Drive machine brake	X						X
2.18 Traction-drive machines	X						X
2.19 Gears, bearings, and flexible couplings	X						X
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X				X
2.21 Belt- or chain-drive machine			X				X
2.22 Motor generator			X				X
2.23 Absorption of regenerated power	X						X
2.24 AC drives from a DC source	X						X
2.25 Traction sheaves	X						X
2.26 Secondary and deflector sheaves	X						X
2.27 Rope fastenings	X						X
2.28 Terminal stopping devices	X						X
2.29 Car and counterweight safeties	X						X
2.40 Maintenance records	X						X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X				X
3 TOP OF CAR							
3.1 Top-of-car stop switch	X						X
3.2 Car top light and outlet	X						X
3.3 Top-of-car operating device	X						X
3.4 Top-of-car clearance, refuge space, and standard railing		X					X
3.5 Normal terminal stopping devices	X						X
3.6 Final and emergency terminal stopping devices	X						X
4 OUTSIDE HOISTWAY							
4.1 Car platform guard						X	X
4.2 Hoistway doors						X	X
4.3 Vision panels						X	X
4.4 Hoistway door-locking devices						X	X
4.5 Access to hoistway						X	X
4.6 Power closing of hoistway doors						X	X
4.7 Sequence operation						X	X
4.8 Hoistway enclosure						X	X
4.9 Elevator parking devices						X	X
4.10 Emergency doors in blind hoistways							X
4.12 Standby power selection switch						X	X
5 PIT							
5.1 Pit access, lighting, stop switch & condition							X
5.2 Bottom clearance, runby & minimum refuge space						X	X
5.3 Final and emergency terminal stopping devices						X	X
5.4 Normal terminal stopping devices						X	X
5.5 Traveling cables						X	X
6 FIREFIGHTERS' SERVICE (FEO)							
6.1 A17.1b-1973 through A17.1b-1980							X
6.2 17.1-1981 through A17.1b-1983							X
6.3 A17.1-1984 through A17.1a-1988 and A17.3							X
6.4 A17.1b-1989 through A17.1d-2000						X	X
6.5 A 17.1-2000/644-00							X
6.6 A 17.1-2004/644-04							X
6.7 A17.1-2007/B44-07							X
6.8 A17.1-2010/B44-10							X
6.9 A17.1-2013/B44-13							X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Wyly Tower Of Learning
Railroad Ave
Ruston, LA 71270

Location ID:

731002-75

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0110

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 2:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 5/3/2000

Capacity: 3000

Inspection End Time: 3:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 9

Device Designation: #2

Device Manufacturer: Schindler

Speed: 450

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.18 Restricted opening of car or hoistway doors	8.6.4.13 - Repair car door restrictor	No
1.3 Operating control devices	2.27.1.13 - Repair In car phone	No
2.9 Guarding of exposed auxiliary equipment	2.10.1 - Provide a Guard on Elevator hoist machine sheave	No
3.4 Top-of-car clearance; refuge space; and standard railing	2.14.1.7 - Provide car top hand rails	No
3.22 Wire rope fastening and hitch plate	2.20.9.8 - Provide correct size hobble cable on hoist rope shackles	No
2.13 Governor; overspeed switch; and seal	8.11.1.6 - Provide five year full load test tag on the governor with correct test date	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0110

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X		
1.2 Stop Switches	X			3.8 Top emergency exit	X		
1.3 Operating control devices		X		3.9 Floor and emergency identification numbering	X		
1.4 Sills and car floor	X			3.10 Hoistway construction	X		
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X		
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X		
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks	X		
1.8 Door closing force	X			3.14 Hoistway clearances	X		
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X		
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X		
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X		
1.12 Car enclosure	X			3.18 Car frame and stiles	X		
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X		
1.14 Ventilation	X			3.20 Governor rope	X		
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X		
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X		
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X		
1.18 Restricted opening of car or hoistway doors		X		3.27 Crosshead data plate and rope data tags	X		
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29 Counterweight safeties			X
2 MACHINE ROOM				3.30 Speed Test	X		
2.1 Access to machinery space	X			3.33 Compensating ropes and chains	X		
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels	X		
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment		X		4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal		X		4.10 Emergency doors in blind hoistways			X
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.15 Static control	X			5 PIT			
2.16 Overhead beam and fastenings	X			5.1 Pit access, lighting, stop switch & condition	X		
2.17 Drive machine brake	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.18 Traction-drive machines	X			5.3 Final and emergency terminal stopping devices	X		
2.19 Gears, bearings, and flexible couplings	X			5.4 Normal terminal stopping devices	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5 Traveling cables	X		
2.21 Belt- or chain-drive machine		X		5.6 Governor-rope tension devices	X		
2.22 Motor generator		X		5.7 Car frame and platform	X		
2.23 Absorption of regenerated power	X			5.8 Car and counterweight safeties and guiding members	X		
2.24 AC drives from a DC source	X			5.9 Buffers and emergency terminal speed-limiting devices	X		
2.25 Traction sheaves	X			5.10 Compensating chains, ropes & sheaves	X		
2.26 Secondary and deflector sheaves	X			5.12 Car buffers	X		
2.27 Rope fastenings	X			5.13 Guiding members [rails, rollers, slides]	X		
2.28 Terminal stopping devices	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.29 Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)			
2.40 Maintenance records	X			6.1 A17.1b-1973 through A17.1b-1980			X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.2 17.1-1981 through A17.1b-1983			X
3 TOP OF CAR				6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.1 Top-of-car stop switch	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.2 Car top light and outlet	X			6.5 A 17.1-2000/644-00			X
3.3 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.4 Top-of-car clearance, refuge space, and standard railing		X		6.7 A17.1-2007/B44-07			X
3.5 Normal terminal stopping devices	X			6.8 A17.1-2010/B44-10			X
3.6 Final and emergency terminal stopping devices	X			6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Wyly Tower Of Learning
Railroad Ave
Ruston, LA 71270

Location ID:

731002-75

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspection Start Time: 3:00:00 PM

Inspection End Time: 4:00:00 PM

Inspector: Voiles, Jeff ||

Inspection Type: Category 1 Test

Inspection Result: Passed - Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: T0111

Device Type: Traction Elevator

of Landings: 9

Due Month: November

Device Use: Passenger

Device Designation: #3

Code Edition:

Installation Date: 6/3/2000

Device Manufacturer: Schindler

Cat 5 Required?

Capacity: 3000

Speed: 450

Inspector Notes:

Testing Results:

Violation Information:

Previous Violations

Previous Violation

Inspector Comments

Corrected?

1.18 Restricted opening of car or hoistway doors

8.6.4.13 - Repair car door restrictor

No

3.4 Top-of-car clearance; refuge space; and standard railing

2.14.1.7 - Provide cartop hand rails

No

3.22 Wire rope fastening and hitch plate

2.20.9.8 - Provide correct size hobble cable on hoist rope shackles

No

2.9 Guarding of exposed auxiliary equipment

2.10.1 - Provide a guard on elevator hoist machine sheave

No

2.13 Governor; overspeed switch; and seal

Provide five year full load test tag on the governor with correct test date

No

5.1 Pit access; lighting; stop switch; and condition

2.2.4.2 - Provide elevator pit ladder

No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Wyly Tower Of Learning, Railroad Ave Ruston, LA 71270

ID No: T0111

Device Type: Traction Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	N	G	N/A	3.7 Car leveling and anticreep devices	OK	N	G	N/A
1.1 Door reopening device	X				3.7 Car leveling and anticreep devices	X			
1.2 Stop Switches	X				3.8 Top emergency exit	X			
1.3 Operating control devices	X				3.9 Floor and emergency identification numbering	X			
1.4 Sills and car floor	X				3.10 Hoistway construction	X			
1.5 Car lighting and receptacles	X				3.11 Hoistway smoke control	X			
1.6 Car emergency signal	X				3.12 Pipes, wiring, and ducts	X			
1.7 Car door or gate	X				3.13 Windows, projections, recesses, and setbacks	X			
1.8 Door closing force	X				3.14 Hoistway clearances	X			
1.9 Power closing of doors or gates	X				3.15 Multiple hoistways	X			
1.10 Power opening of doors or gates	X				3.16 Traveling cables and junction boxes	X			
1.11 Car vision panels and glass car doors	X				3.17 Door and gate equipment	X			
1.12 Car enclosure	X				3.18 Car frame and stiles	X			
1.13 Emergency exit	X				3.19 Guide rails, fastenings, and equipment	X			
1.14 Ventilation	X				3.20 Governor rope	X			
1.15 Signs and operating device symbols	X				3.21 Governor releasing carrier	X			
1.16 Rated load, platform area, and data plate	X				3.22 Wire rope fastening and hitch plate	X			
1.17 Standby power operation	X				3.23 Suspension compensation and governor systems	X			
1.18 Restricted opening of car or hoistway doors		X			3.27 Crosshead data plate and rope data tags	X			
1.19 Car ride	X				3.28 Counterweight and counterweight buffer	X			
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		3.29 Counterweight safeties				X
2 MACHINE ROOM					3.30 Speed Test	X			
2.1 Access to machinery space	X				3.33 Compensating ropes and chains	X			
2.2 Headroom	X				3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
2.3 Lighting and receptacles	X				4 OUTSIDE HOISTWAY				
2.4 Machinery space	X				4.1 Car platform guard	X			
2.5 Housekeeping	X				4.2 Hoistway doors	X			
2.6 Ventilation	X				4.3 Vision panels	X			
2.7 Fire extinguisher	X				4.4 Hoistway door-locking devices	X			
2.8 Pipes, wiring, and ducts	X				4.5 Access to hoistway	X			
2.9 Guarding of exposed auxiliary equipment		X			4.6 Power closing of hoistway doors	X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X				4.7 Sequence operation	X			
2.11 Disconnecting means and control	X				4.8 Hoistway enclosure	X			
2.12 Controller wiring, fuses, grounding, etc.	X				4.9 Elevator parking devices	X			
2.13 Governor, overspeed switch, and seal		X			4.10 Emergency doors in blind hoistways				X
2.14 Code data plate	X				4.12 Standby power selection switch	X			
2.15 Static control	X				5 PIT				
2.16 Overhead beam and fastenings	X				5.1 Pit access, lighting, stop switch & condition				X
2.17 Drive machine brake	X				5.2 Bottom clearance, runby & minimum refuge space	X			
2.18 Traction-drive machines	X				5.3 Final and emergency terminal stopping devices	X			
2.19 Gears, bearings, and flexible couplings	X				5.4 Normal terminal stopping devices	X			
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X		5.5 Traveling cables	X			
2.21 Belt- or chain-drive machine			X		5.6 Governor-rope tension devices	X			
2.22 Motor generator			X		5.7 Car frame and platform	X			
2.23 Absorption of regenerated power	X				5.8 Car and counterweight safeties and guiding members	X			
2.24 AC drives from a DC source	X				5.9 Buffers and emergency terminal speed-limiting devices	X			
2.25 Traction sheaves	X				5.10 Compensating chains, ropes & sheaves	X			
2.26 Secondary and deflector sheaves	X				5.12 Car buffers	X			
2.27 Rope fastenings	X				5.13 Guiding members [rails, rollers, slides]	X			
2.28 Terminal stopping devices	X				5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
2.29 Car and counterweight safeties	X				6 FIREFIGHTERS' SERVICE (FEO)				
2.40 Maintenance records	X				6.1 A17.1b-1973 through A17.1b-1980				X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		6.2 17.1-1981 through A17.1b-1983				X
3 TOP OF CAR					6.3 A17.1-1984 through A17.1a-1988 and A17.3				X
3.1 Top-of-car stop switch	X				6.4 A17.1b-1989 through A17.1d-2000	X			
3.2 Car top light and outlet	X				6.5 A 17.1-2000/644-00				X
3.3 Top-of-car operating device	X				6.6 A 17.1-2004/644-04				X
3.4 Top-of-car clearance, refuge space, and standard railing		X			6.7 A17.1-2007/B44-07				X
3.5 Normal terminal stopping devices	X				6.8 A17.1-2010/B44-10				X
3.6 Final and emergency terminal stopping devices	X				6.9 A17.1-2013/B44-13				X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Biomedical Engineering Building
Hergott St
Ruston, LA 71270

Location ID:

731002-92

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0236

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results: Relief (psi): 505, Working (psi): 210,

Inspection Start Time: 9:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 11/2/2006

Plunger Gripper?

Speed: 125

Inspection End Time: 10:00:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: Thyssen

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

1.3 Operating control devices

Inspector Comments

A17.1- 2.14.7.1.3. Repair emergency lights located inside of elevator

Corrected?

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0236

Device Type: Hydraulic Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members	X		
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07	X		
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Bogard Hall
College Dr
Ruston, LA 71270

Location ID:

731002-57

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0237

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2000

Inspector Notes:

Testing Results: Relief (psi): 440, Working (psi): 220,

Inspection Start Time: 11:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 11/5/2002

Plunger Gripper?

Speed: 125

Inspection End Time: 11:30:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 4

Device Designation: #1

Device Manufacturer: EC

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
5.1 Pit access; lighting; stop switch; and condition	A17.1-3.18.3.7 Clean oil and debris from elevator pit area	No
1.3 Operating control devices	2.14.7.1.3 - Repair in car emergency lights	Yes

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0237

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition			X
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Business Bldg
502 West Texas Ave
Ruston, LA 71270

Location ID:
731002-99

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0238

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 3500

Inspector Notes:

Testing Results: Relief (psi): 440, Working (psi): 250,

Inspection Start Time: 2:30:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 11/4/2011

Plunger Gripper?

Speed: 125

Inspection End Time: 3:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: Schindler

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

5.1 Pit access; lighting; stop switch; and condition

1.3 Operating control devices

Inspector Comments

A17.1- 3.18.3.7 clean and remove oil from elevator pit area

Repair in car emergency lights

Corrected?

No

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0238 **Device Type:** Hydraulic Elevator **Date:** 11/7/2023 **Inspection Type:** Category 1 Test
Firm #: 33 **Code Edition:** **Location Contact Name:** JOE PEEL
Inspected By: Voiles, Jeff || **Signature:** **Location Contact Signature:**

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X						
1.2 Stop Switches	X						
1.3 Operating control devices		X					
1.4 Sills and car floor	X						
1.5 Car lighting and receptacles	X						
1.6 Car emergency signal	X						
1.7 Car door or gate	X						
1.8 Door closing force	X						
1.9 Power closing of doors or gates	X						
1.10 Power opening of doors or gates	X						
1.11 Car vision panels and glass car doors	X						
1.12 Car enclosure	X						
1.13 Emergency exit	X						
1.14 Ventilation	X						
1.15 Signs and operating device symbols	X						
1.16 Rated load, platform area, and data plate	X						
1.17 Standby power operation	X						
1.18 Restricted opening of car or hoistway doors	X						
1.19 Car ride	X						
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X				
2 MACHINE ROOM							
2.1 Access to machinery space	X						
2.2 Headroom	X						
2.3 Lighting and receptacles	X						
2.4 Machinery space	X						
2.5 Housekeeping	X						
2.6 Ventilation	X						
2.7 Fire extinguisher	X						
2.8 Pipes, wiring, and ducts	X						
2.9 Guarding of exposed auxiliary equipment	X						
2.10 Numbering of elevators, machines, controllers & disconnect switches	X						
2.11 Disconnecting means and control	X						
2.12 Controller wiring, fuses, grounding, etc.	X						
2.13 Governor, overspeed switch, and seal			X				
2.14 Code data plate	X						
2.30 Hydraulic power unit	X						
2.31 Relief valves	X						
2.32 Control valve	X						
2.33 Tanks	X						
2.36 Hydraulic cylinders	X						
2.37 Pressure switch	X						
2.38 Roped water hydraulic elevators			X				
2.39 Low oil protection	X						
2.40 Maintenance records	X						
2.41 Hydraulic control	X						
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X				
2.44 Auxiliary power lowering operation	X						
2.45 Inspection operation with open door circuits and inspection hierarchy	X						
3 TOP OF CAR							
3.1 Top-of-car stop switch	X						
3.2 Car top light and outlet	X						
3.3 Top-of-car operating device	X						
3.4 Top-of-car clearance, refuge space, and standard railing	X						
3.5 Normal terminal stopping devices	X						
3.6 Final and emergency terminal stopping devices	X						
3.7 Top-of-car operating device	X						
3.8 Top-of-car clearance, refuge space, and standard railing	X						
3.9 Floor and emergency identification numbering					X		
3.10 Hoistway Construction					X		
3.11 Hoistway smoke control					X		
3.12 Pipes, wiring, and ducts					X		
3.13 Windows, projections, recesses, and setbacks					X		
3.14 Hoistway clearances					X		
3.15 Multiple hoistways					X		
3.16 Traveling cables and junction boxes					X		
3.17 Door and gate equipment					X		
3.18 Car frame and stiles					X		
3.19 Guide rails, fastenings, and equipment					X		
3.20 Governor rope						X	
3.21 Governor releasing carrier						X	
3.22 Wire rope fastening and hitch plate						X	
3.23 Suspension compensation and governor systems						X	
3.27 Crosshead data plate and rope data tags					X		
3.28 Counterweight and counterweight buffer						X	
3.29 Counterweight safeties						X	
3.30 Speed Test					X		
3.31 Slack rope test - roped hydraulic elevators						X	
3.32 Speed Test						X	
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)						X	
4 OUTSIDE HOISTWAY							
4.1 Car platform guard					X		
4.2 Hoistway doors					X		
4.3 Vision panels					X		
4.4 Hoistway door-locking devices					X		
4.5 Access to hoistway					X		
4.6 Power closing of hoistway doors					X		
4.7 Sequence operation					X		
4.8 Hoistway enclosure					X		
4.9 Elevator parking devices					X		
4.10 Emergency doors in blind hoistways						X	
4.12 Standby power selection switch					X		
5 PIT							
5.1 Pit access, lighting, stop switch & condition						X	
5.2 Bottom clearance, runby & minimum refuge space					X		
5.4 Normal terminal stopping devices					X		
5.5 Traveling cables					X		
5.6 Governor-rope tension devices						X	
5.7 Car frame and platform					X		
5.8 Car and counterweight safeties and guiding members						X	
5.11 Buffers and emergency terminal speed-limiting devices					X		
5.12 Car buffers					X		
5.13 Guiding members [rails, rollers, slides]					X		
5.14 Guiding members [rails, rollers, slides]					X		
5.15 Overspeed valve						X	
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)						X	
5.17 Plunger gripper						X	
6 FIREFIGHTERS' SERVICE (FEO)							
6.1 A17.1-1984 through A17.1a-1988 and A17.3						X	
6.2 A17.1b-1989 through A17.1d-2000						X	
6.3 A17.1-1984 through A17.1a-1988 and A17.3						X	
6.4 A17.1b-1989 through A17.1d-2000						X	
6.5 A 17.1-2000/644-00						X	
6.6 A 17.1-2004/644-04						X	
6.7 A17.1-2007/B44-07						X	
6.8 A17.1-2010/B44-10						X	
6.9 A17.1-2013/B44-13					X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Carson Taylor Hall
Adams Blvd
Ruston, LA 71270

Location ID:

731002-53

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0239

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results: Relief (psi): 400, Working (psi): 160,

Inspection Start Time: 9:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 10/5/2018

Plunger Gripper?

Speed: 125

Inspection End Time: 9:30:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Smartrise

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation	Inspector Comments	Corrected?
1.3 Operating control devices	A17.1- 3.2.6.4 Repair emergency lighting, located inside of elevator	No
1.3 Operating control devices	A17.1- 2.27.1 Repair emergency alarm located inside of elevator	No
2.3 Lighting and receptacles	NEC- 110.26 Provide standard 110 volt AC toggle light switch in elevator machine room, cannot use motion control light switch	Yes

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0239

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	N	G	N/A	3.9 Floor and emergency identification numbering	X	N	G	N/A
1.1 Door reopening device	X				3.10 Hoistway Construction	X			
1.2 Stop Switches	X				3.11 Hoistway smoke control	X			
1.3 Operating control devices		X			3.12 Pipes, wiring, and ducts	X			
1.4 Sills and car floor	X				3.13 Windows, projections, recesses, and setbacks	X			
1.5 Car lighting and receptacles	X				3.14 Hoistway clearances	X			
1.6 Car emergency signal	X				3.15 Multiple hoistways	X			
1.7 Car door or gate	X				3.16 Traveling cables and junction boxes	X			
1.8 Door closing force	X				3.17 Door and gate equipment	X			
1.9 Power closing of doors or gates	X				3.18 Car frame and stiles	X			
1.10 Power opening of doors or gates	X				3.19 Guide rails, fastenings, and equipment	X			
1.11 Car vision panels and glass car doors	X				3.20 Governor rope				X
1.12 Car enclosure	X				3.21 Governor releasing carrier				X
1.13 Emergency exit	X				3.22 Wire rope fastening and hitch plate				X
1.14 Ventilation	X				3.23 Suspension compensation and governor systems				X
1.15 Signs and operating device symbols	X				3.27 Crosshead data plate and rope data tags	X			
1.16 Rated load, platform area, and data plate	X				3.28 Counterweight and counterweight buffer				X
1.17 Standby power operation	X				3.29 Counterweight safeties				X
1.18 Restricted opening of car or hoistway doors	X				3.30 Speed Test	X			
1.19 Car ride	X				3.31 Slack rope test - roped hydraulic elevators				X
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)				X	3.32 Speed Test				X
2 MACHINE ROOM					3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
2.1 Access to machinery space	X				4 OUTSIDE HOISTWAY				
2.2 Headroom	X				4.1 Car platform guard	X			
2.3 Lighting and receptacles	X				4.2 Hoistway doors	X			
2.4 Machinery space	X				4.3 Vision panels	X			
2.5 Housekeeping	X				4.4 Hoistway door-locking devices	X			
2.6 Ventilation	X				4.5 Access to hoistway	X			
2.7 Fire extinguisher	X				4.6 Power closing of hoistway doors	X			
2.8 Pipes, wiring, and ducts	X				4.7 Sequence operation	X			
2.9 Guarding of exposed auxiliary equipment	X				4.8 Hoistway enclosure	X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X				4.9 Elevator parking devices	X			
2.11 Disconnecting means and control	X				4.10 Emergency doors in blind hoistways				X
2.12 Controller wiring, fuses, grounding, etc.	X				4.12 Standby power selection switch	X			
2.13 Governor, overspeed switch, and seal				X	5 PIT				
2.14 Code data plate	X				5.1 Pit access, lighting, stop switch & condition	X			
2.30 Hydraulic power unit	X				5.2 Bottom clearance, runby & minimum refuge space	X			
2.31 Relief valves	X				5.4 Normal terminal stopping devices	X			
2.32 Control valve	X				5.5 Traveling cables	X			
2.33 Tanks	X				5.6 Governor-rope tension devices	X			
2.36 Hydraulic cylinders	X				5.7 Car frame and platform	X			
2.37 Pressure switch	X				5.8 Car and counterweight safeties and guiding members	X			
2.38 Roped water hydraulic elevators				X	5.11 Buffers and emergency terminal speed-limiting devices	X			
2.39 Low oil protection	X				5.12 Car buffers	X			
2.40 Maintenance records	X				5.13 Guiding members [rails, rollers, slides]	X			
2.41 Hydraulic control	X				5.14 Guiding members [rails, rollers, slides]	X			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)				X	5.15 Overspeed valve				X
2.44 Auxillary power lowering operation	X				5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
2.45 Inspection operation with open door circuits and inspection hierarchy	X				5.17 Plunger gripper				X
3 TOP OF CAR					6 FIREFIGHTERS' SERVICE (FEO)				
3.1 Top-of-car stop switch	X				6.1 A17.1-1984 through A17.1a-1988 and A17.3				X
3.2 Car top light and outlet	X				6.2 A17.1b-1989 through A17.1d-2000				X
3.3 Top-of-car operating device	X				6.3 A17.1-1984 through A17.1a-1988 and A17.3				X
3.4 Top-of-car clearance, refuge space, and standard railing	X				6.4 A17.1b-1989 through A17.1d-2000				X
3.5 Normal terminal stopping devices	X				6.5 A 17.1-2000/644-00				X
3.6 Final and emergency terminal stopping devices	X				6.6 A 17.1-2004/644-04				X
3.7 Top-of-car operating device	X				6.7 A17.1-2007/B44-07				X
3.8 Top-of-car clearance, refuge space, and standard railing	X				6.8 A17.1-2010/B44-10				X
					6.9 A17.1-2013/B44-13			X	

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Davison Hall
Hergott St
Ruston, LA 71270

Location ID:

731002-89

Location Contact Information:

Name: JOE PEEL

Title:

Phone: +13182573267

Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0240

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2100

Inspector Notes:

Testing Results: Relief (psi): 510, Working (psi): 210,

Inspection Start Time: 10:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 8/2/1998

Plunger Gripper?

Speed: 125

Inspection End Time: 10:30:00 AM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Dover

Cat 5 Required?

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0240

Device Type: Hydraulic Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	N	G	N/A		OK	N	G	N/A
1.1 Door reopening device	X				3.9 Floor and emergency identification numbering	X			
1.2 Stop Switches	X				3.10 Hoistway Construction	X			
1.3 Operating control devices	X				3.11 Hoistway smoke control	X			
1.4 Sills and car floor	X				3.12 Pipes, wiring, and ducts	X			
1.5 Car lighting and receptacles	X				3.13 Windows, projections, recesses, and setbacks	X			
1.6 Car emergency signal	X				3.14 Hoistway clearances	X			
1.7 Car door or gate	X				3.15 Multiple hoistways	X			
1.8 Door closing force	X				3.16 Traveling cables and junction boxes	X			
1.9 Power closing of doors or gates	X				3.17 Door and gate equipment	X			
1.10 Power opening of doors or gates	X				3.18 Car frame and stiles	X			
1.11 Car vision panels and glass car doors	X				3.19 Guide rails, fastenings, and equipment	X			
1.12 Car enclosure	X				3.20 Governor rope				X
1.13 Emergency exit	X				3.21 Governor releasing carrier				X
1.14 Ventilation	X				3.22 Wire rope fastening and hitch plate				X
1.15 Signs and operating device symbols	X				3.23 Suspension compensation and governor systems				X
1.16 Rated load, platform area, and data plate	X				3.27 Crosshead data plate and rope data tags	X			
1.17 Standby power operation	X				3.28 Counterweight and counterweight buffer				X
1.18 Restricted opening of car or hoistway doors	X				3.29 Counterweight safeties				X
1.19 Car ride	X				3.30 Speed Test	X			
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)				X	3.31 Slack rope test - roped hydraulic elevators				X
2 MACHINE ROOM					3.32 Speed Test				X
2.1 Access to machinery space	X				3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
2.2 Headroom	X				4 OUTSIDE HOISTWAY				
2.3 Lighting and receptacles	X				4.1 Car platform guard	X			
2.4 Machinery space	X				4.2 Hoistway doors	X			
2.5 Housekeeping	X				4.3 Vision panels	X			
2.6 Ventilation	X				4.4 Hoistway door-locking devices	X			
2.7 Fire extinguisher	X				4.5 Access to hoistway	X			
2.8 Pipes, wiring, and ducts	X				4.6 Power closing of hoistway doors	X			
2.9 Guarding of exposed auxiliary equipment	X				4.7 Sequence operation	X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X				4.8 Hoistway enclosure	X			
2.11 Disconnecting means and control	X				4.9 Elevator parking devices	X			
2.12 Controller wiring, fuses, grounding, etc.	X				4.10 Emergency doors in blind hoistways				X
2.13 Governor, overspeed switch, and seal				X	4.12 Standby power selection switch	X			
2.14 Code data plate	X				5 PIT				
2.30 Hydraulic power unit	X				5.1 Pit access, lighting, stop switch & condition	X			
2.31 Relief valves	X				5.2 Bottom clearance, runby & minimum refuge space	X			
2.32 Control valve	X				5.4 Normal terminal stopping devices	X			
2.33 Tanks	X				5.5 Traveling cables	X			
2.36 Hydraulic cylinders	X				5.6 Governor-rope tension devices				X
2.37 Pressure switch	X				5.7 Car frame and platform	X			
2.38 Roped water hydraulic elevators				X	5.8 Car and counterweight safeties and guiding members				X
2.39 Low oil protection	X				5.11 Buffers and emergency terminal speed-limiting devices	X			
2.40 Maintenance records	X				5.12 Car buffers	X			
2.41 Hydraulic control	X				5.13 Guiding members [rails, rollers, slides]	X			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)				X	5.14 Guiding members [rails, rollers, slides]	X			
2.44 Auxiliary power lowering operation	X				5.15 Overspeed valve				X
2.45 Inspection operation with open door circuits and inspection hierarchy	X				5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
3 TOP OF CAR					5.17 Plunger gripper				X
3.1 Top-of-car stop switch	X				6 FIREFIGHTERS' SERVICE (FEO)				
3.2 Car top light and outlet	X				6.1 A17.1-1984 through A17.1a-1988 and A17.3				X
3.3 Top-of-car operating device	X				6.2 A17.1b-1989 through A17.1d-2000				X
3.4 Top-of-car clearance, refuge space, and standard railing	X				6.3 A17.1-1984 through A17.1a-1988 and A17.3				X
3.5 Normal terminal stopping devices	X				6.4 A17.1b-1989 through A17.1d-2000	X			
3.6 Final and emergency terminal stopping devices	X				6.5 A 17.1-2000/644-00				X
3.7 Top-of-car operating device	X				6.6 A 17.1-2004/644-04				X
3.8 Top-of-car clearance, refuge space, and standard railing	X				6.7 A17.1-2007/B44-07				X
					6.8 A17.1-2010/B44-10				X
					6.9 A17.1-2013/B44-13				X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

George Madison Hall
Wisteria Dr
Ruston, LA 71270

Location ID:

731002-65

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0241

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results:

Inspection Start Time: 12:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 8/5/2000

Plunger Gripper?

Speed: 125

Inspection End Time: 12:30:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 4

Device Designation: #1

Device Manufacturer: EC

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 2.8.4.6 Repair emergency light located inside of elevator	No
1.3 Operating control devices	2.27.1 - Repair in car alarm Bell	No
5.1 Pit access; lighting; stop switch; and condition	2.2.6 - Provide pit light switch and pit stop switch next to elevator pit ladder	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0241 **Device Type:** Hydraulic Elevator **Date:** 11/9/2023 **Inspection Type:** Category 1 Test
Firm #: 33 **Code Edition:** **Location Contact Name:** JOE PEEL
Inspected By: Voiles, Jeff || **Signature:** **Location Contact Signature:**

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition			X
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Hale Hall
Madison Ave
Ruston, LA 71270

Location ID:

731002-91

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0242

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 3500

Inspector Notes:

Testing Results: Relief (psi): 360, Working (psi): 110,

Inspection Start Time: 2:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 5/5/2003

Plunger Gripper?

Speed: 125

Inspection End Time: 2:30:00 PM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: TKE

Cat 5 Required?

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0242 **Device Type:** Hydraulic Elevator **Date:** 11/9/2023 **Inspection Type:** Category 1 Test
Firm #: 33 **Code Edition:** **Location Contact Name:** JOE PEEL
Inspected By: Voiles, Jeff || **Signature:** **Location Contact Signature:**

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK N G N/A			OK N G N/A			
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal		X		4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators		X		5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
				5.17 Plunger gripper			X
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04			X
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Institute For Micromanufacturing
Tech Dr
Ruston, LA 71270

Location ID:

731002-85

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0243

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2100

Inspector Notes:

Testing Results: Relief (psi): 400, Working (psi): 200,

Inspection Start Time: 8:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 6/2/1996

Plunger Gripper?

Speed: 100

Inspection End Time: 9:00:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Dover

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

1.3 Operating control devices

1.3 Operating control devices

Inspector Comments

A17.1- 8.9.1.3 Repair emergency phone located inside of elevator

2.27.1.13 - Repair in car phone

2.14.7.1.3 - Repair in car emergency light

Corrected?

No

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0243

Device Type: Hydraulic Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR				OK	NG	N/A
1.1 Door reopening device	X					
1.2 Stop Switches	X					
1.3 Operating control devices		X				
1.4 Sills and car floor	X					
1.5 Car lighting and receptacles	X					
1.6 Car emergency signal	X					
1.7 Car door or gate	X					
1.8 Door closing force	X					
1.9 Power closing of doors or gates	X					
1.10 Power opening of doors or gates	X					
1.11 Car vision panels and glass car doors	X					
1.12 Car enclosure	X					
1.13 Emergency exit	X					
1.14 Ventilation	X					
1.15 Signs and operating device symbols	X					
1.16 Rated load, platform area, and data plate	X					
1.17 Standby power operation	X					
1.18 Restricted opening of car or hoistway doors	X					
1.19 Car ride	X					
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			
2 MACHINE ROOM						
2.1 Access to machinery space	X					
2.2 Headroom	X					
2.3 Lighting and receptacles	X					
2.4 Machinery space	X					
2.5 Housekeeping	X					
2.6 Ventilation	X					
2.7 Fire extinguisher	X					
2.8 Pipes, wiring, and ducts	X					
2.9 Guarding of exposed auxiliary equipment	X					
2.10 Numbering of elevators, machines, controllers & disconnect switches	X					
2.11 Disconnecting means and control	X					
2.12 Controller wiring, fuses, grounding, etc.	X					
2.13 Governor, overspeed switch, and seal			X			
2.14 Code data plate	X					
2.30 Hydraulic power unit	X					
2.31 Relief valves	X					
2.32 Control valve	X					
2.33 Tanks	X					
2.36 Hydraulic cylinders	X					
2.37 Pressure switch	X					
2.38 Roped water hydraulic elevators			X			
2.39 Low oil protection	X					
2.40 Maintenance records	X					
2.41 Hydraulic control	X					
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			
2.44 Auxiliary power lowering operation	X					
2.45 Inspection operation with open door circuits and inspection hierarchy	X					
3 TOP OF CAR						
3.1 Top-of-car stop switch	X					
3.2 Car top light and outlet	X					
3.3 Top-of-car operating device	X					
3.4 Top-of-car clearance, refuge space, and standard railing	X					
3.5 Normal terminal stopping devices	X					
3.6 Final and emergency terminal stopping devices	X					
3.7 Top-of-car operating device	X					
3.8 Top-of-car clearance, refuge space, and standard railing	X					
3.9 Floor and emergency identification numbering	X					
3.10 Hoistway Construction	X					
3.11 Hoistway smoke control	X					
3.12 Pipes, wiring, and ducts	X					
3.13 Windows, projections, recesses, and setbacks	X					
3.14 Hoistway clearances	X					
3.15 Multiple hoistways	X					
3.16 Traveling cables and junction boxes	X					
3.17 Door and gate equipment	X					
3.18 Car frame and stiles	X					
3.19 Guide rails, fastenings, and equipment	X					
3.20 Governor rope						X
3.21 Governor releasing carrier						X
3.22 Wire rope fastening and hitch plate						X
3.23 Suspension compensation and governor systems						X
3.27 Crosshead data plate and rope data tags	X					
3.28 Counterweight and counterweight buffer						X
3.29 Counterweight safeties						X
3.30 Speed Test					X	
3.31 Slack rope test - roped hydraulic elevators						X
3.32 Speed Test						X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)						X
4 OUTSIDE HOISTWAY						
4.1 Car platform guard	X					
4.2 Hoistway doors	X					
4.3 Vision panels	X					
4.4 Hoistway door-locking devices	X					
4.5 Access to hoistway	X					
4.6 Power closing of hoistway doors	X					
4.7 Sequence operation	X					
4.8 Hoistway enclosure	X					
4.9 Elevator parking devices	X					
4.10 Emergency doors in blind hoistways						X
4.12 Standby power selection switch	X					
5 PIT						
5.1 Pit access, lighting, stop switch & condition	X					
5.2 Bottom clearance, runby & minimum refuge space	X					
5.4 Normal terminal stopping devices	X					
5.5 Traveling cables	X					
5.6 Governor-rope tension devices						X
5.7 Car frame and platform	X					
5.8 Car and counterweight safeties and guiding members						X
5.11 Buffers and emergency terminal speed-limiting devices	X					
5.12 Car buffers	X					
5.13 Guiding members [rails, rollers, slides]	X					
5.14 Guiding members [rails, rollers, slides]	X					
5.15 Overspeed valve						X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)						X
5.17 Plunger gripper						X
6 FIREFIGHTERS' SERVICE (FEO)						
6.1 A17.1-1984 through A17.1a-1988 and A17.3						X
6.2 A17.1b-1989 through A17.1d-2000						X
6.3 A17.1-1984 through A17.1a-1988 and A17.3						X
6.4 A17.1b-1989 through A17.1d-2000	X					
6.5 A 17.1-2000/644-00						X
6.6 A 17.1-2004/644-04						X
6.7 A17.1-2007/B44-07						X
6.8 A17.1-2010/B44-10						X
6.9 A17.1-2013/B44-13						X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Neithken Hall
Homer St.
Ruston, LA 71270

Location ID:

731002-64

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0246

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2100

Inspector Notes:

Testing Results: Relief (psi): 450, Working (psi): 190,

Inspection Start Time: 8:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 2/5/2002

Plunger Gripper?

Speed: 100

Inspection End Time: 9:00:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: Schindler

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 2.27.1.13 Repair emergency phone located inside of elevator	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0246

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A		OK	NG	N/A
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Prescott Library
Railroad Ave
Ruston, LA 71270

Location ID:

731002-34

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/8/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0247

Due Month: November

Code Edition: 1998 - A17.1b

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results: Relief (psi): 450, Working (psi): 140,

Inspection Start Time: 4:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 10/6/2001

Plunger Gripper?

Speed: 125

Inspection End Time: 5:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 4

Device Designation: #1

Device Manufacturer: EC

Cat 5 Required?

Violation Information:

New Violations

Violation

1.3 Operating control devices

Inspector Comments

7.3.9.2 Repair emergency phone located inside of the elevator

Previous Violations

Previous Violation

3.4 Top-of-car clearance; refuge space; and standard railing

Inspector Comments

Has fall hazard in some areas of the hoistway, Provide cartop hand rails

Corrected?

Yes

5.1 Pit access; lighting; stop switch; and condition

Elevator pit switch mounted too high from floor sill landing, must be mounted no more than 18 inches from floor sill landing

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0247

Device Type: Hydraulic Elevator

Date: 11/8/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition: 1998 - A17.1b

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A	
1 INSIDE OF CAR					OK NG N/A			
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X			
1.2 Stop Switches	X			3.10 Hoistway Construction	X			
1.3 Operating control devices		X		3.11 Hoistway smoke control	X			
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X			
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X			
1.6 Car emergency signal	X			3.14 Hoistway clearances	X			
1.7 Car door or gate	X			3.15 Multiple hoistways	X			
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X			
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X			
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X			
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X			
1.12 Car enclosure	X			3.20 Governor rope	X			
1.13 Emergency exit	X			3.21 Governor releasing carrier	X			
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X	
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X	
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X			
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X	
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X	
1.19 Car ride	X			3.30 Speed Test	X			
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X	
2 MACHINE ROOM				3.32 Speed Test			X	
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
2.2 Headroom	X			4 OUTSIDE HOISTWAY				
2.3 Lighting and receptacles	X			4.1 Car platform guard	X			
2.4 Machinery space	X			4.2 Hoistway doors	X			
2.5 Housekeeping	X			4.3 Vision panels	X			
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X			
2.7 Fire extinguisher	X			4.5 Access to hoistway	X			
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X			
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X			
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X			
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X	
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X			
2.14 Code data plate	X			5 PIT				
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition			X	
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X			
2.32 Control valve	X			5.4 Normal terminal stopping devices	X			
2.33 Tanks	X			5.5 Traveling cables	X			
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X	
2.37 Pressure switch	X			5.7 Car frame and platform	X			
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X	
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X			
2.40 Maintenance records	X			5.12 Car buffers	X			
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X			
2.44 Auxiliary power lowering operation	X			5.15 Overspeed valve			X	
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
3 TOP OF CAR				5.17 Plunger gripper			X	
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)				
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X	
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X	
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X	
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X			
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X	
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X	
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X	
				6.8 A17.1-2010/B44-10			X	
				6.9 A17.1-2013/B44-13			X	

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Student Center - Book Store
Arizona Ave
Ruston, LA 71270

Location ID:
731002-32

Location Contact Information:
Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0248

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results: Relief (psi): 450, Working (psi): 200,

Inspection Start Time: 10:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 3/5/1986

Plunger Gripper?

Speed: 100

Inspection End Time: 11:00:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Otis

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 4.8.8.2 Repair position indicator located inside of elevator	No
1.3 Operating control devices	A17.1-2.27.1.13 Repair emergency phone located inside of elevator	No
1.3 Operating control devices	A17.1- Repair broken emergency alarm button located inside of elevator	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0248

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK N G N/A				OK N G N/A		
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard		X	
2.4 Machinery space	X			4.2 Hoistway doors		X	
2.5 Housekeeping	X			4.3 Vision panels		X	
2.6 Ventilation	X			4.4 Hoistway door-locking devices		X	
2.7 Fire extinguisher	X			4.5 Access to hoistway		X	
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors		X	
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation		X	
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure		X	
2.11 Disconnecting means and control	X			4.9 Elevator parking devices		X	
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal		X		4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition		X	
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space		X	
2.32 Control valve	X			5.4 Normal terminal stopping devices		X	
2.33 Tanks	X			5.5 Traveling cables		X	
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform		X	
2.38 Roped water hydraulic elevators		X		5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices		X	
2.40 Maintenance records	X			5.12 Car buffers		X	
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]		X	
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		5.14 Guiding members [rails, rollers, slides]		X	
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
				5.17 Plunger gripper			X
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3		X	
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04			X
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Student Center - Book Store
Arizona Ave
Ruston, LA 71270

Location ID:

731002-32

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0249

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2000

Inspector Notes:

Testing Results: Relief (psi): 305, Working (psi): 120,

Inspection Start Time: 9:30:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Freight

Installation Date: 6/5/2003

Plunger Gripper?

Speed: 75

Inspection End Time: 10:00:00 AM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #2 Freight

Device Manufacturer: Esco

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

5.1 Pit access; lighting; stop switch; and condition

Inspector Comments

8.6.4.7 - Clean the elevator pit

2.2.6 - Provide elevator pit light switch next to the pit ladder

Corrected?

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0249

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A	
1 INSIDE OF CAR								
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X			
1.2 Stop Switches	X			3.10 Hoistway Construction	X			
1.3 Operating control devices	X			3.11 Hoistway smoke control	X			
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X			
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X			
1.6 Car emergency signal	X			3.14 Hoistway clearances	X			
1.7 Car door or gate	X			3.15 Multiple hoistways	X			
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X			
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X			
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X			
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X			
1.12 Car enclosure	X			3.20 Governor rope			X	
1.13 Emergency exit	X			3.21 Governor releasing carrier			X	
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X	
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X	
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X			
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X	
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X	
1.19 Car ride	X			3.30 Speed Test	X			
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X	
2 MACHINE ROOM				3.32 Speed Test			X	
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
2.2 Headroom	X			4 OUTSIDE HOISTWAY				
2.3 Lighting and receptacles	X			4.1 Car platform guard	X			
2.4 Machinery space	X			4.2 Hoistway doors	X			
2.5 Housekeeping	X			4.3 Vision panels	X			
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X			
2.7 Fire extinguisher	X			4.5 Access to hoistway	X			
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X			
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X			
2.11 Disconnecting means and control	X			4.9 Elevator parking devices			X	
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X	
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X	
2.14 Code data plate	X			5 PIT				
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition			X	
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X			
2.32 Control valve	X			5.4 Normal terminal stopping devices	X			
2.33 Tanks	X			5.5 Traveling cables	X			
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X	
2.37 Pressure switch	X			5.7 Car frame and platform	X			
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X	
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X			
2.40 Maintenance records	X			5.12 Car buffers	X			
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X			
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X	
2.45 Inspection operation with open door circuits and inspection hierarchy			X	5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
3 TOP OF CAR				5.17 Plunger gripper			X	
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)				
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X	
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X	
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X	
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000			X	
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00	X			
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X	
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X	
				6.8 A17.1-2010/B44-10			X	
				6.9 A17.1-2013/B44-13			X	

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

F. Jay Taylor Visual Arts Center
b/t Tech Dr & Mayfield
Ruston, LA 71270

Location ID:

731002-62

Location Contact Information:

Name: JOE PEEL

Title:

Phone: +13182573267

Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0254

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 3500

Inspector Notes:

Testing Results: Relief (psi): 470, Working (psi): 185,

Inspection Start Time: 11:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 6/2/1995

Plunger Gripper?

Speed: 100

Inspection End Time: 12:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Dover

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	2.16.3.3 - Repair in car emergency lights are very dim	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0254

Device Type: Hydraulic Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Aillett Field House
Railroad Ave
Ruston, LA 71270

Location ID:

731002-73

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0255

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 3500

Inspector Notes:

Testing Results:

Inspection Start Time: 2:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 3/6/2000

Plunger Gripper?

Speed: 100

Inspection End Time: 2:30:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1

Device Manufacturer: Schindler

Cat 5 Required?

Violation Information:

Previous Violations

Previous Violation

1.18 Restricted opening of car or hoistway doors

Inspector Comments

A17.1- 8.6.4.13 Repair the elevator car door restrictor

Corrected?

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0255

Device Type: Hydraulic Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A						
1.1 Door reopening device	X								
1.2 Stop Switches	X								
1.3 Operating control devices	X								
1.4 Sills and car floor	X								
1.5 Car lighting and receptacles	X								
1.6 Car emergency signal	X								
1.7 Car door or gate	X								
1.8 Door closing force	X								
1.9 Power closing of doors or gates	X								
1.10 Power opening of doors or gates	X								
1.11 Car vision panels and glass car doors	X								
1.12 Car enclosure	X								
1.13 Emergency exit	X								
1.14 Ventilation	X								
1.15 Signs and operating device symbols	X								
1.16 Rated load, platform area, and data plate	X								
1.17 Standby power operation	X								
1.18 Restricted opening of car or hoistway doors		X							
1.19 Car ride	X								
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X						
2 MACHINE ROOM	OK	NG	N/A						
2.1 Access to machinery space	X								
2.2 Headroom	X								
2.3 Lighting and receptacles	X								
2.4 Machinery space	X								
2.5 Housekeeping	X								
2.6 Ventilation	X								
2.7 Fire extinguisher	X								
2.8 Pipes, wiring, and ducts	X								
2.9 Guarding of exposed auxiliary equipment	X								
2.10 Numbering of elevators, machines, controllers & disconnect switches	X								
2.11 Disconnecting means and control	X								
2.12 Controller wiring, fuses, grounding, etc.	X								
2.13 Governor, overspeed switch, and seal			X						
2.14 Code data plate	X								
2.30 Hydraulic power unit	X								
2.31 Relief valves	X								
2.32 Control valve	X								
2.33 Tanks	X								
2.36 Hydraulic cylinders	X								
2.37 Pressure switch	X								
2.38 Roped water hydraulic elevators			X						
2.39 Low oil protection	X								
2.40 Maintenance records	X								
2.41 Hydraulic control	X								
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X						
2.44 Auxiliary power lowering operation	X								
2.45 Inspection operation with open door circuits and inspection hierarchy	X								
3 TOP OF CAR	OK	NG	N/A						
3.1 Top-of-car stop switch	X								
3.2 Car top light and outlet	X								
3.3 Top-of-car operating device	X								
3.4 Top-of-car clearance, refuge space, and standard railing	X								
3.5 Normal terminal stopping devices	X								
3.6 Final and emergency terminal stopping devices	X								
3.7 Top-of-car operating device	X								
3.8 Top-of-car clearance, refuge space, and standard railing	X								
3.9 Floor and emergency identification numbering	OK	NG	N/A						
3.9 Floor and emergency identification numbering								X	
3.10 Hoistway Construction								X	
3.11 Hoistway smoke control								X	
3.12 Pipes, wiring, and ducts								X	
3.13 Windows, projections, recesses, and setbacks								X	
3.14 Hoistway clearances								X	
3.15 Multiple hoistways								X	
3.16 Traveling cables and junction boxes								X	
3.17 Door and gate equipment								X	
3.18 Car frame and stiles								X	
3.19 Guide rails, fastenings, and equipment								X	
3.20 Governor rope									X
3.21 Governor releasing carrier									X
3.22 Wire rope fastening and hitch plate									X
3.23 Suspension compensation and governor systems									X
3.27 Crosshead data plate and rope data tags							X		
3.28 Counterweight and counterweight buffer									X
3.29 Counterweight safeties									X
3.30 Speed Test							X		
3.31 Slack rope test - roped hydraulic elevators									X
3.32 Speed Test									X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)									X
4 OUTSIDE HOISTWAY	OK	NG	N/A						
4.1 Car platform guard							X		
4.2 Hoistway doors							X		
4.3 Vision panels							X		
4.4 Hoistway door-locking devices							X		
4.5 Access to hoistway							X		
4.6 Power closing of hoistway doors							X		
4.7 Sequence operation							X		
4.8 Hoistway enclosure							X		
4.9 Elevator parking devices							X		
4.10 Emergency doors in blind hoistways									X
4.12 Standby power selection switch							X		
5 PIT	OK	NG	N/A						
5.1 Pit access, lighting, stop switch & condition							X		
5.2 Bottom clearance, runby & minimum refuge space							X		
5.4 Normal terminal stopping devices							X		
5.5 Traveling cables							X		
5.6 Governor-rope tension devices									X
5.7 Car frame and platform							X		
5.8 Car and counterweight safeties and guiding members									X
5.11 Buffers and emergency terminal speed-limiting devices							X		
5.12 Car buffers							X		
5.13 Guiding members [rails, rollers, slides]							X		
5.14 Guiding members [rails, rollers, slides]							X		
5.15 Overspeed valve									X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)									X
5.17 Plunger gripper									X
6 FIREFIGHTERS' SERVICE (FEO)	OK	NG	N/A						
6.1 A17.1-1984 through A17.1a-1988 and A17.3									X
6.2 A17.1b-1989 through A17.1d-2000									X
6.3 A17.1-1984 through A17.1a-1988 and A17.3									X
6.4 A17.1b-1989 through A17.1d-2000							X		
6.5 A 17.1-2000/644-00									X
6.6 A 17.1-2004/644-04									X
6.7 A17.1-2007/B44-07									X
6.8 A17.1-2010/B44-10									X
6.9 A17.1-2013/B44-13									X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Keeny Hall
Keeny Circle
Ruston, LA 71270

Location ID:

731002-33

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/9/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: H0647

Due Month: November

Code Edition:

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results: Relief (psi): 470, Working (psi): 160,

Inspection Start Time: 1:30:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Hydraulic Elevator

Device Use: Passenger

Installation Date: 10/5/2001

Plunger Gripper?

Speed: 125

Inspection End Time: 2:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 4

Device Designation: #1

Device Manufacturer: EC

Cat 5 Required?

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- 2.27.1.13 Repair emergency phone located inside of elevator	No
2.1 Access to machine space	A17.1- 2.7.1.1 Patch holes located in the elevator machine room walls	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0647

Device Type: Hydraulic Elevator

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

	OK	NG	N/A		OK	NG	N/A
1 INSIDE OF CAR							
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices		X		3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space		X		3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal	X			4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators		X		5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxiliary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00			X
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
				6.8 A17.1-2010/B44-10			X
				6.9 A17.1-2013/B44-13			X

Agency Information:**Agency Address:**

Maintenance Company Information:**Maintenance Company:**

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:**Location Address:**Bogard Hall
College Dr
Ruston, LA 71270**Location ID:**

731002-57

Location Contact Information:Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:**Inspection Date:** 11/9/2023**Inspector:** Voiles, Jeff ||**Re-Inspection Required:** No**Device ID:** L0023**Due Month:** November**Code Edition:****Cat 5 Required?****Inspector Notes:****Testing Results:****Inspection Start Time:** 11:30:00 AM**Inspection Type:** Category 1 Test**Generator Test Performed:** No**Device Type:** Wheelchair Lift**Device Use:** Passenger**Installation Date:****Capacity:** 750**Inspection End Time:** 12:00:00 PM**Inspection Result:** Passed - No Violations**Re-Inspection Maint Co Required:** No**# of Landings:** 2**Device Designation:** #2**Device Manufacturer:** Porch Lift**Speed:** 8

Violation Information:

Checklist and Report for Inspection of Lifts ASME A18.1-2020 Requirement: 10.2.2

ID No: L0023

Device Type: Wheelchair Lift

Date: 11/9/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

A	INSIDE PLATFORM INSPECTIONS	OK	NG	N/A	C	INSIDE RUNWAY INSPECTIONS	OK	NG	N/A
1	Stop switches	X			1	Platform, overhead, and deflector sheaves	X		
2	Operating control devices	X			2	Normal terminal stopping devices	X		
3	Floor and landing sill	X			3	Final terminal stopping devices	X		
4	Lighting	X			4	Broken rope, chain, or tape switch			X
5	Emergency signal	X			5	Counterweight			X
6	Door or gate	X			6	Head room	X		
7	Enclosure	X			7	Slack-rope devices			X
8	Floor	X			8	Traveling sheave			X
9	Signs and operating device symbols	X			9	Platform safeties and guiding members			X
10	Rate load, platform floor area and data plate	X			10	Runway construction	X		
11	Ride	X			11	Pipes, wiring and ducts	X		
B MACHINE INSPECTIONS					12	Runway clearances	X		
1	Enclosure of machine space	X			13	Traveling cables and junction boxes	X		
2	Guarding of exposed auxiliary equipment	X			14	Door and gate equipment	X		
3	Overhead beam and fastenings	X			15	Platform frame	X		
4	Drive-machine brake			X	16	Guide rails fastening and equipment	X		
5	Traction drive machines			X	17	Governor rope			X
6	Gears and bearings	X			18	Governor releasing carrier			X
7	Winding drum machine			X	19	Wire rope fastening and hitch plate			X
8	Belt- or chain-drive machine			X	20	Suspension rope			X
9	Traction sheaves			X	21	Compensation ropes and chains			X
10	Secondary and deflector sheaves			X	D OUTSIDE RUNWAY INSPECTIONS				
11	Rope fastenings			X	1	Runway doors	X		
12	Slack-rope devices			X	2	Runway door locking devices	X		
13	Governor, overspeed switch and seal			X	3	Runway enclosure	X		
14	Platform safeties			X					
15	Hydraulic power unit	X							
16	Control valves	X							
17	Hydraulic cylinders	X							

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Davison Athletic Complex
1450 W. Alabama
Ruston, LA 71270

Location ID:
731002-109

Location Contact Information:
Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023
Inspector: Voiles, Jeff ||
Re-Inspection Required: No
Device ID: T0097
Due Month: November
Code Edition:
Cat 5 Required? No
Inspector Notes:
Testing Results:

Inspection Start Time: 12:00:00 PM
Inspection Type: Category 1 Test
Generator Test Performed: No
Device Type: Traction Elevator
Device Use: Passenger
Installation Date: 6/4/2015
Capacity: 2500

Inspection End Time: 1:00:00 PM
Inspection Result: Passed - No Violations
Re-Inspection Maint Co Required: No
of Landings: 3
Device Designation: #1
Device Manufacturer: Schindler
Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Davison Athletic Complex, 1450 W. Alabama Ruston, LA 71270

ID No: T0097

Device Type: Traction Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR					OK NG N/A
1.1 Door reopening device	X				
1.2 Stop Switches	X				
1.3 Operating control devices	X				
1.4 Sills and car floor	X				
1.5 Car lighting and receptacles	X				
1.6 Car emergency signal	X				
1.7 Car door or gate	X				
1.8 Door closing force	X				
1.9 Power closing of doors or gates	X				
1.10 Power opening of doors or gates	X				
1.11 Car vision panels and glass car doors	X				
1.12 Car enclosure	X				
1.13 Emergency exit	X				
1.14 Ventilation	X				
1.15 Signs and operating device symbols	X				
1.16 Rated load, platform area, and data plate	X				
1.17 Standby power operation	X				
1.18 Restricted opening of car or hoistway doors	X				
1.19 Car ride	X				
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		
2 MACHINE ROOM					
2.1 Access to machinery space	X				
2.2 Headroom	X				
2.3 Lighting and receptacles	X				
2.4 Machinery space	X				
2.5 Housekeeping	X				
2.6 Ventilation	X				
2.7 Fire extinguisher	X				
2.8 Pipes, wiring, and ducts	X				
2.9 Guarding of exposed auxiliary equipment	X				
2.10 Numbering of elevators, machines, controllers & disconnect switches	X				
2.11 Disconnecting means and control	X				
2.12 Controller wiring, fuses, grounding, etc.	X				
2.13 Governor, overspeed switch, and seal	X				
2.14 Code data plate	X				
2.15 Static control	X				
2.16 Overhead beam and fastenings	X				
2.17 Drive machine brake	X				
2.18 Traction-drive machines	X				
2.19 Gears, bearings, and flexible couplings	X				
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X		
2.21 Belt- or chain-drive machine			X		
2.22 Motor generator			X		
2.23 Absorption of regenerated power	X				
2.24 AC drives from a DC source	X				
2.25 Traction sheaves	X				
2.26 Secondary and deflector sheaves	X				
2.27 Rope fastenings	X				
2.28 Terminal stopping devices	X				
2.29 Car and counterweight safeties	X				
2.40 Maintenance records	X				
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		
3 TOP OF CAR					
3.1 Top-of-car stop switch	X				
3.2 Car top light and outlet	X				
3.3 Top-of-car operating device	X				
3.4 Top-of-car clearance, refuge space, and standard railing	X				
3.5 Normal terminal stopping devices	X				
3.6 Final and emergency terminal stopping devices	X				
3.7 Car leveling and anticreep devices					X
3.8 Top emergency exit					X
3.9 Floor and emergency identification numbering					X
3.10 Hoistway construction					X
3.11 Hoistway smoke control					X
3.12 Pipes, wiring, and ducts					X
3.13 Windows, projections, recesses, and setbacks					X
3.14 Hoistway clearances					X
3.15 Multiple hoistways					X
3.16 Traveling cables and junction boxes					X
3.17 Door and gate equipment					X
3.18 Car frame and stiles					X
3.19 Guide rails, fastenings, and equipment					X
3.20 Governor rope					X
3.21 Governor releasing carrier					X
3.22 Wire rope fastening and hitch plate					X
3.23 Suspension compensation and governor systems					X
3.27 Crosshead data plate and rope data tags					X
3.28 Counterweight and counterweight buffer					X
3.29 Counterweight safeties					X
3.30 Speed Test					X
3.33 Compensating ropes and chains					X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)					X
4 OUTSIDE HOISTWAY					
4.1 Car platform guard					X
4.2 Hoistway doors					X
4.3 Vision panels					X
4.4 Hoistway door-locking devices					X
4.5 Access to hoistway					X
4.6 Power closing of hoistway doors					X
4.7 Sequence operation					X
4.8 Hoistway enclosure					X
4.9 Elevator parking devices					X
4.10 Emergency doors in blind hoistways					X
4.12 Standby power selection switch					X
5 PIT					
5.1 Pit access, lighting, stop switch & condition					X
5.2 Bottom clearance, runby & minimum refuge space					X
5.3 Final and emergency terminal stopping devices					X
5.4 Normal terminal stopping devices					X
5.5 Traveling cables					X
5.6 Governor-rope tension devices					X
5.7 Car frame and platform					X
5.8 Car and counterweight safeties and guiding members					X
5.9 Buffers and emergency terminal speed-limiting devices					X
5.10 Compensating chains, ropes & sheaves					X
5.12 Car buffers					X
5.13 Guiding members [rails, rollers, slides]					X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)					X
6 FIREFIGHTERS' SERVICE (FEO)					
6.1 A17.1b-1973 through A17.1b-1980					X
6.2 17.1-1981 through A17.1b-1983					X
6.3 A17.1-1984 through A17.1a-1988 and A17.3					X
6.4 A17.1b-1989 through A17.1d-2000					X
6.5 A 17.1-2000/644-00					X
6.6 A 17.1-2004/644-04					X
6.7 A17.1-2007/B44-07					X
6.8 A17.1-2010/B44-10					X
6.9 A17.1-2013/B44-13					X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:
Davison Athletic Complex
1450 W. Alabama
Ruston, LA 71270

Location ID:
731002-109

Location Contact Information:
Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0098

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 1:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 6/4/2015

Capacity: 2500

Inspection End Time: 2:00:00 AM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #2

Device Manufacturer: Schindler

Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Davison Athletic Complex, 1450 W. Alabama Ruston, LA 71270

ID No: T0098

Device Type: Traction Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A							OK	NG	N/A
1.1 Door reopening device	X									X		
1.2 Stop Switches	X									X		
1.3 Operating control devices	X									X		
1.4 Sills and car floor	X									X		
1.5 Car lighting and receptacles	X									X		
1.6 Car emergency signal	X									X		
1.7 Car door or gate	X									X		
1.8 Door closing force	X									X		
1.9 Power closing of doors or gates	X									X		
1.10 Power opening of doors or gates	X									X		
1.11 Car vision panels and glass car doors	X									X		
1.12 Car enclosure	X									X		
1.13 Emergency exit	X									X		
1.14 Ventilation	X									X		
1.15 Signs and operating device symbols	X									X		
1.16 Rated load, platform area, and data plate	X									X		
1.17 Standby power operation	X									X		
1.18 Restricted opening of car or hoistway doors	X									X		
1.19 Car ride	X									X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X									X
2 MACHINE ROOM	OK	NG	N/A							OK	NG	N/A
2.1 Access to machinery space	X									X		
2.2 Headroom	X									X		
2.3 Lighting and receptacles	X									X		
2.4 Machinery space	X									X		
2.5 Housekeeping	X									X		
2.6 Ventilation	X									X		
2.7 Fire extinguisher	X									X		
2.8 Pipes, wiring, and ducts	X									X		
2.9 Guarding of exposed auxiliary equipment	X									X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X									X		
2.11 Disconnecting means and control	X									X		
2.12 Controller wiring, fuses, grounding, etc.	X									X		
2.13 Governor, overspeed switch, and seal	X									X		
2.14 Code data plate	X									X		
2.15 Static control	X									X		
2.16 Overhead beam and fastenings	X									X		
2.17 Drive machine brake	X									X		
2.18 Traction-drive machines	X									X		
2.19 Gears, bearings, and flexible couplings	X									X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X									
2.21 Belt- or chain-drive machine			X									
2.22 Motor generator			X									
2.23 Absorption of regenerated power	X									X		
2.24 AC drives from a DC source	X									X		
2.25 Traction sheaves	X									X		
2.26 Secondary and deflector sheaves	X									X		
2.27 Rope fastenings	X									X		
2.28 Terminal stopping devices	X									X		
2.29 Car and counterweight safeties	X									X		
2.40 Maintenance records	X									X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X									
3 TOP OF CAR	OK	NG	N/A							OK	NG	N/A
3.1 Top-of-car stop switch	X									X		
3.2 Car top light and outlet	X									X		
3.3 Top-of-car operating device	X									X		
3.4 Top-of-car clearance, refuge space, and standard railing	X									X		
3.5 Normal terminal stopping devices	X									X		
3.6 Final and emergency terminal stopping devices	X									X		
4 OUTSIDE HOISTWAY	OK	NG	N/A							OK	NG	N/A
4.1 Car platform guard										X		
4.2 Hoistway doors										X		
4.3 Vision panels										X		
4.4 Hoistway door-locking devices										X		
4.5 Access to hoistway										X		
4.6 Power closing of hoistway doors										X		
4.7 Sequence operation										X		
4.8 Hoistway enclosure										X		
4.9 Elevator parking devices										X		
4.10 Emergency doors in blind hoistways												X
4.12 Standby power selection switch										X		
5 PIT	OK	NG	N/A							OK	NG	N/A
5.1 Pit access, lighting, stop switch & condition										X		
5.2 Bottom clearance, runby & minimum refuge space										X		
5.3 Final and emergency terminal stopping devices										X		
5.4 Normal terminal stopping devices										X		
5.5 Traveling cables										X		
5.6 Governor-rope tension devices										X		
5.7 Car frame and platform										X		
5.8 Car and counterweight safeties and guiding members										X		
5.9 Buffers and emergency terminal speed-limiting devices										X		
5.10 Compensating chains, ropes & sheaves										X		
5.12 Car buffers										X		
5.13 Guiding members [rails, rollers, slides]										X		
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)												X
6 FIREFIGHTERS' SERVICE (FEO)	OK	NG	N/A							OK	NG	N/A
6.1 A17.1b-1973 through A17.1b-1980												X
6.2 17.1-1981 through A17.1b-1983												X
6.3 A17.1-1984 through A17.1a-1988 and A17.3												X
6.4 A17.1b-1989 through A17.1d-2000												X
6.5 A 17.1-2000/644-00												X
6.6 A 17.1-2004/644-04												X
6.7 A17.1-2007/B44-07												X
6.8 A17.1-2010/B44-10												X
6.9 A17.1-2013/B44-13										X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Davison Athletic Complex
1450 W. Alabama
Ruston, LA 71270

Location ID:

731002-109

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0099

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 4:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Freight

Installation Date: 3/4/2017

Capacity: 4000

Inspection End Time: 5:00:00 PM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #3 Freight

Device Manufacturer: Schindler

Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Davison Athletic Complex, 1450 W. Alabama Ruston, LA 71270

ID No: T0099

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK NG N/A		OK NG N/A
1.1 Door reopening device	X		X
1.2 Stop Switches	X		X
1.3 Operating control devices	X		X
1.4 Sills and car floor	X		X
1.5 Car lighting and receptacles	X		X
1.6 Car emergency signal	X		X
1.7 Car door or gate	X		X
1.8 Door closing force	X		X
1.9 Power closing of doors or gates	X		X
1.10 Power opening of doors or gates	X		X
1.11 Car vision panels and glass car doors	X		X
1.12 Car enclosure	X		X
1.13 Emergency exit	X		X
1.14 Ventilation	X		X
1.15 Signs and operating device symbols	X		X
1.16 Rated load, platform area, and data plate	X		X
1.17 Standby power operation	X		X
1.18 Restricted opening of car or hoistway doors	X		X
1.19 Car ride	X		X
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)		X	
2 MACHINE ROOM			
2.1 Access to machinery space	X		
2.2 Headroom	X		
2.3 Lighting and receptacles	X		
2.4 Machinery space	X		
2.5 Housekeeping	X		
2.6 Ventilation	X		
2.7 Fire extinguisher	X		
2.8 Pipes, wiring, and ducts	X		
2.9 Guarding of exposed auxiliary equipment	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X		
2.11 Disconnecting means and control	X		
2.12 Controller wiring, fuses, grounding, etc.	X		
2.13 Governor, overspeed switch, and seal	X		
2.14 Code data plate	X		
2.15 Static control	X		
2.16 Overhead beam and fastenings	X		
2.17 Drive machine brake	X		
2.18 Traction-drive machines	X		
2.19 Gears, bearings, and flexible couplings	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening		X	
2.21 Belt- or chain-drive machine		X	
2.22 Motor generator		X	
2.23 Absorption of regenerated power	X		
2.24 AC drives from a DC source	X		
2.25 Traction sheaves	X		
2.26 Secondary and deflector sheaves	X		
2.27 Rope fastenings	X		
2.28 Terminal stopping devices	X		
2.29 Car and counterweight safeties	X		
2.40 Maintenance records	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)		X	
3 TOP OF CAR			
3.1 Top-of-car stop switch	X		
3.2 Car top light and outlet	X		
3.3 Top-of-car operating device	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X		
3.5 Normal terminal stopping devices	X		
3.6 Final and emergency terminal stopping devices	X		
3.7 Car leveling and anticreep devices			X
3.8 Top emergency exit			X
3.9 Floor and emergency identification numbering			X
3.10 Hoistway construction			X
3.11 Hoistway smoke control			X
3.12 Pipes, wiring, and ducts			X
3.13 Windows, projections, recesses, and setbacks			X
3.14 Hoistway clearances			X
3.15 Multiple hoistways			X
3.16 Traveling cables and junction boxes			X
3.17 Door and gate equipment			X
3.18 Car frame and stiles			X
3.19 Guide rails, fastenings, and equipment			X
3.20 Governor rope			X
3.21 Governor releasing carrier			X
3.22 Wire rope fastening and hitch plate			X
3.23 Suspension compensation and governor systems			X
3.27 Crosshead data plate and rope data tags			X
3.28 Counterweight and counterweight buffer			X
3.29 Counterweight safeties			X
3.30 Speed Test			X
3.33 Compensating ropes and chains			X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
4 OUTSIDE HOISTWAY			
4.1 Car platform guard			X
4.2 Hoistway doors			X
4.3 Vision panels			X
4.4 Hoistway door-locking devices			X
4.5 Access to hoistway			X
4.6 Power closing of hoistway doors			X
4.7 Sequence operation			X
4.8 Hoistway enclosure			X
4.9 Elevator parking devices			X
4.10 Emergency doors in blind hoistways			X
4.12 Standby power selection switch			X
5 PIT			
5.1 Pit access, lighting, stop switch & condition			X
5.2 Bottom clearance, runby & minimum refuge space			X
5.3 Final and emergency terminal stopping devices			X
5.4 Normal terminal stopping devices			X
5.5 Traveling cables			X
5.6 Governor-rope tension devices			X
5.7 Car frame and platform			X
5.8 Car and counterweight safeties and guiding members			X
5.9 Buffers and emergency terminal speed-limiting devices			X
5.10 Compensating chains, ropes & sheaves			X
5.12 Car buffers			X
5.13 Guiding members [rails, rollers, slides]			X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
6 FIREFIGHTERS' SERVICE (FEO)			
6.1 A17.1b-1973 through A17.1b-1980			X
6.2 17.1-1981 through A17.1b-1983			X
6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
6.4 A17.1b-1989 through A17.1d-2000			X
6.5 A 17.1-2000/644-00			X
6.6 A 17.1-2004/644-04			X
6.7 A17.1-2007/B44-07			X
6.8 A17.1-2010/B44-10			X
6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Howard Center For The Performing
Arts
Main Campus
Ruston, LA 71272

Location ID:

731002-56

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0102

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 12:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Freight

Installation Date: 4/3/1940

Capacity: 2000

Inspection End Time: 12:30:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: Otis

Speed: 75

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	2.27.1 - Repair in car alarm	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Howard Center For The Performing Arts, Main Campus Ruston, LA 71272

ID No: T0102

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR									OK NG N/A
1.1 Door reopening device									X
1.2 Stop Switches	X								X
1.3 Operating control devices		X							X
1.4 Sills and car floor	X								X
1.5 Car lighting and receptacles	X								X
1.6 Car emergency signal	X								X
1.7 Car door or gate	X								X
1.8 Door closing force				X					X
1.9 Power closing of doors or gates				X					X
1.10 Power opening of doors or gates				X					X
1.11 Car vision panels and glass car doors	X								X
1.12 Car enclosure	X								X
1.13 Emergency exit	X								X
1.14 Ventilation	X								X
1.15 Signs and operating device symbols	X								X
1.16 Rated load, platform area, and data plate	X								X
1.17 Standby power operation				X					X
1.18 Restricted opening of car or hoistway doors	X								X
1.19 Car ride	X								X
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)				X					X
2 MACHINE ROOM									
2.1 Access to machinery space	X								X
2.2 Headroom	X								X
2.3 Lighting and receptacles	X								X
2.4 Machinery space	X								X
2.5 Housekeeping	X								X
2.6 Ventilation	X								X
2.7 Fire extinguisher	X								X
2.8 Pipes, wiring, and ducts	X								X
2.9 Guarding of exposed auxiliary equipment	X								X
2.10 Numbering of elevators, machines, controllers & disconnect switches	X								X
2.11 Disconnecting means and control	X								X
2.12 Controller wiring, fuses, grounding, etc.	X								X
2.13 Governor, overspeed switch, and seal	X								X
2.14 Code data plate	X								X
2.15 Static control	X								X
2.16 Overhead beam and fastenings	X								X
2.17 Drive machine brake	X								X
2.18 Traction-drive machines	X								X
2.19 Gears, bearings, and flexible couplings	X								X
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening				X					X
2.21 Belt- or chain-drive machine				X					X
2.22 Motor generator				X					X
2.23 Absorption of regenerated power				X					X
2.24 AC drives from a DC source				X					X
2.25 Traction sheaves	X								X
2.26 Secondary and deflector sheaves	X								X
2.27 Rope fastenings	X								X
2.28 Terminal stopping devices	X								X
2.29 Car and counterweight safeties	X								X
2.40 Maintenance records	X								X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)				X					X
3 TOP OF CAR									
3.1 Top-of-car stop switch	X								X
3.2 Car top light and outlet	X								X
3.3 Top-of-car operating device	X								X
3.4 Top-of-car clearance, refuge space, and standard railing	X								X
3.5 Normal terminal stopping devices	X								X
3.6 Final and emergency terminal stopping devices	X								X
3.7 Car leveling and anticreep devices									X
3.8 Top emergency exit									X
3.9 Floor and emergency identification numbering									X
3.10 Hoistway construction									X
3.11 Hoistway smoke control									X
3.12 Pipes, wiring, and ducts									X
3.13 Windows, projections, recesses, and setbacks									X
3.14 Hoistway clearances									X
3.15 Multiple hoistways									X
3.16 Traveling cables and junction boxes									X
3.17 Door and gate equipment									X
3.18 Car frame and stiles									X
3.19 Guide rails, fastenings, and equipment									X
3.20 Governor rope									X
3.21 Governor releasing carrier									X
3.22 Wire rope fastening and hitch plate									X
3.23 Suspension compensation and governor systems									X
3.27 Crosshead data plate and rope data tags									X
3.28 Counterweight and counterweight buffer									X
3.29 Counterweight safeties									X
3.30 Speed Test									X
3.33 Compensating ropes and chains									X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)									X
4 OUTSIDE HOISTWAY									
4.1 Car platform guard									X
4.2 Hoistway doors									X
4.3 Vision panels									X
4.4 Hoistway door-locking devices									X
4.5 Access to hoistway									X
4.6 Power closing of hoistway doors									X
4.7 Sequence operation									X
4.8 Hoistway enclosure									X
4.9 Elevator parking devices									X
4.10 Emergency doors in blind hoistways									X
4.12 Standby power selection switch									X
5 PIT									
5.1 Pit access, lighting, stop switch & condition									X
5.2 Bottom clearance, runby & minimum refuge space									X
5.3 Final and emergency terminal stopping devices									X
5.4 Normal terminal stopping devices									X
5.5 Traveling cables									X
5.6 Governor-rope tension devices									X
5.7 Car frame and platform									X
5.8 Car and counterweight safeties and guiding members									X
5.9 Buffers and emergency terminal speed-limiting devices									X
5.10 Compensating chains, ropes & sheaves									X
5.12 Car buffers									X
5.13 Guiding members [rails, rollers, slides]									X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)									X
6 FIREFIGHTERS' SERVICE (FEO)									
6.1 A17.1b-1973 through A17.1b-1980									X
6.2 17.1-1981 through A17.1b-1983									X
6.3 A17.1-1984 through A17.1a-1988 and A17.3									X
6.4 A17.1b-1989 through A17.1d-2000									X
6.5 A 17.1-2000/644-00									X
6.6 A 17.1-2004/644-04									X
6.7 A17.1-2007/B44-07									X
6.8 A17.1-2010/B44-10									X
6.9 A17.1-2013/B44-13									X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address: Integrated Engineering & Science Bldg 418 Dan Reneau Dr Ruston, LA 71272	Location ID: 731002-127	Location Contact Information: Name: Joe Peel Title: Phone: +13182573267 Email: JPEEL@LATECH.EDU
---	-----------------------------------	--

Inspection Information:

Inspection Date: 11/7/2023	Inspection Start Time: 10:00:00 AM	Inspection End Time: 11:00:00 AM
Inspector: Voiles, Jeff	Inspection Type: Category 1 Test	Inspection Result: Passed - Violations
Re-Inspection Required: No	Generator Test Performed: No	Re-Inspection Maint Co Required: No
Device ID: T0279	Device Type: Traction Elevator	# of Landings: 3
Due Month: November	Device Use: Passenger	Device Designation: #1
Code Edition:	Installation Date: 11/8/2019	Device Manufacturer: Schindler
Cat 5 Required?	Capacity: 3500	Speed: 150
Inspector Notes:		
Testing Results:		

Violation Information:

<u>Previous Violations</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.3 Operating control devices	A17.1- Repair emergency phone located inside the elevator, phone must call Louisiana tech security	Yes
5.1 Pit access; lighting; stop switch; and condition	A17.1- 8.6.4.7 Clean debris from elevator pit area	No
1.15 Signs and operating device symbols	A17.1- 2.16.3.3 Provide a car ID #2 and a capacity plate, must be located inside of elevator on the COP panel	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Integrated Engineering & Science Bldg, 418 Dan Reneau Dr Ruston, LA 71272

ID No: T0279

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: Joe Peel

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1	INSIDE OF CAR	OK	NG	N/A	OK	NG	N/A
1.1	Door reopening device	X			X		
1.2	Stop Switches	X			X		
1.3	Operating control devices	X			X		
1.4	Sills and car floor	X			X		
1.5	Car lighting and receptacles	X			X		
1.6	Car emergency signal	X			X		
1.7	Car door or gate	X			X		
1.8	Door closing force	X			X		
1.9	Power closing of doors or gates	X			X		
1.10	Power opening of doors or gates	X			X		
1.11	Car vision panels and glass car doors	X			X		
1.12	Car enclosure	X			X		
1.13	Emergency exit	X			X		
1.14	Ventilation	X			X		
1.15	Signs and operating device symbols		X				
1.16	Rated load, platform area, and data plate	X			X		
1.17	Standby power operation	X			X		
1.18	Restricted opening of car or hoistway doors	X			X		
1.19	Car ride	X			X		
1.20	Earthquake inspection and tests (seismic risk zone 2 or greater)			X			X
2	MACHINE ROOM						
2.1	Access to machinery space	X			X		
2.2	Headroom	X			X		
2.3	Lighting and receptacles	X			X		
2.4	Machinery space	X			X		
2.5	Housekeeping	X			X		
2.6	Ventilation	X			X		
2.7	Fire extinguisher	X			X		
2.8	Pipes, wiring, and ducts	X			X		
2.9	Guarding of exposed auxiliary equipment	X			X		
2.10	Numbering of elevators, machines, controllers & disconnect switches	X			X		
2.11	Disconnecting means and control	X			X		
2.12	Controller wiring, fuses, grounding, etc.	X			X		
2.13	Governor, overspeed switch, and seal	X			X		
2.14	Code data plate	X			X		
2.15	Static control	X			X		
2.16	Overhead beam and fastenings	X			X		
2.17	Drive machine brake	X			X		
2.18	Traction-drive machines	X			X		
2.19	Gears, bearings, and flexible couplings	X			X		
2.20	Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X			
2.21	Belt- or chain-drive machine			X			
2.22	Motor generator			X			
2.23	Absorption of regenerated power	X			X		
2.24	AC drives from a DC source	X			X		
2.25	Traction sheaves	X			X		
2.26	Secondary and deflector sheaves	X			X		
2.27	Rope fastenings	X			X		
2.28	Terminal stopping devices	X			X		
2.29	Car and counterweight safeties	X			X		
2.40	Maintenance records	X			X		
2.42	Earthquake inspection and tests (seismic risk zone 2 or greater)			X			
3	TOP OF CAR						
3.1	Top-of-car stop switch	X			X		
3.2	Car top light and outlet	X			X		
3.3	Top-of-car operating device	X			X		
3.4	Top-of-car clearance, refuge space, and standard railing	X			X		
3.5	Normal terminal stopping devices	X			X		
3.6	Final and emergency terminal stopping devices	X			X		
3.7	Car leveling and anticreep devices				X		
3.8	Top emergency exit				X		
3.9	Floor and emergency identification numbering				X		
3.10	Hoistway construction				X		
3.11	Hoistway smoke control				X		
3.12	Pipes, wiring, and ducts				X		
3.13	Windows, projections, recesses, and setbacks				X		
3.14	Hoistway clearances				X		
3.15	Multiple hoistways				X		
3.16	Traveling cables and junction boxes				X		
3.17	Door and gate equipment				X		
3.18	Car frame and stiles				X		
3.19	Guide rails, fastenings, and equipment				X		
3.20	Governor rope				X		
3.21	Governor releasing carrier				X		
3.22	Wire rope fastening and hitch plate				X		
3.23	Suspension compensation and governor systems				X		
3.27	Crosshead data plate and rope data tags				X		
3.28	Counterweight and counterweight buffer				X		
3.29	Counterweight safeties						X
3.30	Speed Test				X		
3.33	Compensating ropes and chains				X		
3.34	Earthquake inspection and tests (seismic risk zone 2 or greater)						X
4	OUTSIDE HOISTWAY						
4.1	Car platform guard				X		
4.2	Hoistway doors				X		
4.3	Vision panels				X		
4.4	Hoistway door-locking devices				X		
4.5	Access to hoistway				X		
4.6	Power closing of hoistway doors				X		
4.7	Sequence operation				X		
4.8	Hoistway enclosure				X		
4.9	Elevator parking devices				X		
4.10	Emergency doors in blind hoistways						X
4.12	Standby power selection switch				X		
5	PIT						
5.1	Pit access, lighting, stop switch & condition						X
5.2	Bottom clearance, runby & minimum refuge space				X		
5.3	Final and emergency terminal stopping devices				X		
5.4	Normal terminal stopping devices				X		
5.5	Traveling cables				X		
5.6	Governor-rope tension devices				X		
5.7	Car frame and platform				X		
5.8	Car and counterweight safeties and guiding members				X		
5.9	Buffers and emergency terminal speed-limiting devices				X		
5.10	Compensating chains, ropes & sheaves				X		
5.12	Car buffers				X		
5.13	Guiding members [rails, rollers, slides]				X		
5.16	Earthquake inspection and tests (seismic risk zone 2 or greater)						X
6	FIREFIGHTERS' SERVICE (FEO)						
6.1	A17.1b-1973 through A17.1b-1980						X
6.2	17.1-1981 through A17.1b-1983						X
6.3	A17.1-1984 through A17.1a-1988 and A17.3						X
6.4	A17.1b-1989 through A17.1d-2000						X
6.5	A 17.1-2000/644-00						X
6.6	A 17.1-2004/644-04						X
6.7	A17.1-2007/B44-07						X
6.8	A17.1-2010/B44-10						X
6.9	A17.1-2013/B44-13						X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Integrated Engineering & Science
Bldg
418 Dan Reneau Dr
Ruston, LA 71272

Location ID:

731002-127

Location Contact Information:

Name: Joe Peel
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0280

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 11:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date:

Capacity: 3500

Inspection End Time: 12:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #2

Device Manufacturer: Schindler

Speed: 150

Violation Information:

Previous Violations

Previous Violation

5.1 Pit access; lighting; stop switch; and condition

Inspector Comments

A17.1- 8.6.4.7 Clean debris from elevator pit area

Corrected?

No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Integrated Engineering & Science Bldg, 418 Dan Reneau Dr Ruston, LA 71272

ID No: T0280

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: Joe Peel

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A													OK	NG	N/A	
1.1 Door reopening device	X															X			
1.2 Stop Switches	X															X			
1.3 Operating control devices	X															X			
1.4 Sills and car floor	X															X			
1.5 Car lighting and receptacles	X															X			
1.6 Car emergency signal	X															X			
1.7 Car door or gate	X															X			
1.8 Door closing force	X															X			
1.9 Power closing of doors or gates	X															X			
1.10 Power opening of doors or gates	X															X			
1.11 Car vision panels and glass car doors	X															X			
1.12 Car enclosure	X															X			
1.13 Emergency exit	X															X			
1.14 Ventilation	X															X			
1.15 Signs and operating device symbols	X															X			
1.16 Rated load, platform area, and data plate	X															X			
1.17 Standby power operation	X															X			
1.18 Restricted opening of car or hoistway doors	X															X			
1.19 Car ride	X															X			
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X															X	
2 MACHINE ROOM	OK	NG	N/A													OK	NG	N/A	
2.1 Access to machinery space	X															X			
2.2 Headroom	X															X			
2.3 Lighting and receptacles	X															X			
2.4 Machinery space	X															X			
2.5 Housekeeping	X															X			
2.6 Ventilation	X															X			
2.7 Fire extinguisher	X															X			
2.8 Pipes, wiring, and ducts	X															X			
2.9 Guarding of exposed auxiliary equipment	X															X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X															X			
2.11 Disconnecting means and control	X															X			
2.12 Controller wiring, fuses, grounding, etc.	X															X			
2.13 Governor, overspeed switch, and seal	X															X			
2.14 Code data plate	X															X			
2.15 Static control	X															X			
2.16 Overhead beam and fastenings	X															X			
2.17 Drive machine brake	X															X			
2.18 Traction-drive machines	X															X			
2.19 Gears, bearings, and flexible couplings	X															X			
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X															X	
2.21 Belt- or chain-drive machine			X															X	
2.22 Motor generator			X															X	
2.23 Absorption of regenerated power	X															X			
2.24 AC drives from a DC source	X															X			
2.25 Traction sheaves	X															X			
2.26 Secondary and deflector sheaves	X															X			
2.27 Rope fastenings	X															X			
2.28 Terminal stopping devices	X															X			
2.29 Car and counterweight safeties	X															X			
2.40 Maintenance records	X															X			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X															X	
3 TOP OF CAR	OK	NG	N/A													OK	NG	N/A	
3.1 Top-of-car stop switch	X															X			
3.2 Car top light and outlet	X															X			
3.3 Top-of-car operating device	X															X			
3.4 Top-of-car clearance, refuge space, and standard railing	X															X			
3.5 Normal terminal stopping devices	X															X			
3.6 Final and emergency terminal stopping devices	X															X			
4 OUTSIDE HOISTWAY	OK	NG	N/A													OK	NG	N/A	
4.1 Car platform guard																X			
4.2 Hoistway doors																X			
4.3 Vision panels																X			
4.4 Hoistway door-locking devices																X			
4.5 Access to hoistway																X			
4.6 Power closing of hoistway doors																X			
4.7 Sequence operation																X			
4.8 Hoistway enclosure																X			
4.9 Elevator parking devices																X			
4.10 Emergency doors in blind hoistways																		X	
4.12 Standby power selection switch																X			
5 PIT	OK	NG	N/A													OK	NG	N/A	
5.1 Pit access, lighting, stop switch & condition																		X	
5.2 Bottom clearance, runby & minimum refuge space																X			
5.3 Final and emergency terminal stopping devices																X			
5.4 Normal terminal stopping devices																X			
5.5 Traveling cables																X			
6 FIREFIGHTERS' SERVICE (FEO)	OK	NG	N/A													OK	NG	N/A	
6.1 A17.1b-1973 through A17.1b-1980																		X	
6.2 17.1-1981 through A17.1b-1983																		X	
6.3 A17.1-1984 through A17.1a-1988 and A17.3																		X	
6.4 A17.1b-1989 through A17.1d-2000																		X	
6.5 A 17.1-2000/644-00																		X	
6.6 A 17.1-2004/644-04																		X	
6.7 A17.1-2007/B44-07																		X	
6.8 A17.1-2010/B44-10																		X	
6.9 A17.1-2013/B44-13																		X	

Agency Information:**Agency Address:**

Maintenance Company Information:**Maintenance Company:**

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:**Location Address:**Business Bldg
502 West Texas Ave
Ruston, LA 71270**Location ID:**

731002-99

Location Contact Information:

Name: JOE PEEL

Title:

Phone: +13182573267

Email: JPEEL@LATECH.EDU

Inspection Information:**Inspection Date:** 11/7/2023**Inspector:** Voiles, Jeff ||**Re-Inspection Required:** No**Device ID:** T0322**Due Month:** November**Code Edition:****Cat 5 Required?****Inspector Notes:****Testing Results:****Inspection Start Time:** 3:00:00 PM**Inspection Type:** Category 1 Test**Generator Test Performed:** No**Device Type:** Traction Elevator**Device Use:** Passenger**Installation Date:** 6/4/2017**Capacity:** 2100**Inspection End Time:** 4:00:00 PM**Inspection Result:** Passed - No Violations**Re-Inspection Maint Co Required:** No**# of Landings:** 3**Device Designation:** #2**Device Manufacturer:** Schindler**Speed:** 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Business Bldg, 502 West Texas Ave Ruston, LA 71270

ID No: T0322

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK			NG			N/A		
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X				
1.2 Stop Switches	X			3.8 Top emergency exit	X				
1.3 Operating control devices	X			3.9 Floor and emergency identification numbering	X				
1.4 Sills and car floor	X			3.10 Hoistway construction	X				
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X				
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X				
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks	X				
1.8 Door closing force	X			3.14 Hoistway clearances	X				
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X				
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X				
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X				
1.12 Car enclosure	X			3.18 Car frame and stiles	X				
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X				
1.14 Ventilation	X			3.20 Governor rope	X				
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X				
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X				
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X				
1.18 Restricted opening of car or hoistway doors	X			3.27 Crosshead data plate and rope data tags	X				
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X				
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29 Counterweight safeties			X		
				3.30 Speed Test	X				
				3.33 Compensating ropes and chains	X				
				3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		
2 MACHINE ROOM				4 OUTSIDE HOISTWAY					
2.1 Access to machinery space	X			4.1 Car platform guard	X				
2.2 Headroom	X			4.2 Hoistway doors	X				
2.3 Lighting and receptacles	X			4.3 Vision panels	X				
2.4 Machinery space	X			4.4 Hoistway door-locking devices	X				
2.5 Housekeeping	X			4.5 Access to hoistway	X				
2.6 Ventilation	X			4.6 Power closing of hoistway doors	X				
2.7 Fire extinguisher	X			4.7 Sequence operation	X				
2.8 Pipes, wiring, and ducts	X			4.8 Hoistway enclosure	X				
2.9 Guarding of exposed auxiliary equipment	X			4.9 Elevator parking devices	X				
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.10 Emergency doors in blind hoistways			X		
2.11 Disconnecting means and control	X			4.12 Standby power selection switch	X				
2.12 Controller wiring, fuses, grounding, etc.	X			5 PIT					
2.13 Governor, overspeed switch, and seal	X			5.1 Pit access, lighting, stop switch & condition	X				
2.14 Code data plate	X			5.2 Bottom clearance, runby & minimum refuge space	X				
2.15 Static control	X			5.3 Final and emergency terminal stopping devices	X				
2.16 Overhead beam and fastenings	X			5.4 Normal terminal stopping devices	X				
2.17 Drive machine brake	X			5.5 Traveling cables	X				
2.18 Traction-drive machines	X								
2.19 Gears, bearings, and flexible couplings	X			5.6 Governor-rope tension devices	X				
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.7 Car frame and platform	X				
				5.8 Car and counterweight safeties and guiding members	X				
2.21 Belt- or chain-drive machine			X	5.9 Buffers and emergency terminal speed-limiting devices	X				
2.22 Motor generator			X	5.10 Compensating chains, ropes & sheaves	X				
2.23 Absorption of regenerated power	X			5.12 Car buffers	X				
2.24 AC drives from a DC source	X			5.13 Guiding members [rails, rollers, slides]	X				
2.25 Traction sheaves	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X		
2.26 Secondary and deflector sheaves	X			6 FIREFIGHTERS' SERVICE (FEO)					
2.27 Rope fastenings	X			6.1 A17.1b-1973 through A17.1b-1980			X		
2.28 Terminal stopping devices	X			6.2 17.1-1981 through A17.1b-1983			X		
2.29 Car and counterweight safeties	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3			X		
2.40 Maintenance records	X			6.4 A17.1b-1989 through A17.1d-2000			X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.5 A 17.1-2000/644-00			X		
				6.6 A 17.1-2004/644-04			X		
3 TOP OF CAR				6.7 A17.1-2007/B44-07			X		
3.1 Top-of-car stop switch	X			6.8 A17.1-2010/B44-10			X		
3.2 Car top light and outlet	X			6.9 A17.1-2013/B44-13			X		
3.3 Top-of-car operating device	X								
3.4 Top-of-car clearance, refuge space, and standard railing	X								
3.5 Normal terminal stopping devices	X								
3.6 Final and emergency terminal stopping devices	X								

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Aillett Stadium
Alabama Ave
Ruston, LA 71270

Location ID:

731002-69

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0453

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 9:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 7/4/2017

Capacity: 3500

Inspection End Time: 10:00:00 AM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 4

Device Designation: #1

Device Manufacturer: Schindler

Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Aillet Stadium, Alabama Ave Ruston, LA 71270

ID No: T0453

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OKNG N/A			OKNG N/A
1.1 Door reopening device	X			
1.2 Stop Switches	X			
1.3 Operating control devices	X			
1.4 Sills and car floor	X			
1.5 Car lighting and receptacles	X			
1.6 Car emergency signal	X			
1.7 Car door or gate	X			
1.8 Door closing force	X			
1.9 Power closing of doors or gates	X			
1.10 Power opening of doors or gates	X			
1.11 Car vision panels and glass car doors	X			
1.12 Car enclosure	X			
1.13 Emergency exit	X			
1.14 Ventilation	X			
1.15 Signs and operating device symbols	X			
1.16 Rated load, platform area, and data plate	X			
1.17 Standby power operation	X			
1.18 Restricted opening of car or hoistway doors	X			
1.19 Car ride	X			
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
2 MACHINE ROOM				
2.1 Access to machinery space	X			
2.2 Headroom	X			
2.3 Lighting and receptacles	X			
2.4 Machinery space	X			
2.5 Housekeeping	X			
2.6 Ventilation	X			
2.7 Fire extinguisher	X			
2.8 Pipes, wiring, and ducts	X			
2.9 Guarding of exposed auxiliary equipment	X			
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			
2.11 Disconnecting means and control	X			
2.12 Controller wiring, fuses, grounding, etc.	X			
2.13 Governor, overspeed switch, and seal	X			
2.14 Code data plate	X			
2.15 Static control	X			
2.16 Overhead beam and fastenings	X			
2.17 Drive machine brake	X			
2.18 Traction-drive machines	X			
2.19 Gears, bearings, and flexible couplings	X			
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	
2.21 Belt- or chain-drive machine			X	
2.22 Motor generator			X	
2.23 Absorption of regenerated power	X			
2.24 AC drives from a DC source	X			
2.25 Traction sheaves	X			
2.26 Secondary and deflector sheaves	X			
2.27 Rope fastenings	X			
2.28 Terminal stopping devices	X			
2.29 Car and counterweight safeties	X			
2.40 Maintenance records	X			
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
3 TOP OF CAR				
3.1 Top-of-car stop switch	X			
3.2 Car top light and outlet	X			
3.3 Top-of-car operating device	X			
3.4 Top-of-car clearance, refuge space, and standard railing	X			
3.5 Normal terminal stopping devices	X			
3.6 Final and emergency terminal stopping devices	X			
3.7 Car leveling and anticreep devices				X
3.8 Top emergency exit				X
3.9 Floor and emergency identification numbering				X
3.10 Hoistway construction				X
3.11 Hoistway smoke control				X
3.12 Pipes, wiring, and ducts				X
3.13 Windows, projections, recesses, and setbacks				X
3.14 Hoistway clearances				X
3.15 Multiple hoistways				X
3.16 Traveling cables and junction boxes				X
3.17 Door and gate equipment				X
3.18 Car frame and stiles				X
3.19 Guide rails, fastenings, and equipment				X
3.20 Governor rope				X
3.21 Governor releasing carrier				X
3.22 Wire rope fastening and hitch plate				X
3.23 Suspension compensation and governor systems				X
3.27 Crosshead data plate and rope data tags				X
3.28 Counterweight and counterweight buffer				X
3.29 Counterweight safeties				X
3.30 Speed Test				X
3.33 Compensating ropes and chains				X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
4 OUTSIDE HOISTWAY				
4.1 Car platform guard				X
4.2 Hoistway doors				X
4.3 Vision panels				X
4.4 Hoistway door-locking devices				X
4.5 Access to hoistway				X
4.6 Power closing of hoistway doors				X
4.7 Sequence operation				X
4.8 Hoistway enclosure				X
4.9 Elevator parking devices				X
4.10 Emergency doors in blind hoistways				X
4.12 Standby power selection switch				X
5 PIT				
5.1 Pit access, lighting, stop switch & condition				X
5.2 Bottom clearance, runby & minimum refuge space				X
5.3 Final and emergency terminal stopping devices				X
5.4 Normal terminal stopping devices				X
5.5 Traveling cables				X
5.6 Governor-rope tension devices				X
5.7 Car frame and platform				X
5.8 Car and counterweight safeties and guiding members				X
5.9 Buffers and emergency terminal speed-limiting devices				X
5.10 Compensating chains, ropes & sheaves				X
5.12 Car buffers				X
5.13 Guiding members [rails, rollers, slides]				X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)				X
6 FIREFIGHTERS' SERVICE (FEO)				
6.1 A17.1b-1973 through A17.1b-1980				X
6.2 17.1-1981 through A17.1b-1983				X
6.3 A17.1-1984 through A17.1a-1988 and A17.3				X
6.4 A17.1b-1989 through A17.1d-2000				X
6.5 A 17.1-2000/644-00				X
6.6 A 17.1-2004/644-04				X
6.7 A17.1-2007/B44-07				X
6.8 A17.1-2010/B44-10				X
6.9 A17.1-2013/B44-13				X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Aillett Stadium
Alabama Ave
Ruston, LA 71270

Location ID:

731002-69

Location Contact Information:

Name: JOE PEEL
Title:
Phone: +13182573267
Email: JPEEL@LATECH.EDU

Inspection Information:

Inspection Date: 11/7/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0454

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 8:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 6/4/2017

Capacity: 3500

Inspection End Time: 9:00:00 AM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 4

Device Designation: #2

Device Manufacturer: Schindler

Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Aillet Stadium, Alabama Ave Ruston, LA 71270

ID No: T0454

Device Type: Traction Elevator

Date: 11/7/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: JOE PEEL

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR				OK N G N/A			
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X		
1.2 Stop Switches	X			3.8 Top emergency exit	X		
1.3 Operating control devices	X			3.9 Floor and emergency identification numbering	X		
1.4 Sills and car floor	X			3.10 Hoistway construction	X		
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X		
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X		
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks	X		
1.8 Door closing force	X			3.14 Hoistway clearances	X		
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X		
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X		
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X		
1.12 Car enclosure	X			3.18 Car frame and stiles	X		
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X		
1.14 Ventilation	X			3.20 Governor rope	X		
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X		
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X		
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X		
1.18 Restricted opening of car or hoistway doors	X			3.27 Crosshead data plate and rope data tags	X		
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29 Counterweight safeties			X
2 MACHINE ROOM				3.30 Speed Test	X		
2.1 Access to machinery space	X			3.33 Compensating ropes and chains	X		
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels	X		
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment	X			4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal	X			4.10 Emergency doors in blind hoistways			X
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.15 Static control	X			5 PIT			
2.16 Overhead beam and fastenings	X			5.1 Pit access, lighting, stop switch & condition	X		
2.17 Drive machine brake	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.18 Traction-drive machines	X			5.3 Final and emergency terminal stopping devices	X		
2.19 Gears, bearings, and flexible couplings	X			5.4 Normal terminal stopping devices	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5 Traveling cables	X		
2.21 Belt- or chain-drive machine			X	5.6 Governor-rope tension devices	X		
2.22 Motor generator			X	5.7 Car frame and platform	X		
2.23 Absorption of regenerated power	X			5.8 Car and counterweight safeties and guiding members	X		
2.24 AC drives from a DC source	X			5.9 Buffers and emergency terminal speed-limiting devices	X		
2.25 Traction sheaves	X			5.10 Compensating chains, ropes & sheaves	X		
2.26 Secondary and deflector sheaves	X			5.12 Car buffers	X		
2.27 Rope fastenings	X			5.13 Guiding members [rails, rollers, slides]	X		
2.28 Terminal stopping devices	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.29 Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)			
2.40 Maintenance records	X			6.1 A17.1b-1973 through A17.1b-1980			X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.2 17.1-1981 through A17.1b-1983			X
3 TOP OF CAR				6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.1 Top-of-car stop switch	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.2 Car top light and outlet	X			6.5 A 17.1-2000/644-00			X
3.3 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
3.5 Normal terminal stopping devices	X			6.8 A17.1-2010/B44-10			X
3.6 Final and emergency terminal stopping devices	X			6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

Origin Bank Softball & Soccer
Complex
1300 Stadium Drive
Ruston, LA 71270

Location ID:

Location Contact Information:

Name:

Title:

Phone:

Email:

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0560

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 2:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 9/2/2021

Capacity: 2500

Inspection End Time: 3:00:00 PM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 2

Device Designation: #1 Softball

Device Manufacturer: Schindler

Speed: 100

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Origin Bank Softball & Soccer Complex, 1300 Stadium Drive Ruston, LA 71270

ID No: T0560

Device Type: Traction Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name:

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A		OK	NG	N/A
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X		
1.2 Stop Switches	X			3.8 Top emergency exit	X		
1.3 Operating control devices	X			3.9 Floor and emergency identification numbering	X		
1.4 Sills and car floor	X			3.10 Hoistway construction	X		
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X		
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X		
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks	X		
1.8 Door closing force	X			3.14 Hoistway clearances	X		
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways			X
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X		
1.11 Car vision panels and glass car doors			X	3.17 Door and gate equipment	X		
1.12 Car enclosure	X			3.18 Car frame and stiles	X		
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X		
1.14 Ventilation	X			3.20 Governor rope	X		
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X		
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X		
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X		
1.18 Restricted opening of car or hoistway doors	X			3.27 Crosshead data plate and rope data tags	X		
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29 Counterweight safeties			X
2 MACHINE ROOM				3.30 Speed Test	X		
2.1 Access to machinery space	X			3.33 Compensating ropes and chains	X		
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels			X
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment	X			4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal	X			4.10 Emergency doors in blind hoistways	X		
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.15 Static control	X			5 PIT			
2.16 Overhead beam and fastenings	X			5.1 Pit access, lighting, stop switch & condition	X		
2.17 Drive machine brake	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.18 Traction-drive machines	X			5.3 Final and emergency terminal stopping devices	X		
2.19 Gears, bearings, and flexible couplings	X			5.4 Normal terminal stopping devices	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5 Traveling cables	X		
2.21 Belt- or chain-drive machine			X	5.6 Governor-rope tension devices	X		
2.22 Motor generator			X	5.7 Car frame and platform	X		
2.23 Absorption of regenerated power			X	5.8 Car and counterweight safeties and guiding members	X		
2.24 AC drives from a DC source	X			5.9 Buffers and emergency terminal speed-limiting devices	X		
2.25 Traction sheaves	X			5.10 Compensating chains, ropes & sheaves	X		
2.26 Secondary and deflector sheaves	X			5.12 Car buffers	X		
2.27 Rope fastenings	X			5.13 Guiding members [rails, rollers, slides]	X		
2.28 Terminal stopping devices	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.29 Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)			
2.40 Maintenance records	X			6.1 A17.1b-1973 through A17.1b-1980			X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.2 17.1-1981 through A17.1b-1983			X
				6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
				6.4 A17.1b-1989 through A17.1d-2000			X
3 TOP OF CAR				6.5 A 17.1-2000/644-00			X
3.1 Top-of-car stop switch	X			6.6 A 17.1-2004/644-04			X
3.2 Car top light and outlet	X			6.7 A17.1-2007/B44-07			X
3.3 Top-of-car operating device	X			6.8 A17.1-2010/B44-10			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.9 A17.1-2013/B44-13			X
3.5 Normal terminal stopping devices	X						
3.6 Final and emergency terminal stopping devices	X						

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

JC Love Baseball Stadium
1111 W. Alabama
Ruston, LA 71270

Location ID:

Location Contact Information:

Name:

Title:

Phone:

Email:

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0561

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 3:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 9/2/2021

Capacity: 3500

Inspection End Time: 4:00:00 PM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: #1

Device Manufacturer: Schindler

Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: JC Love Baseball Stadium, 1111 W. Alabama Ruston, LA 71270

ID No: T0561

Device Type: Traction Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name:

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A		OK	NG	N/A
1.1 Door reopening device	X			3.7 Car leveling and anticreep devices	X		
1.2 Stop Switches	X			3.8 Top emergency exit	X		
1.3 Operating control devices	X			3.9 Floor and emergency identification numbering	X		
1.4 Sills and car floor	X			3.10 Hoistway construction	X		
1.5 Car lighting and receptacles	X			3.11 Hoistway smoke control	X		
1.6 Car emergency signal	X			3.12 Pipes, wiring, and ducts	X		
1.7 Car door or gate	X			3.13 Windows, projections, recesses, and setbacks			X
1.8 Door closing force	X			3.14 Hoistway clearances	X		
1.9 Power closing of doors or gates	X			3.15 Multiple hoistways	X		
1.10 Power opening of doors or gates	X			3.16 Traveling cables and junction boxes	X		
1.11 Car vision panels and glass car doors	X			3.17 Door and gate equipment	X		
1.12 Car enclosure	X			3.18 Car frame and stiles	X		
1.13 Emergency exit	X			3.19 Guide rails, fastenings, and equipment	X		
1.14 Ventilation	X			3.20 Governor rope	X		
1.15 Signs and operating device symbols	X			3.21 Governor releasing carrier	X		
1.16 Rated load, platform area, and data plate	X			3.22 Wire rope fastening and hitch plate	X		
1.17 Standby power operation	X			3.23 Suspension compensation and governor systems	X		
1.18 Restricted opening of car or hoistway doors	X			3.27 Crosshead data plate and rope data tags	X		
1.19 Car ride	X			3.28 Counterweight and counterweight buffer	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		3.29 Counterweight safeties			X
2 MACHINE ROOM				3.30 Speed Test	X		
2.1 Access to machinery space	X			3.33 Compensating ropes and chains	X		
2.2 Headroom	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.3 Lighting and receptacles	X			4 OUTSIDE HOISTWAY			
2.4 Machinery space	X			4.1 Car platform guard	X		
2.5 Housekeeping	X			4.2 Hoistway doors	X		
2.6 Ventilation	X			4.3 Vision panels	X		
2.7 Fire extinguisher	X			4.4 Hoistway door-locking devices	X		
2.8 Pipes, wiring, and ducts	X			4.5 Access to hoistway	X		
2.9 Guarding of exposed auxiliary equipment	X			4.6 Power closing of hoistway doors	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.7 Sequence operation	X		
2.11 Disconnecting means and control	X			4.8 Hoistway enclosure	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.9 Elevator parking devices	X		
2.13 Governor, overspeed switch, and seal	X			4.10 Emergency doors in blind hoistways	X		
2.14 Code data plate	X			4.12 Standby power selection switch	X		
2.15 Static control	X			5 PIT			
2.16 Overhead beam and fastenings	X			5.1 Pit access, lighting, stop switch & condition	X		
2.17 Drive machine brake	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.18 Traction-drive machines	X			5.3 Final and emergency terminal stopping devices	X		
2.19 Gears, bearings, and flexible couplings	X			5.4 Normal terminal stopping devices	X		
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening		X		5.5 Traveling cables	X		
2.21 Belt- or chain-drive machine		X		5.6 Governor-rope tension devices	X		
2.22 Motor generator		X		5.7 Car frame and platform	X		
2.23 Absorption of regenerated power		X		5.8 Car and counterweight safeties and guiding members	X		
2.24 AC drives from a DC source	X			5.9 Buffers and emergency terminal speed-limiting devices	X		
2.25 Traction sheaves	X			5.10 Compensating chains, ropes & sheaves	X		
2.26 Secondary and deflector sheaves	X			5.12 Car buffers	X		
2.27 Rope fastenings	X			5.13 Guiding members [rails, rollers, slides]	X		
2.28 Terminal stopping devices	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.29 Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)			
2.40 Maintenance records	X			6.1 A17.1b-1973 through A17.1b-1980			X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)		X		6.2 17.1-1981 through A17.1b-1983			X
3 TOP OF CAR				6.3 A17.1-1984 through A17.1a-1988 and A17.3			X
3.1 Top-of-car stop switch	X			6.4 A17.1b-1989 through A17.1d-2000			X
3.2 Car top light and outlet	X			6.5 A 17.1-2000/644-00			X
3.3 Top-of-car operating device	X			6.6 A 17.1-2004/644-04			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07			X
3.5 Normal terminal stopping devices	X			6.8 A17.1-2010/B44-10			X
3.6 Final and emergency terminal stopping devices	X			6.9 A17.1-2013/B44-13			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:

Schindler Elevator : Schindler Elevator : LA - Shreveport

Building Information:

Location Address:

JC Love Baseball Stadium
1111 W. Alabama
Ruston, LA 71270

Location ID:

Location Contact Information:

Name:
Title:
Phone:
Email:

Inspection Information:

Inspection Date: 11/6/2023

Inspector: Voiles, Jeff ||

Re-Inspection Required: No

Device ID: T0562

Due Month: November

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 4:00:00 PM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use: Passenger

Installation Date: 9/2/2021

Capacity: 2500

Inspection End Time: 5:00:00 PM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings: 3

Device Designation: # 2

Device Manufacturer: Schindler

Speed: 125

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: JC Love Baseball Stadium, 1111 W. Alabama Ruston, LA 71270

ID No: T0562

Device Type: Traction Elevator

Date: 11/6/2023

Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name:

Inspected By: Voiles, Jeff ||

Signature:

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

#	DESCRIPTION	OK	NG	N/A	#	DESCRIPTION	OK	NG	N/A					
1 INSIDE OF CAR					OKNGN/A					OKNGN/A				
1.1	Door reopening device	X			3.7	Car leveling and anticreep devices	X							
1.2	Stop Switches	X			3.8	Top emergency exit	X							
1.3	Operating control devices	X			3.9	Floor and emergency identification numbering	X							
1.4	Sills and car floor	X			3.10	Hoistway construction	X							
1.5	Car lighting and receptacles	X			3.11	Hoistway smoke control	X							
1.6	Car emergency signal	X			3.12	Pipes, wiring, and ducts	X							
1.7	Car door or gate	X			3.13	Windows, projections, recesses, and setbacks			X					
1.8	Door closing force	X			3.14	Hoistway clearances	X							
1.9	Power closing of doors or gates	X			3.15	Multiple hoistways	X							
1.10	Power opening of doors or gates	X			3.16	Traveling cables and junction boxes	X							
1.11	Car vision panels and glass car doors			X	3.17	Door and gate equipment	X							
1.12	Car enclosure	X			3.18	Car frame and stiles	X							
1.13	Emergency exit	X			3.19	Guide rails, fastenings, and equipment	X							
1.14	Ventilation	X			3.20	Governor rope	X							
1.15	Signs and operating device symbols	X			3.21	Governor releasing carrier	X							
1.16	Rated load, platform area, and data plate	X			3.22	Wire rope fastening and hitch plate	X							
1.17	Standby power operation	X			3.23	Suspension compensation and governor systems	X							
1.18	Restricted opening of car or hoistway doors	X			3.27	Crosshead data plate and rope data tags	X							
1.19	Car ride	X			3.28	Counterweight and counterweight buffer	X							
1.20	Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.29	Counterweight safeties			X					
2 MACHINE ROOM					3.30 Speed Test					X				
2.1	Access to machinery space	X			3.33	Compensating ropes and chains	X							
2.2	Headroom	X			3.34	Earthquake inspection and tests (seismic risk zone 2 or greater)			X					
2.3	Lighting and receptacles	X			4 OUTSIDE HOISTWAY									
2.4	Machinery space	X			4.1	Car platform guard	X							
2.5	Housekeeping	X			4.2	Hoistway doors	X							
2.6	Ventilation	X			4.3	Vision panels			X					
2.7	Fire extinguisher	X			4.4	Hoistway door-locking devices	X							
2.8	Pipes, wiring, and ducts	X			4.5	Access to hoistway	X							
2.9	Guarding of exposed auxiliary equipment	X			4.6	Power closing of hoistway doors	X							
2.10	Numbering of elevators, machines, controllers & disconnect switches	X			4.7	Sequence operation	X							
2.11	Disconnecting means and control	X			4.8	Hoistway enclosure	X							
2.12	Controller wiring, fuses, grounding, etc.	X			4.9	Elevator parking devices			X					
2.13	Governor, overspeed switch, and seal	X			4.10	Emergency doors in blind hoistways	X							
2.14	Code data plate	X			4.12	Standby power selection switch	X							
2.15	Static control	X			5 PIT									
2.16	Overhead beam and fastenings	X			5.1	Pit access, lighting, stop switch & condition	X							
2.17	Drive machine brake	X			5.2	Bottom clearance, runby & minimum refuge space	X							
2.18	Traction-drive machines	X			5.3	Final and emergency terminal stopping devices	X							
2.19	Gears, bearings, and flexible couplings	X			5.4	Normal terminal stopping devices	X							
2.20	Winding drum machine & slack rope device, stop-motion switch, & rope fastening			X	5.5	Traveling cables	X							
2.21	Belt- or chain-drive machine			X	5.6	Governor-rope tension devices	X							
2.22	Motor generator			X	5.7	Car frame and platform			X					
2.23	Absorption of regenerated power			X	5.8	Car and counterweight safeties and guiding members	X							
2.24	AC drives from a DC source	X			5.9	Buffers and emergency terminal speed-limiting devices	X							
2.25	Traction sheaves	X			5.10	Compensating chains, ropes & sheaves			X					
2.26	Secondary and deflector sheaves	X			5.12	Car buffers	X							
2.27	Rope fastenings	X			5.13	Guiding members [rails, rollers, slides]	X							
2.28	Terminal stopping devices	X			5.16	Earthquake inspection and tests (seismic risk zone 2 or greater)			X					
2.29	Car and counterweight safeties	X			6 FIREFIGHTERS' SERVICE (FEO)									
2.40	Maintenance records	X			6.1	A17.1b-1973 through A17.1b-1980			X					
2.42	Earthquake inspection and tests (seismic risk zone 2 or greater)			X	6.2	17.1-1981 through A17.1b-1983			X					
3 TOP OF CAR					6.3	A17.1-1984 through A17.1a-1988 and A17.3			X					
3.1	Top-of-car stop switch	X			6.4	A17.1b-1989 through A17.1d-2000			X					
3.2	Car top light and outlet	X			6.5	A 17.1-2000/644-00			X					
3.3	Top-of-car operating device	X			6.6	A 17.1-2004/644-04			X					
3.4	Top-of-car clearance, refuge space, and standard railing	X			6.7	A17.1-2007/B44-07			X					
3.5	Normal terminal stopping devices	X			6.8	A17.1-2010/B44-10			X					
3.6	Final and emergency terminal stopping devices	X			6.9	A17.1-2013/B44-13			X					