



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

July 12, 2024

ADDENDUM # 1

Bid Number: 50-00145650

Bid Opening Date: August 01, 2024 at 2:00 pm cst

Furnish Labor, Materials and Equipment to Supply and Install One (1) New Pre-Engineered Building for the Jefferson Parish Training Center for the Jefferson Parish Department of Fire Services

CLARIFICATION:

QUESTION: What is the size of the windows and where they are located?

ANSWER: The size of the windows is 3' x 3' with horizontal slide, standard glass mill finish and 1/1 window pane arrangement located on the north and south walls.

QUESTION: What is the size of the framed opening for the roll up door?

ANSWER: The rollup door is 10 x 8 on the west wall.

QUESTION: Is there an existing slab already and do we need to use drill and pin anchor bolts or are we going to have to modify the slab and pour new concrete with concrete placed anchor bolts?

ANSWER: You will need to do a Site visit.

QUESTION: Are we tying into an existing building?

ANSWER: No.

QUESTION: Do you have any drawings? Based off Section 7.3 left end wall is mentioned twice with two Different bay sides/

ANSWER: No drawings. Per the department the left end wall being mentioned twice can be discussed At the Site visit.

JOSEPH S. YENNI BUILDING - 1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242
OFFICE 504.364-2678

GENERAL GOVERNMENT BUILDING - 200 DERBIGNY ST - SUITE 4400 - GRETNA, LA 70053 - PO BOX 9 - GRETNA - LA 70054
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.NET

WEBSITE: WWW.JEFFPARISH.NET



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

Sincerely,

Donna M. Evans
Purchasing Specialist II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.