



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

August 26, 2024

Please find the following addendum to the below mentioned BID.

Addendum No.: 2

Bid#: 24-32-2

Project Name: River Oaks New Elevated Water Tower

Bid Due Date: September 4, 2024

Receipt of this addendum shall be acknowledged by inserting its number and date in the space provided on the Proposal.

DRAWINGS:

1. Drawing Sheet 12:
 - a. **Add** the following note: “3. Tank Signage/ lettering is required for either the pedestal style tank or the multi-column style tank. “

SPECIFICATIONS

1. Section 15120.
 - a. **Add:** the following to Para 1.1.A: “A mixer is required for the Pedestal style tank and the Multi-column style tank.”

QUESTIONS AND ANSWERS

1. Question: When do you anticipate the demo of Tank B to be available for demo?
Answer: Tank B is available for removal to a site designated by the Owner following the issuance of the Notice to Proceed. The removal of the Tank can commence immediately following mobilization to the site. Valves must be operated by DU personnel.

<< End of Addendum 2 >>