



ST. TAMMANY PARISH

MICHAEL B. COOPER
PARISH PRESIDENT

August 8, 2024

Please find the following addendum to the below mentioned BID.

Addendum No.: 4

Bid # 24-29-2

Project Name: Davis Canal Restoration

Bid Due Date: Tuesday, August 13, 2024

GENERAL INFORMATION:

Receipt of this addendum shall be acknowledged by inserting its number in the space provided on the proposal.

QUESTIONS & ANSWERS:

Question 1. The C12x20.7 you have listed in Addendum 3 will not fit over the PZ-40 sheet pile you have specified.

Answer 1. MC18x42.7 or welded 1/2" steel plate shall be used in lieu of c12x20.7 for sheet pile cap.

<< End of Addendum #4 >>