August 9, 2024

Please find the following addendum to the below-mentioned QUOTE.

Addendum No.: 1

Quote#: 24-34-1

Project Name: Lenel Rd Drainage

Quote Due Date: Wednesday, August 14, 2024

QUESTIONS & ANSWERS:

Question 1: Can you please provide more information about the layout of the work required

for this bid? Any survey information, sketches, etc.

Answer 1: There is no sketch or survey info. CB-01s will be added to existing cross culvert

with stub outs and deep patching to widen the turn radius. All elevations of CB-

01s and flow lines of pipe will be field fit to keep positive drainage.

End of Addendum #1