



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

**August 21, 2024**

Please find the following addendum to the below mentioned BID.

**Addendum No.: 1**

**Bid#: 24-36-2**

**Project Name: US 190 E. Water Main, Vadia Ln., Woodview Dr.**

**Bid Due Date: 2:00 p.m. on Wednesday, August 28, 2024**

**Receipt of this addendum shall be acknowledged by inserting its number in the space provided on the Proposal.**

### **GENERAL INFORMATION & REVISIONS:**

---

- General: Bid date and time remains as advertised; **2:00 p.m., on Wednesday, August 28, 2024**
- Drawings: "Sheet C-228 – PLAN & PROFILE STA 190+00 TO STA 195+00"; **REVISED 2" P.E. WL to be 3" P.E. WL in Profile.**
- Drawings: "Sheet C-401 – CONNECTION DETAILS"; **REVISED "10" DI Spool Piece" and "8"x8"x10" Tee" to be "8" DI Spool Piece" and "8"x8"x8" Tee" respectfully.**

### **QUESTIONS & ANSWERS:**

---

- 1) Question: There is a long lead time on brass tap-in saddles for waterline. Is there an Approved equal?

**Answer: The use of stainless service saddles (Models CSC and CS) from Cascade (or approved equal) for service line taps on HDPE pipe is an acceptable alternative.**



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

2) Question: What is the Engineer's Estimate?

**Answer: \$2,860,811.00**

### ATTACHMENTS:

---

1) Pre-Bid Meeting Agenda and Sign-in Sheet

**<< End of Addendum #1 >>**

