



JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR

August 16, 2024

ADDENDUM # 2

Bid Number: 50-00145704

Bid Opening Date: August 22, 2024 AT 2:00 PM

Description of Bid: Purchase of Stationary Emergency Standby Flood Control Pump for the Jefferson Parish Department of Drainage.

REVISION:

- Remove Page 4 of Specifications in its entirety and replace with the attached Revised Specifications Page 4.

Per the revision below:

MOUNTING

The pump and engine shall be mounted on a structural steel skid chassis shall be fitted with a lifting bale, no fork pockets required.

*****PLEASE REMEMBER TO ACKNOWLEDGE THIS ADDENDUM BY NUMBER ON YOUR BID SUBMISSION****

Sincerely,

A handwritten signature in blue ink, appearing to read "Ruby Tran", with a long horizontal flourish extending to the right.

**Ruby Tran, Purchasing Specialist II
Jefferson Parish Purchasing Department**

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

JOSEPH S. YENNI BUILDING - 1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242
OFFICE 504.364-2678

GENERAL GOVERNMENT BUILDING - 200 DERBIGNY ST - SUITE 4400 - GRETNA, LA 70053 - PO BOX 9 - GRETNA - LA 70054
OFFICE 504.364.2678

EMAIL: PURCHASING@JEFFPARISH.GOV

WEBSITE: WWW.JEFFPARISH.GOV

- g) Engine shall have safety shutdown switches for low oil pressure and high temperature.
- h) An instrument panel shall be provided in an enclosure and mounted on rubber isolators
- i) FUEL SOURCE: No fuel source is required on skid but vendor shall have fuel source for testing purposes only.

MOUNTING

The pump and engine shall be mounted on a structural steel skid chassis shall be fitted with a lifting bale, no fork pockets required.

COATING

The complete pump assembly shall be prepared inside and outside using standards SSPC-SP10 / (Near-White Blast cleaning) and painted with a high build epoxy primer/finish, polyurethane or equal, to a dry film thickness of 8.0 mils. Sherwin Williams Macropoxy 646 with Sherwin Williams Acrolon 218 HS or equal.

SPARE PARTS

In addition to the factory installed filters for the diesel drive unit, the vendor shall provide one complete set (when applicable) of spare oil filters, fuel filters, air filters with pre-filters, and water filters.

In addition to the oil required to fill the engine, the contractor shall provide enough oil for one complete oil change of specified lube oil.

The vendor shall furnish one wafer style 12" dual disc check valve shipped loose.

WARRANTY

The vendor shall furnish to the owner the manufacturer's one-year parts and labor warranty covering all parts and components and shall assign the engine and other component manufacturers' warranties.

DELIVERY

The work under this contract shall consist of providing the pump package specified herein with seventy (70) calendar days from receipt of the purchase order. Vendor shall notify Drainage Department two (2) weeks prior to delivery which shall be received at the Ames pump station warehouse at 5100 Rochester Drive, Marrero Louisiana. Any and all freight charges are to be included in bid price.