

The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET NEW ORLEANS, LA 70165 504.529.2837 OR 52.WATER

www.swbno.org

August 19, 2024

Addendum No. 2

Your reference is directed to the Invitation to Bid for: <u>2024-SWB-34 (30265) Portable</u> <u>Generators</u> for the Sewerage and Water Board of New Orleans which proposals are due on **August 23, 2024,** at **11:00 a.m.** CST.

This addendum provides for the following:

- a) Revision to Bid due date and opening date.
- b) Responses to Questions

Revision to Bid Due date and Opening Date

- a. Extended bid due date: August 27, 2024, at 11:00 a.m.
- b. Extended Bid Opening Date and Time: August 27, 2024, at 11:30 a.m.

Responses to Questions

1. Question from vendor:

Will a Purchase Order be issued for the entire seventeen (17) Trailer Mounted Generators? Or will separate purchase orders be issued at different times throughout the contract period as outlined on Page 9 of the solicitation, {one (1) Year Period)}.?

Answer: There will be one P.O. for the entire project. As lead times may differ, individual generators may be invoiced upon delivery.

2. Question from vendor:

Are all seventeen (17) units going to shipped to the same location? And what is the shipping location?

Answer: Ship all generators to: 2901 Eads St.
NOLA 70122

3. On Board Load Bank-is this to prevent wet stacking? Will a Load Management System be sufficient to address the requirement of a Load Bank on each unit?

Answer: On Board Load Banks is for wet stacking and a Load Management System is acceptable and preferred.

4. Question from Vendor:

a. What are the generators running? Pumps? Is the service Prime Power or Standby Power?

Answer: Generators will be backup power for sewer pumping stations. The specifications are based on Standby Power.

5. Question from Vendor:

a. Do you want Cam-Locks or Lugs for connections?

Answer: Lugs.

6. Question from Vendor:

a. Is there a need for a positive air shut down?

Answer: Yes, assure each generator is equipped with a positive air shut down.

7. Question from Vendor:

Do the Generators need to be load-banked on site or can the factory complete the load-Bank test at the factory prior to shipping, then provide all the test results at the time of shipments.

Answer: Load Bank testing can be performed at the factory with result supplied upon shipment.

8. Question from Vendor:

- a. Pg. 10, Paragraph IV-1: Provide Low Oil Alarm-Clarify required so we understand exactly what is needed to provide.
- b. Does this requirement refer to:
 - Low Oil Pressure with engine shutdown & alarm indication
 - Low Oil level indication & alarm

Answer: Please assure generators are equipped with low oil pressure alarm with engine shutdown or low oil level alarm with engine shutdown.

9. Pg. 10, Paragraph IV-4: Please advise type of trailer coupler required. I assume it to be a Pintle Coupler but am requestion clarification.

Answer: Trailer coupler type shall be Pintle.

