



The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165
504.529.2837 OR 52.WATER
www.swbno.org

August 19, 2024

Addendum No. 3

Your reference is directed to the Invitation to Bid for: **2024-SWB-34 (30265) Portable Generators** for the Sewerage and Water Board of New Orleans which proposals are due on **August 23, 2024**, at **11:00 a.m.** CST.

This addendum provides for the following:

a) Responses to Questions

Responses to Questions

1. Question from vendor:

- a. Fuel tank UL-142 - This is a self-contained fuel tank that is not available on portable trailer mounted generators.

Answer: Assure tank is double walled and includes 100% spill containment.

Question from vendor:

- b. 100% load bank mounted on the generator/trailer. This is unrealistic, incredibly expensive and kind of a waste of money (in my opinion)

Answer: On board load bank system shall consist of an onboard integrated Load Management system manufactured by the generator's manufacturer. 100% load bank is not necessary.

- c. On Board Load Bank-is this to prevent wet stacking? Will a Load Management System be sufficient to address the requirement of a Load Bank on each unit?

Answer: On Board Load Banks is for wet stacking and a Load Management System is acceptable and preferred.

The changes, additions, and/or deletions included herein are hereby made part of the solicitation documents for 2024-SWB-34 (30265) Portable Generators, as fully and completely as if the same were set forth therein. The bidder shall be responsible for having knowledge of all addenda issued for this ITB.

This addendum consists of one (1) page.

***** END OF ADDENDUM *****