

JEFFERSON PARISH

DEPARTMENT OF PURCHASING

RENNY SIMNO DIRECTOR

September 16, 2024

ADDENDUM #2

Bid Number: 50-00145907 Bid Due Date: September 19, 2024

Three (3) Year Contract to Provide Elevator Maintenance Services for the Jefferson Parish Department of General Services

Q & A:

<u>Question</u> - According to the Cat 1, 3, and 5 tests and other equipment test are required, according to ASME A17.1, to be inspected by a state licensed and QEI licensed inspector. **Answer** - Yes

<u>Question</u> - In the Paragraph, "perform periodic inspections and tests per the more stringent requirements of ASME A17.1 or the AHJ". This also needs to be performed by a state licensed and QEI licensed inspector **Answer** - We are abiding to the requirements of ASME A17.1 and the AHJ.

<u>Questions</u> - In the Paragraph, "all the periodic inspections and tests are required, by Jefferson Parish Mechanical Inspection Department, to be performed by a third-party licensed inspector". There is no mention of obsolescent parts, etc. I recommend this to be addressed.

<u>Answer</u> - If a part is obsolete, it will be verified by Jefferson Parish and the labor portion of the contract can be utilized.

***PLEASE REMEMBER TO ACKNOWLEDGE THIS ADDENDUM BY NUMBER ON YOUR BID SUBMISSION**

Sincerely,

Ruby Tran, Purchasing Specialist II

Jefferson Parish Purchasing Department

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

JOSEPH S. YENNI BUILDING-1221 ELMWOOD PARK BLVD - SUITE 404 - JEFFERSON, LA 70123 - PO BOX 10242 JEFFERSON, LA 70181-0242 OFFICE 504.364-2678