



The Sewerage & Water Board OF NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165
504.529.2837 OR 52.WATER
www.swbno.org

October 10, 2024
Addendum No. 2

Your reference is directed to the Invitation to Bid for: **2024-SWB-78 Bearing Repairs** for the Sewerage and Water Board of New Orleans which proposals are due **October 17, 2024**, at **11:00 a.m.** CST.

This addendum provides for the following:

1. Responses to Questions

a. *Is anything to be done with the anti-vortex plates in the pit attached to the pump and the wall?*

- *There should be no anti-vortex plates on this pump, as seen in the drawings with the bid package and observed when an identical pump at the station was recently removed for repair. The scope does not include any work related to anti0vortex plates.*

b. *Are the stop logs currently installed?*

- *Stop logs are available at DPS 14 but are not currently installed. Contractor shall install the stop logs and remove them after the work is completed.*

The changes, additions, and/or deletions included herein are hereby made part of the solicitation documents for 2024-SWB-78 Bearing Repairs, as fully and completely as if the same were set forth therein. The bidder shall be responsible for having knowledge of all addenda issued for this ITB.

This addendum consists of one (1) page.

***** END OF ADDENDUM *****