



MARRERO, COUVILLON AND ASSOCIATES, LLC

2644 S. Sherwood Forest Blvd., Suite 200, Baton Rouge, Louisiana 70816
Ph: (225) 408-8249 Fax: (225) 408-8244

Boiler Replacement @ Katherine Johnson School
Orleans Parish Schools Project # ITB 24-FAC-0016, MCA Project Number OPS 23031.801
October 22, 2024

Addendum No. 2

This Addendum, applicable to work designated herein below shall be understood to be an Addendum and as such shall be included in the "Contract Documents".

Following are the changes, amendments, deletions or additions to components of the "Request for Contractor Services" as now written or drawn. All provisions of General Conditions of the Contract for Construction, Supplementary Conditions, and other pertinent portions of the Specifications and Drawings shall apply to this Addendum.

GENERAL:

1. Disregard the previous Addendum #2 distributed on 2024.10.21.
2. This project shall be Tax Exempt.
3. The bid opening for this project shall be rescheduled to 2:00 pm Central Time on Thursday, October 31, 2024.

SPECIFICATIONS:

1. No changes as part of this addendum.

PLANS:

1. No changes as part of this addendum

PRIOR APPROVALS:

1. No prior approvals have been submitted to date.

Bid Clarification Questions:

1. "Drawing p201 - In the diagram it shows a thermal expansion tank. I have not see any cut sheet or anything in the specs nor the equipment schedule on this tank. At the site visit there was no expansion tank anywhere to be seen."

Response:

Please reference specification 223300 – Electric, Domestic-Water Heaters and provide a compression tank that meets the specifications noted in section 2.2.A.

END OF ADDENDUM