

**CITY OF BATON ROUGE  
PARISH OF EAST BATON ROUGE**

October 28, 2024

**ADDENDUM NO. 1**

**TO: ALL BIDDERS**

**SUBJECT: HIDDEN BIKE PATH  
(COLLEGE DRIVE TO COUNTRY CLUB DRIVE)  
(CITY PARISH PROJECT NO. 20-EN-HC-0030)**

**REVISED BID DATE: THURSDAY, NOVEMBER 14, 2024  
BID TIME: 2:00 P.M.**

**ORIGINAL BID DATE: TUESDAY, OCTOBER 29, 2024  
BID TIME: 2:00 P.M.**

The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract documents.

**REVISED BID OPENING DATE:**

The bid opening date is hereby postponed/extended ten (12) working days. **Bids will be opened at 2:00 p.m. THURSDAY, NOVEMBER 14, 2024**, in lieu of TUESDAY, OCTOBER 29, 2024.

**CONSTRUCTION BID FORM:**

1. For paper, sealed and electronic bidders, with reference to page UCBF 1 of 4 of Part 1, Uniform Construction Bid Forms, the Bidder shall indicate receipt of this Addendum in the space provided. Failure to indicate receipt of this addendum shall be cause for the bid to be rejected.
2. Replace Unit Price Form with the attached Revised Unit Price Form (dated 10-08-2024). This revised Unit Price Form **MUST** be used by all Bidders for this project. Failure to submit on the revised Unit Price Form shall be cause for the bid to be rejected.

**PART 2-SPECIAL PROVISIONS AND CONTRACT DOCUMENTS:**

**SECTION 9900071 REMOVAL OF BOLLARDS**

**Add the following Section to the Special Provisions in its entirety:**

**9900071 REMOVAL OF BOLLARDS**

**DESCRIPTION:** This work consists of removal and disposal of bollards within the area of work as identified on the plans or as instructed by the Engineer. It shall also include salvaging designated materials and backfilling resulting trenches and holes.

**CONSTRUCTION:** The contractor shall remove and dispose of all materials as identified in the plans or by the Engineer. Designated salvageable materials shall remain the property of the City-Parish and shall be removed, without unnecessary damage, in sections which may be readily transported and shall be hauled to a designated

maintenance storage yard and stacked. Materials not to be salvaged shall be disposed of off the project. Cavities left by bollard removal shall be filled to the level of the surrounding ground and compacted to at least the density of the surrounding ground.

Operations necessary for removal which may damage new construction shall be completed prior to placing the new work.

**MEASUREMENT:** When the contract stipulates that payment will be made for removal on a unit basis, measurement will be made by the unit stipulated in the contract.

**PAYMENT:** Payment includes removal, disposal, salvage (when specified), and excavation and backfill incidental to the removal.

**PAY ITEMS:**

<u>Item No.</u>	<u>Pay Item</u>	<u>Unit</u>
9900071	Removal of Bollards	EACH

**DRAWINGS:**

1. Delete Sheets 2 and 7 and replace with Revised Sheets 2 and 7.

**QUESTIONS & CLARIFICATIONS:**

1. Has there been a engineers estimate made for this project as no estimate is listed in plans or specifications?  
**An Engineer's Opinion of Probable Cost has been made but will not be made available to bidders until after bid opening.**
2. Plan Sheet pg. 2 under trail rehab notes, note 1 states, "The existing trail shall be overlaid with 2" of asphalt pavement" factoring the total length of the trail 200 tons will be needed to overlay 2" of asphalt pavement. Will pay summary of estimated quantities be changed to match?  
**The relative notes on Sheet 2 apply to the specific type of reconstruction, repair, or rehab work. The specific location of these types of work are delineated on the plan sheets. Only the sections identified as "Trail Rehab" (Example: Sta 16+30 to 16+75), or as otherwise directed by the Project Engineer, shall require a 2" overlay. The intent is NOT to overlay the entire path with 2" of asphalt.**
3. Plan Sheet 7 detail 12 for bollard removal detail shows to remove a max of 2' paved surface around post up to 1' in depth. Does this removal of replacement need to be included in the "removal of bollards"-9900071 pay item or "provide and install wooden bollards"-99000070 pay item?  
**All work incidental to the removal of existing bollards as shown in the detail and in the specifications, or as otherwise identified as necessary for the completion of the work by the contractor, to be included in the unit price for item 900071 – Removal of Bollards.**
4. Is there any updated plan holders/bidders list?
  - a. **An electronic plan holder list can be obtained with a subscription to Central Bidding. A physical plan holder list can be obtained by contacting the City-Parish DTD at 1100 Laurel St. per the Advertisement.**

**APPROVED:**

\_\_\_\_\_  
Thomas Stephens, P.E.  
Chief Design & Construction Engineer