



Purchasing Office

P.O. Box 2052 | Thibodaux, LA 70310 | 985.448.4038 | 985.448.4921 [F]

**ADDENDUM NO 3
FOR
NICHOLLS STATE UNIVERSITY
THIBODAUX, LOUISIANA
01/16/2025**

PAGE 1 OF 2

Bid SB01895 – SB01895 NSU Didier Field Public Restroom Project

Bid Responses are Due at 3:00 PM on 01/21/2025

This addendum is hereby made a part of the Bidding Documents to the extent as though it was originally included therein.

This addendum, must be acknowledged on the Louisiana Public Works Bid Form

Purpose of Addendum:

1. Provide sheet from designer regarding prior approvals. That sheet follows this page. Designer document
2. Provide Central Bidding Clarification – Central Bidding states their site is closed for bids regarding this project. That is because the University is Using the Central Bidding Site as a plan room and the bids are to be de
3. Provide answers to additional questions received from release date of Addendum No. 2 to the date of this addendum.

All addenda may be obtained through LaPac, Central Bidding, and the following link.

<https://www.nicholls.edu/purchasing/>

Copy the following link to a browser:

https://www.dropbox.com/scl/fo/vh45owudqszmg5unv5zz/AleLTpXDgz6wsW3MhOxD_nA?rlkey=n9djrf90buck3jspnx42wsnot&st=ebhdxyr1&dl=0

- Q: Due to the limited number of timber piles in this project, would it be acceptable to vibrate in the piles? This would significantly reduce installation costs.
- A: Badaux Engineers Response: Pile installation should be bid as specified. Installation by vibration would require a geotechnical evaluation. If desired, an evaluation could be performed after the bid so that the associated credit could be reviewed along with any added costs due to potential lower pile capacities, increased pile lengths, etc.
- Q: I'm trying to reach out to someone with Nicholls. There are several questions that fall into play with being able to quote. Will they be removing the old meter / relocating the meter or will this be a new service? Are they wanting a larger size meter? Hopefully they can provide some insight or if you know these answers would be helpful.
- A: WHLC Response: Per note on sheet C-4 Utility Plan, the new water meter, service line, and main line tap are to be installed by the City of Thibodaux. The size of the new meter is to be determined by the City. The contractor/plumber is responsible for all plumbing infrastructure from the water meter to fixtures.

Terry G. Dupre
Director of Purchasing, Property Control
and Support Services Administration

ADDENDUM NO. 3
January 16, 2025

Issued by designer

PROJECT: NSU Didier Field Public Restrooms
331 Colonel Drive
Thibodaux, LA 70310
WHLC PROJECT No. 23-008A

ARCHITECT: Washer Hill Lipscomb Cabaniss Architecture (LA) LLC, WHLC Architecture
1744 Oakdale Drive
Baton Rouge, LA 70810

Incorporate in the plans and the project manual the following additions, deletions, changes and clarifications. Each item shall be governed by the conditions set forth in Division 1 General Requirements of this Project Manual and the specific conditions set forth in the sections of the specifications pertaining to the item:

ADDENDUM NO. 3

Total Pages: 1- (8 1/2" x 11") including Title Sheet

PRIOR APPROVALS

- A. This addendum article is concerned solely with substitution of items of materials, products, and equipment prior to submittal of Bid Proposal as provided for in the Instructions to Bidders. No other items shall be substituted or bid.
- B. Items allowed by this Prior Approval are subject to full compliance with the provisions of original Contract Documents including all modifications thereto, and shall be warranted as substitutions conforming to Contract Documents requirements. Prior approval shall in no way relieve the Bidder from providing materials and workmanship in accordance with the intent of original Contract Documents.
- C. Approvals are based on the opinion, knowledge, information, and belief of Architect at time of issuance of this Addendum and reliance upon data submitted. Approval is interim in nature and subject to reconsideration as additional data, materials, workmanship, and coordination with other work are observed and reviewed. In proposing items and manufactures allowed by this Addendum, Bidder assumes all risks, costs, and responsibility for final acceptance, integration into the work, and performance.
- D. The following manufacturers are Prior-approved for items listed:

<u>ITEM</u>	<u>MANUFACTURER</u>
Section 10 28 00 Toilet, Bath, and Laundry Accessories	BabyMedi

END OF ADDENDUM 3