



1/30/2025

Addendum # 1 to Bid 002873

This document must be signed and included with bid submission

Signature: _____

Change the above referenced Invitation to Bid to agree with this addendum.

1. The spec indicates the use of 3 NVX-360 in the lectern, the parts list only calls for 2. Please clarify.
A. Please replace one of the DM-NVX-360 units with a DM-NVX-384. The 384 will be in the lectern for the HDMI inputs and its loop out will be used for the Mediasite content feed. The 360 will be installed near the projector to feed it video and control.
2. What is the purpose of the E30 and D30 units. These are not described in the spec narrative.
A. These units are not required; please remove them from the bid.
3. Please describe the connectivity of the Hover doc cam.
A. It will be connected to the AIO Lectern PC via USB.
4. Please confirm network cabling be provide to the TC2 Mic.
A. There will be two network jacks pulled to the TC2, one for Dante audio and the other for power and control.
5. Please clarify, is the system to have two pair of JBL LCT81 C/T (total of 4 speakers) or simply a total of two speakers
A. There is just one pair, two speakers total.
6. Please describe connectivity of the occupancy sensor and will cable be owner provided?
A. There will be a single network connection with PoE.

Patrick Defourneaux
Procurement Analyst, LSU Health Sciences Center
433 Bolivar St. 6th Floor, New Orleans, LA 70112
Office phone: 504-568-2947
Email: pdefou@lsuhsc.edu

