



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

**May 19, 2025**

Please find the following addendum to the below mentioned RFP.

**Addendum No.: 1**

**RFP#: 25-3-3**

**Project Name: Large Lift Station Cleaning**

**RFP Due Date: Thursday, May 22, 2025**

### **QUESTIONS & ANSWERS:**

---

**Question 1:** Is the disposal of the sludge able to be disposed of at a Parish facility to include Cross Gates WWTP?

**Answer 1:** The disposal of sludge is to be hauled to an off-site facility not operated by St. Tammany Parish Department of Utilities due to the amount of oil and grease.

**End of Addendum #1**