

**CITY OF BATON ROUGE
PARISH OF EAST BATON ROUGE**

May 30, 2025

ADDENDUM NO. 3

TO: ALL BIDDERS

**SUBJECT: S SHERWOOD FOREST (Coursey Blvd. – I-12) SIDEWALKS PROJECT
CITY-PARISH PROJECT NO. 20-EN-HC-0026**

REVISED BID DATE: Thursday, June 19, 2025 at 2:00 P.M.


ORIGINAL BID DATE: Tuesday June 3, 2025 at 2:00 P.M.

The following revisions shall be incorporated in and take precedence over any conflicting part of the original contract documents.

REQUESTS FOR INFORMATION AND RESPONSES

As of May 29, 2025 the following requests for information (RFI) were received and are answered, as follows:

1. In accordance with Louisiana Revised Statute 38:2212 the bid opening date must be extended as the issuance of attached Addenda # 2 for the above referenced project is less than 72 hours of the public bid opening date and time. As can be seen below the issuance of Addenda # 2 was not issued until 5/29/25 at 3:30:03 P.M., and not uploaded onto Central Auction House until 5/29/25 at 3:28:58 P.M.
 - Bid open date has been revised and extended accordingly.
2. Also, previously submitted RFI (# 8- There is a line item for adjusting valve boxes but the plans say water valves to be adjusted by BR water. Is the contractor making the adjustment or BR?) in the attached email correspondence and also noted below was not answered in Addenda # 2. Please advise.
 - Adjusting water valves are to be coordinated and adjusted by BR Water. The Pay Item Number 1112100 - Adjusting Valve Boxes does not include this quantity.


George Chike, P.E.
Project Manager