



**Bid Number 50-00147735**

**Two (2) Year Contract for Electric Motor Repairs for the Jefferson Parish Department of Public Works- Sewerage and all Jefferson Parish Agencies and Municipalities**

**June 17, 2025 at 2:00 pm**

**ATTENTION VENDORS!!!**

**Please review all pages and respond accordingly, complying with all provisions in the technical specifications and Jefferson Parish Instructions for Bidders and General Terms and Conditions. All bids must be received on the Purchasing Department's eProcurement site by the bid due date and time.**

**Jefferson Parish Purchasing Department  
200 Derbigny Street  
General Government Building, Suite 4400  
Gretna, LA 70053  
Buyer Name: Donna M Evans, Buyer II  
Buyer Email: [DONNA.EVANS@jeffparish.gov](mailto:DONNA.EVANS@jeffparish.gov)  
Buyer Phone: 504-364-2691**

INVITATION TO BID  
THIS IS NOT AN ORDER

**JEFFERSON PARISH**

PURCHASING DEPARTMENT  
P.O. BOX 9  
GRETNA, LA. 70054-0009  
504-364-2678

PURCHASING SPECIALIST:  
DMEVANS@jeffparish.net

**BIDS WILL BE RECEIVED ONLINE VIA [WWW.JEFFPARISHBIDS.NET](http://WWW.JEFFPARISHBIDS.NET) UNTIL 2:00 PM, 6/17/2025 AND PUBLICLY OPENED THEREAFTER IN THE WEST BANK PURCHASING DEPT, SUITE 4400, JEFFERSON PARISH GENERAL GOVERNMENT BUILDING, 200 DERBIGNY STREET, GRETNA, LA 70053. At no charge, bidders are to submit via Jefferson Parish's electronic procurement page by visiting [www.jeffparishbids.net](http://www.jeffparishbids.net) to register for this free site. Additional instructions are included in the text box highlighting electronic procurement.**

**LATE BIDS WILL NOT BE ACCEPTED**

**NOTE: ONLY BIDS WRITTEN IN INK OR TYPEWRITTEN, AND PROPERLY SIGNED BY A MEMBER OF THE FIRM OR AUTHORIZED REPRESENTATIVE, WILL BE ACCEPTED. PENCIL AND/OR PHOTOSTATIC FIGURES OR SIGNATURES SHALL RESULT IN BID REJECTION. HOWEVER, ELECTRONIC SIGNATURES AS DEFINED IN LSA - R.S. 9:2620(8) ARE ACCEPTABLE. SIGNATURE MUST BE A SECURED DIGITAL SIGNATURE AND MUST PROVIDE PROOF OF THE SECURED SIGNATURE WITH BID SUBMISSION.**

**INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS**

**THE FOLLOWING INSTRUCTIONS APPLY TO ALL BIDS**

All bids submitted are subject to these instructions and general conditions and any special conditions and specifications contained herein, all of which are made part of this bid proposal reference. By submitting a bid, vendor agrees to comply with all provisions of Louisiana Law as well be in compliance with the Jefferson Parish Code of Ordinances, Louisiana Code of Ethics, applicable Jefferson Parish ethical standards and Jefferson Parish Resolution No. 136353 and/or Resolution No. 141125 as amended.

Jefferson Parish adheres to the Louisiana Code of Governmental Ethics, contained in Louisiana Revised Statutes Annotated, R.S. 42:1101, et seq. Vendor/Proposer by this submission, warrants that there are no "conflicts of interest" related to this procurement that would violate applicable Louisiana Law. Violation of the Louisiana Code of Governmental Ethics may result in rescission of contract, permit or licenses, and the imposition of fines and/or penalties, without contractual liability to the public in accordance with applicable law.

All vendors submitting bids should register as a Jefferson Parish vendor if not already yet registered. Registration forms may be downloaded from <http://www.jeffparish.gov/464/Purchasing> and by clicking on Vendor Information. Current W-9 forms with respective Tax Identification numbers and vendor applications may be submitted at any time; however, if your company is not registered and/or a current W-9 form is not on file, vendor registration is mandatory. Vendors may experience a delay in payment if your company is not a registered vendor with Jefferson Parish.

All quotations shall be based on F.O.B. Agency warehouse or job site, anywhere within the Parish as designated by the Purchasing Department. This provision does not apply to public works projects

JEFFERSON PARISH requires all products to be new (current) and all work must be performed according to standard practices for the project. Unless otherwise specified, no aftermarket parts will be accepted. Unless otherwise specified, all workmanship and materials must have at least one (1) year guaranty, in writing, from the date of delivery and/or acceptance of the project. Any deviations or alterations from the specifications must be indicated on the bid form with bid submission. Supporting documentation may be required upon request.

Bidders should submit all questions in writing via email to the Purchasing Specialist's email address as indicated above, no later than Five (5) working days prior to the bid opening. Bid numbers must be mentioned in all requests. If submitting online, vendors may send questions via the E-Procurement site no later than Five (5) working days prior to the bid opening.

If this bid requires a pre-bid conference (see Additional Requirements section), bidders are advised that such conference will be held to allow bidders the opportunity to identify any discrepancies in the bid specifications and seek further clarification regarding instructions.

The Purchasing Department will issue a written response to bidder's questions in the form of an Addendum. Please note that all official communication will be expressed in the form of an addendum.

All formal Addenda require written acknowledgement on the bid form by the bidder. Failure to acknowledge any Addendum on the bid form shall cause the bid to be rejected. JEFFERSON PARISH reserves the right to award bid to next lowest responsive and responsible bidder in this event.

JEFFERSON PARISH will accept one price for each item unless otherwise indicated. Two or more prices for one item will result in bid rejection. Bidders are required to complete, sign and return the bid form and/or complete and return the associated line item pricing forms as indicated. Vendors must not alter the bid forms. Doing so will cause the bid to be rejected.

A corporate resolution or written evidence of the individual signing the bid having such authority must be submitted with the bid. Failure to comply will cause bid to be rejected. Acceptable written evidence may be a printout of the Louisiana Secretary of State's website listing the signatory as an officer or a manager. Such printout shall be included with the bid submission. Bids submitted by Owners or Sole Proprietorships must include certification that he or she owns the entity for which the bid is signed. This documentation must be submitted with the bid. Failure to do so will result in bid rejection.

NOTE: A sample corporate resolution can be downloaded from our website <http://www.jeffparish.gov/464/Purchasing> or you may provide your own document. A sample certification of sole proprietorship can also be downloaded from our website <http://www.jeffparish.gov/464/Purchasing> or you may provide your own document.

## **INSTRUCTIONS FOR BIDDERS AND GENERAL CONDITIONS**

- A. **AWARD OF CONTRACT:** JEFFERSON PARISH reserves the right to award contracts or place orders on a lump sum or individual item basis, or such combination, as shall in its judgment be in the best interest of JEFFERSON PARISH. Every contract or order shall be awarded to the **LOWEST RESPONSIVE AND RESPONSIBLE BIDDER**, taking into consideration the **CONFORMITY WITH THE SPECIFICATIONS** and the **DELIVERY AND/OR COMPLETION DATE**. **SPLIT AWARDS MADE TO SEVERAL VENDORS WILL ONLY BE GRANTED TO THOSE DEEMED RESPONSIVE AND RESPONSIBLE.**

All bid prices shall remain valid for 45 days. Jefferson Parish and the lowest responsive and responsible bidder(s) by mutual written consent may mutually agree to extend the deadline for award by one (1) or more extensions of thirty (30) calendar days.

**PROTESTS:** Only those vendors that submit bids in response to this solicitation may protest any element of the procurement, in writing to the Director of the Purchasing Department. Written protest must be received within 48 hours of the release of the bid tabulation by the Purchasing Department. After consultation, the Parish Attorney's Office will then respond to protests in writing. (For more information, please see Chapter 2, Article VII, Division 2, Sec. 2-914.1 of the Jefferson Parish Code of Ordinances.)

**PREFERENCE:** Unless federal funding is directly spent by Jefferson Parish for this purchase, preference is hereby given to materials, supplies, and provisions produced, manufactured or grown in Louisiana, quality being equal to articles offered by competitors outside the state. "LSA – R.S. 38:2251-2261"

- B. **USE OF BRAND NAMES AND STOCK NUMBERS:** Where brand names and stock numbers are specified, it is for the purpose of establishing certain minimum standards of quality. Bids may be submitted for products of equal quality, provided brand names and stock numbers are specified. Complete product data may be required prior to award.

- C. **CANCELLATION OF CONTRACT:** JEFFERSON PARISH reserves the right to cancel all or any part if not shipped promptly. No charges will be allowed for parking or cartage unless specified in quotation. The order must not be filled at a higher price than quoted. JEFFERSON PARISH reserves the right to cancel any contract at anytime and for any reason by issuing a **THIRTY (30)** day written notice to the contractor.

For good cause and as consideration for executing a contract with Jefferson Parish, vendor conveys, sells, assigns and transfers to Jefferson Parish or its assigns all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the State of Louisiana, relating to the particular good or services purchased or acquired by Jefferson Parish.

- D. **PRICES:** Jefferson Parish is exempt from paying sales tax under LSA-R.S. 47:301 (8)(c). All prices for purchases by Jefferson Parish of supplies and materials shall be quoted in the unit of measure specified and unless otherwise specified, shall be exclusive of state and local taxes. The price quoted for work shall be stated in figures no more than four (4) decimal points. In the event there is a difference in unit prices and totals, the unit price shall prevail.

Quantities listed are for bidding purposes only. Actual requirements may be more or less than quantities listed.

- E. **ANTI-DISCRIMINATION:** Bidders are not to exclude from participation in, deny the benefits of, or subject to discrimination under any program or activity, any person in the United States on the grounds of race, color, national origin, or sex; nor discriminate on the basis of age under the Age Discrimination Act of 1975, or with respect to an otherwise qualified handicapped individual as provided in Section 504 of the Rehabilitation Act of 1973, or on the basis of religion, except that any exemption from such prohibition against discrimination on the basis of religion as provided in the Civil Rights Act of 1964, or Title VI and VII of the Act of April 11, 1968, shall also apply. This assurance includes compliance with the administrative requirements of the Revenue Sharing final handicapped discrimination provisions contained in Section 51.55 (c), (d), (e), and (k)(5) of the Regulations. New construction or renovation projects must comply with Section 504 of the 1973 Rehabilitation Act, as amended, in accordance with the American National Standard Institute's specifications (ANSI A17.1-1961).

In accordance with L.R.S. 38:2216.1, Jefferson Parish is prohibited from entering into a contract with a value of \$100,000 or more with a company for the purchase of goods or services unless the contract contains a written verification from the company of both of the following: 1) The company does not have a practice, policy, guidance, or directive that discriminates against a firearm entity or firearm trade association based solely on the entity's or association's status as a firearm entity or firearm trade association. 2) The company will not discriminate against a firearm entity or firearm trade association during the term of the contract based solely on the entity's or association's status as a firearm entity or firearm trade association. As a result, the awarded bidder will be required to verify the above in the ensuing contract.

F.INSPECTOR GENERAL: It shall be the duty of every parish officer, employee, department, agency, special district, board, and commission: and the duty of every contractor, subcontractor, and licensee of the parish, and the duty of every applicant for certification of eligibility for a parish contract or program, to cooperate with the Inspector General in any investigation, audit, inspection, performance review, or hearing pursuant to JPCO 2-155.10(19). By signing this document, every corporation, partnership, or person contracting with PARISH, whether by cooperative endeavor, intergovernmental agreement, bid,proposal, application or solicitation for a parish contract, and every application for certification of eligibility for a parish contract or program, attests that it understands and will abide by all provisions of JPCO 2-155.10.

G.Cyber Security Training: Pursuant to La. R.S. 42:1267, any contractor who has access to state or local government information technology assets is required to complete cybersecurity training during the term of the contract and during any renewal period. As a Parish contractor, you are responsible for taking the cyber training, whether from the State or another source. After completion of said training please forward proof to your contract monitor/Parish contact.

Jefferson Parish and its partners as the recipients of federal funds are fully committed to awarding a contract(s) to firm(s) that will provide high quality services and that are dedicated to diversity and to containing costs. Thus, Jefferson Parish strongly encourages the involvement of minority and/or woman-owned business enterprises (DBE's, including MBE's, WBE's and SBE's) to stimulate participation in procurement and assistance programs.

The purpose and intention of this invitation to bid is to afford all suppliers an equal opportunity to bid on all construction, maintenance, repair, operating supplies and/or equipment listed in this bid proposal. JEFFERSON PARISH WILL ACCEPT ONE BID ONLY FROM EACH VENDOR. Items bid must meet specifications.

Advertised bids will be tabulated and a copy of the tabulation will be forwarded to each responding bidder after nine (9) working days.

**IN ACCORDANCE WITH STATE REGULATIONS JEFFERSON PARISH OFFERS ELECTRONIC PROCUREMENT TO ALL VENDORS**

**This electronic procurement system allows vendors the convenience of reviewing and submitting bids online.**

**This is a secure site and authorized personnel have limited read access only. Bidders are to submit electronically using this free service; while the website accepts various file types, one single PDF file containing all appropriate and required bid documents is preferred. Bidders submitting uploaded images of bid responses are solely responsible for clarity. If uploaded images/documents are not legible, then bidder's submission will be rejected. Please note all requirements contained in this bid package for electronic bid submission.**

**Please visit our E-Procurement Page at [www.jeffparishbids.net](http://www.jeffparishbids.net) to register and view Jefferson Parish solicitations. For more information, please visit the Purchasing Department page at <http://www.jeffparish.gov/464/Purchasing> .**

The general specifications for construction projects and the purchase of materials, services and/or supplies are those adopted by the JEFFERSON PARISH Council by Resolution No. 136353 or 141125 as amended. The general conditions adopted by this resolution shall be considered as much a part of this document as if they were written wholly herein. A copy may be obtained from the Office of the Parish Clerk, Suite 6700, Jefferson Parish General Government Building, 200 Derbigny Street, Gretna, LA 70053. You may also obtain a copy by visiting the Purchasing Department webpage at <http://www.jeffparish.gov/464/Purchasing> and clicking on Online Forms.

## **ADDITIONAL REQUIREMENTS FOR THIS BID**

PLEASE MATCH THE NUMBERS PRINTED IN THIS BOX WITH THE CORRESPONDING INSTRUCTIONS BELOW. IF THE NUMBER IS NOT SPECIFIED IN THIS BOX, IT IS NOT APPLICABLE FOR THIS BID.

**3, 8, 9, 10, 11, 12, 13, 15**

1. All bidders must attend the MANDATORY pre-bid conference and will be required to sign in and out as evidence of attendance. In accordance with LSA R.S. 38:2212(I), all prospective bidders shall be present at the beginning of the MANDATORY pre-bid conference and shall remain in attendance for the duration of the conference. Any prospective bidder who fails to attend the conference or remain for the duration shall be prohibited from submitting a bid for the project.
2. Attendance to this pre-bid conference is optional. However, failure to attend the pre-bid conference shall not relieve the bidder of responsibility for information discussed at the conference. Furthermore, failure to attend the pre-bid conference and inspection does not relieve the successful bidder from the necessity of furnishing materials or performing any work that may be required to complete the work in accordance with the specification with no additional cost to the owner.
3. Contractor must hold current applicable JEFFERSON PARISH licenses with the Department Building Permits. Contractor shall obtain any and all permits required by the JEFFERSON PARISH Department of Building Permits. The contractor shall be responsible for the payment of these permits. All permits must be obtained prior to the start of the project. Contractor must also hold any and all applicable municipality, Federal and State licenses. Contractor shall be responsible for the payment of these permits and shall obtain them prior to the start of the project.

4. A LA State Contractor's License will be required in accordance with L.R.S. 37:2150 et. seq. and such license number must be entered in the appropriate field in the electronic procurement system. Failure to comply will cause the bid to be rejected.
5. It is the bidder's responsibility to visit the job site and evaluate the job before submitting a bid.
6. Job site must be clean and free of all litter and debris daily and upon completion of the contract. Passageways must be kept clean and free of material, equipment, and debris at all times. Flammable material must be removed from the job site daily because storage will not be permitted on the premises. Precautions must be exercised at all times to safeguard the welfare of JEFFERSON PARISH and the general public.
7. **PUBLIC WORKS BIDS:** All awards for public works in excess of \$5,000.00 will be reduced to a formal contract which shall be recorded at the contractor's expense with the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. A price list of recordation costs may be obtained from the Clerk of Court and Ex-Officio Recorder of Mortgages for the Parish of Jefferson. All awards in excess of \$25,000.00 will require both a performance and a payment bond. Unless otherwise stated in the bid specifications, the performance bond requirements shall be 100% of the contract price. Unless otherwise state in the bid specifications, the payment bond requirements shall be 100% of the contract price. Both bonds shall be supplied at the signing of the contract.
8. **NON-PUBLIC WORKS BIDS:** A performance bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The performance bond shall be supplied at the signing of the contract.
9. **NON-PUBLIC WORKS BIDS:** A payment bond will be required for this bid. The amount of the bond will be 100% of the contract price unless otherwise indicated in the specifications. The payment bond shall be supplied at the signing of the contract.
10. All bidders must comply with the requirements stated in the attached "Standard Insurance Requirements" sheet attached to this bid solicitation. Any deviation from the Standard Insurance Requirements must be requested in writing prior to bid opening. Proof of coverage will be required prior to award. Failure to comply with this instruction will result in bid rejection.
11. A bid bond will be required with bid submission in the amount of 5% of the total bid, unless otherwise stated in the bid specifications. Vendors must submit an electronic bid bond through the respective online clearinghouse bond management system(s) as indicated in the electronic bid solicitation on Central Auction House. No scanned paper copies of any bid bond will be accepted as part of the electronic bid submission.
12. This is a requirements-based contract to be provided on an as needed basis. JEFFERSON PARISH makes no representations on warranties with regard to minimum guaranteed quantities unless otherwise stated in the bid specifications.
13. Freight charges should be included in total cost when quoting. If not quoted FOB DELIVERED, freight must be quoted as a separate item. Bid may be rejected if not quoted FOB DELIVERED or if freight charges are not indicated on bid form.
14. **AFFIDAVIT - Completed, Signed and Properly Notarized Affidavits Required;** This applies to all solicitations in conformity with the provisions contained in LSA-RS 38:2212.9, LSA-RS 38:2212.10, LSA-RS 38:2224, and Sec 2-923.1 of the Jefferson Parish Code of Ordinances. For bidding purposes, all bidders must submit with bid submission COMPLETED, SIGNED and PROPERLY NOTARIZED Affidavits, including: Non-Conviction Affidavit, Non-Collusion Affidavit, Campaign Contribution Affidavit, Debt Disclosures Affidavit and E-Verify Affidavit. For the convenience of vendors, all affidavits have been combined into one form entitled GENERIC BID AFFIDAVIT. This affidavit must be submitted in its original format, and without material alteration, in order to be compliant and for the bid to be considered responsive. A scanned copy of the completed, signed and properly notarized affidavit may be submitted with the bid, however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.
15. The ensuing contract for this bid solicitation may be eligible for FEMA reimbursement and/or Federal funding/reimbursement. As such, the referenced appendix will be applicable accordingly and shall be considered a part of the bid documents and ensuing contract. All applicable certifications must be duly completed, signed and submitted as per the appendix instructions. Failure to submit applicable certifications per the appendix instructions will result in bid rejection.
16. For this project, the Contractor shall not pay any state or local sales or use taxes on materials and equipment which are affixed and made part of the immovable property of the project or which is permanently incorporated in the project (hereinafter referred to as "applicable materials and equipment."). All purchases of applicable materials or equipment shall be made by the contractor on behalf of and as the agent of Jefferson Parish (Owner), a political subdivision of the State of Louisiana. No state and local sales and use taxes are owed on applicable materials and equipment under the provisions of Act 1029 of the 1991 Regular Session - Louisiana Revised Statute 47:301(8)(c). Owner will furnish to contractor a certificate form which certifies that Owner is not required to pay such state or local sales and use taxes, and contractor shall furnish a copy of such certificate to all vendors or suppliers of the applicable materials and equipment, and report to Owner the amount of taxes not incurred.
17. **Tech Affidavit:** The Tech Affidavit is required for this solicitation and shall be submitted with the bid submission. Failure to do so will result in your bid being rejected. Pursuant to La. R.S. 38:2237.1, prior to the procurement of telecommunications or video surveillance equipment or services, the vendor shall provide documentation by affidavit that the equipment or services to be procured are not prohibited telecommunications or video surveillance equipment or services as defined in R.S. 39:1753.1(A). This affidavit is supplied as a courtesy to Affiant. It is the responsibility of the affiant to insure the affidavit submitted to Jefferson Parish complies, in both form and content, with federal, state and parish laws. No procurement shall be made from a vendor or other entity who fails to provide the documentation; any procurement in contravention to this requirement shall be null and void by law.

**BID FORM**  
Non Public Works

**All Public Work Projects are required to use the Louisiana Uniform Public Work Bid Form**

All prices must be held firm throughout the entirety of the contract. However, bidders may request that an escalation provision be added to their contract by selecting "yes" below. The escalation provision in the contract will state that only one escalation will be allowed during the term of the contract, and the escalation shall take effect only after the initial 12 month period of the contract. A vendor with an escalation provision in their contract must submit a request in writing to activate the provision, but should not do so any sooner than the first day of the 13th month of their contract. The escalation percentage shall be limited to the most recently published CPI figure issued at the time an adjustment is requested by bidder based on the U.S. Bureau of Labor Statistics National Index for all Urban Consumers, unadjusted 12-month figure.

Are you requesting an escalation provision?

YES \_\_\_\_\_ NO \_\_\_\_\_

**DELIVERY: FOB JEFFERSON PARISH**

INDICATE DELIVERY DATE ON EQUIPMENT AND SUPPLIES \_\_\_\_\_

**LOUISIANA CONTRACTOR'S LICENSE NO.: (if applicable)** \_\_\_\_\_

**THIS SECTION MUST BE COMPLETED BY BIDDER:**

FIRM NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY, STATE: \_\_\_\_\_ ZIP: \_\_\_\_\_

TELEPHONE: (     ) \_\_\_\_\_

E-MAIL: \_\_\_\_\_

In the event that addenda are issued with this bid, bidders **MUST** acknowledge all addenda on the bid form. Bidder must acknowledge receipt of an addendum on the bid form by placing the addendum number as indicated. Failure to acknowledge any addendum on the bid form will result in bid rejection.

Acknowledge Receipt of Addenda: NUMBER: \_\_\_\_\_

NUMBER: \_\_\_\_\_

NUMBER: \_\_\_\_\_

NUMBER: \_\_\_\_\_

TOTAL PRICE OF ALL BID ITEMS: \$ \_\_\_\_\_

AUTHORIZED

SIGNATURE: \_\_\_\_\_

Printed Name

TITLE: \_\_\_\_\_

**SIGNING INDICATES YOU HAVE READ AND COMPLY WITH THE INSTRUCTIONS AND CONDITIONS.**

**NOTE: All bids should be returned with the BID NUMBER and BID OPENING DATE indicated on the outside of the envelope submitted to the Purchasing Department.**

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
1	1.00	EA	<p>TWO (2) YEAR CONTRACT FOR ELECTRIC MOTOR REPAIRS FOR THE JEFFERSON PARISH DEPT OF PUBLIC WORKS- SEWERAGE AND ALL JEFFERSON PARISH AGENCIES AND MUNICIPALITIES</p> <p>0001 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/3 HP/3600 RPM</p>	\$ _____	\$ _____
2	1.00	EA	<p>TWO (2) YEAR CONTRACT FOR ELECTRIC MOTOR REPAIRS FOR THE JEFFERSON PARISH DEPARTMENT OF PUBLIC WORKS - SEWERAGE AND ALL JEFFERSON PARISH AGENCIES AND MUNICIPALITIES</p> <p>Previous Contract no. 55-21511</p> <p>0002 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/3 HP/1800 RPM</p>	\$ _____	\$ _____
3	1.00	EA	<p>0003 - Electric Motor, Stator Rewind, 200-575-Volts</p> <p>1/3 HP/1200 RPM</p>	\$ _____	\$ _____
4	1.00	EA	<p>0004 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/3 HP/900 RPM</p>	\$ _____	\$ _____
5	1.00	EA	<p>0005 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/3 HP/720 RPM</p>	\$ _____	\$ _____
6	1.00	EA	<p>0006 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/3 HP/600 RPM</p>	\$ _____	\$ _____
7	1.00	EA	<p>0007 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/3 HP/450 RPM</p>	\$ _____	\$ _____
8	1.00	EA	<p>0008 - Electric Motor, Stator Rewind, 200-575 Volts</p> <p>1/2 HP/3600 RPM</p>	\$ _____	\$ _____
9	1.00	EA	<p>0009 - Electric Motor, Stator Rewind, 200-575 Volts</p>	\$ _____	\$ _____

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
10	1.00	EA	1/2 HP/1800 RPM 0010 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
11	1.00	EA	1/2 HP/1200 RPM 0011 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
12	1.00	EA	1/2 HP/900 RPM 0012 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
13	1.00	EA	1/2 HP/720 RPM 0013 - Electric Motor, Stator Rewind, 200-575 Motor	\$	\$
14	1.00	EA	1/2 HP/600 RPM 0014 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
15	1.00	EA	1/2 HP/450 RPM 0015 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
16	1.00	EA	3/4 HP/3600 RPM 0016 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
17	1.00	EA	3/4 HP/1800 RPM 0017 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
18	1.00	EA	3/4 HP/1200 RPM 0018 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
19	1.00	EA	3/4 HP/900 RPM 0019 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			3/4 HP/720 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
20	1.00	EA	0020 - Electric Motor, Stator Rewind, 200-575 Volts  3/4 HP/600 RPM	\$	\$
21	1.00	EA	0021 - Electric Motor, Stator Rewind, 200-575 Volts  3/4 HP/450 RPM	\$	\$
22	1.00	EA	0022 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/3600 RPM	\$	\$
23	1.00	EA	0023 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/1800 RPM	\$	\$
24	1.00	EA	0024 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/1200 RPM	\$	\$
25	1.00	EA	0025 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/900 RPM	\$	\$
26	1.00	EA	0026 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/720 RPM	\$	\$
27	1.00	EA	0027 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/600 RPM	\$	\$
28	1.00	EA	0028 - Electric Motor, Stator Rewind, 200-575 Volts  1 HP/450 RPM	\$	\$
29	1.00	EA	0029 - Electric Motor, Stator Rewind, 200-575 Volts  1.5 HP/3600 RPM	\$	\$
30	1.00	EA	0030 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
31	1.00	EA	1.5 HP/1800 RPM		
			0031 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
32	1.00	EA	1.5 HP/1200 RPM		
			0032 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
33	1.00	EA	1.5 HP/900 RPM		
			0033 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
34	1.00	EA	1.5 HP/720 RPM		
			0034 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
35	1.00	EA	1.5 HP/600 RPM		
			0035 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
36	1.00	EA	1.5 HP/450 RPM		
			0036 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
37	1.00	EA	2 HP/3600 RPM		
			0037 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
38	1.00	EA	2 HP/1800 RPM		
			0038 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
39	1.00	EA	2 HP/1200 RPM		
			0039 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
40	1.00	EA	2 HP/900 RPM		
			0040 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			2 HP/720 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
41	1.00	EA	0041 - Electric Motor, Stator Rewind, 200-575 Volts  2 HP/600 RPM	\$	\$
42	1.00	EA	0042 - Electric Motor, Stator Rewind, 200-575 Volts  2 HP/450 RPM	\$	\$
43	1.00	EA	0043 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/3600 RPM	\$	\$
44	1.00	EA	0044 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/1800 RPM	\$	\$
45	1.00	EA	0045 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/1200 RPM	\$	\$
46	1.00	EA	0046 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/900 RPM	\$	\$
47	1.00	EA	0047 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/720 RPM	\$	\$
48	1.00	EA	0048 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/600 RPM	\$	\$
49	1.00	EA	0049 - Electric Motor, Stator Rewind, 200-575 Volts  3 HP/450 RPM	\$	\$
50	1.00	EA	0050 - Electric Motor, Stator Rewind, 200-575 Volts  5 HP/3600 RPM	\$	\$
51	6.00	EA	0051 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
52	1.00	EA	5 HP/1800 RPM 0052 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
53	1.00	EA	5 HP/1200 RPM 0053 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
54	1.00	EA	5 HP/900 RPM 0054 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
55	1.00	EA	5 HP/720 RPM 0055 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
56	1.00	EA	5 HP/600 RPM 0056 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
57	1.00	EA	5 HP/450 RPM 0057 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
58	1.00	EA	7.5 HP/3600 RPM 0058 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
59	6.00	EA	7.5 HP/1800 RPM 0059 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
60	6.00	EA	7.5 HP/1200 RPM 0060 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
61	1.00	EA	7.5 HP/900 RPM 0061 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			7.5 HP/720 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
62	1.00	EA	0062 - Electric Motor, Stator Rewind, 200-575 Volts  7.5 HP/600 RPM	\$	\$
63	1.00	EA	0063 - Electric Motor, Stator Rewind, 200-575 Volts  7.5 HP/450 RPM	\$	\$
64	1.00	EA	0064 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/3600 RPM	\$	\$
65	2.00	EA	0065 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/1800 RPM	\$	\$
66	7.00	EA	0066 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/1200 RPM	\$	\$
67	1.00	EA	0067 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/900 RPM	\$	\$
68	1.00	EA	0068 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/720 RPM	\$	\$
69	1.00	EA	0069 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/600 RPM	\$	\$
70	1.00	EA	0070 - Electric Motor, Stator Rewind, 200-575 Volts  10 HP/450 RPM	\$	\$
71	1.00	EA	0071 - Electric Motor, Stator Rewind, 200-575 Volts  15 HP/3600 RPM	\$	\$
72	26.00	EA	0072 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
73	5.00	EA	15 HP/1800 RPM 0073 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
74	2.00	EA	15 HP/1200 RPM 0074 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
75	1.00	EA	15 HP/900 RPM 0075 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
76	1.00	EA	15 HP/720 RPM 0076 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
77	1.00	EA	15 HP/600 RPM 0077 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
78	1.00	EA	15 HP/450 RPM 0078 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
79	8.00	EA	20 HP/3600 RPM 0079 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
80	5.00	EA	20 HP/1800 RPM 0080 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
81	1.00	EA	20 HP/1200 RPM 0081 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
82	1.00	EA	20 HP/900 RPM 0082 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			20 HP/720 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
83	1.00	EA	0083 - Electric Motor, Stator Rewind, 200-575 Volts  20 HP/450 RPM	\$	\$
84	1.00	EA	0084 - Electric Motor, Stator Rewind, 200-575 Volts  20 HP/600 RPM	\$	\$
85	1.00	EA	0085 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/3600 RPM	\$	\$
86	1.00	EA	0086 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/1800 RPM	\$	\$
87	1.00	EA	0087 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/1200 RPM	\$	\$
88	3.00	EA	0088 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/900 RPM	\$	\$
89	1.00	EA	0089 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/720 RPM	\$	\$
90	1.00	EA	0090 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/600 RPM	\$	\$
91	1.00	EA	0091 - Electric Motor, Stator Rewind, 200-575 Volts  25 HP/450 RPM	\$	\$
92	1.00	EA	0092 - Electric Motor, Stator Rewind, 200-575 Volts  30 HP/3600 RPM	\$	\$
93	1.00	EA	0093 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
94	1.00	EA	30 HP/1800 RPM 0094 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
95	1.00	EA	30 HP/1200 RPM 0095 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
96	1.00	EA	30 HP/900 RPM 0096 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
97	1.00	EA	30 HP/720 RPM 0097 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
98	1.00	EA	30 HP/600 RPM 0098 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
99	1.00	EA	30 HP/450 RPM 0099 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
100	1.00	EA	40 HP/3600 RPM 0100 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
101	15.00	EA	40 HP/1800 RPM 0101 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
102	1.00	EA	40 HP/1200 RPM 0102 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
103	1.00	EA	40 HP/900 RPM 0103 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			40 HP/720 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
104	1.00	EA	0104 - Electric Motor, Stator Rewind, 200-575 Volts  40 HP/600 RPM	\$	\$
105	1.00	EA	0105 - Electric Motor, Stator Rewind, 200-575 Volts  40 HP/450 RPM	\$	\$
106	1.00	EA	0106 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/3600 RPM	\$	\$
107	2.00	EA	0107 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/1800 RPM	\$	\$
108	10.00	EA	0108 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/1200 RPM	\$	\$
109	1.00	EA	0109 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/900 RPM	\$	\$
110	1.00	EA	0110 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/720 RPM	\$	\$
111	1.00	EA	0111 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/600 RPM	\$	\$
112	1.00	EA	0112 - Electric Motor, Stator Rewind, 200-575 Volts  50 HP/450 RPM	\$	\$
113	1.00	EA	0113 - Electric Motor, Stator Rewind, 200-575 Volts  60 HP/3600 RPM	\$	\$
114	3.00	EA	0114 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
115	5.00	EA	60 HP/1800 RPM 0115 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
116	1.00	EA	60 HP/1200 RPM 0116 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
117	1.00	EA	60 HP/900 RPM 0117 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
118	1.00	EA	60 HP/720 RPM 0118 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
119	1.00	EA	60 HP/600 RPM 0119 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
120	1.00	EA	60 HP/450 RPM 0120 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
121	2.00	EA	75 HP/3600 RPM 0121 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
122	4.00	EA	75 HP/1800 RPM 0122 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
123	1.00	EA	75 HP/1200 RPM 0123 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
124	1.00	EA	75 HP/900 RPM 0124 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			75 HP/750 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
125	1.00	EA	0125 - Electric Motor, Stator Rewind, 200-575 Volts  75 HP/600 RPM	₺	₺
126	1.00	EA	0126 - Electric Motor, Stator Rewind, 200-575 Volts  75 HP/450 RPM	₺	₺
127	1.00	EA	0127 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/3600 RPM	₺	₺
128	2.00	EA	0128 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/1800 RPM	₺	₺
129	2.00	EA	0129 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/1200 RPM	₺	₺
130	1.00	EA	0130 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/900 RPM	₺	₺
131	1.00	EA	0131 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/720 RPM	₺	₺
132	1.00	EA	0132 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/600 RPM	₺	₺
133	1.00	EA	0133 - Electric Motor, Stator Rewind, 200-575 Volts  100 HP/450 RPM	₺	₺
134	1.00	EA	0134 - Electric Motor, Stator Rewind, 200-575 Volts  125 HP/3600 RPM	₺	₺
135	1.00	EA	0135 - Electric Motor, Stator Rewind, 200-575 Volts	₺	₺

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
136	1.00	EA	125 HP/1800 RPM 0136 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
137	3.00	EA	125 HP/1200 RPM 0137 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
138	1.00	EA	125 HP/900 RPM 0138 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
139	1.00	EA	125 HP/720 RPM 0139 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
140	1.00	EA	125 HP/600 RPM 0140 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
141	1.00	EA	125 HP/450 RPM 0141 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
142	1.00	EA	134 HP/3600 RPM 0142 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
143	1.00	EA	134 HP/1800 RPM 0143 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
144	1.00	EA	134 HP/1200 RPM 0144 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
145	1.00	EA	134 HP/900 RPM 0145 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			134 HP/600 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
146	1.00	EA	0146 - Electric Motor, Stator Rewind, 200-575 Volts  134 HP/450 RPM	\$	\$
147	1.00	EA	0147 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/3600 RPM	\$	\$
148	1.00	EA	0148 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/1800 RPM	\$	\$
149	1.00	EA	0149 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/1200 RPM	\$	\$
150	2.00	EA	0150 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/900 RPM	\$	\$
151	1.00	EA	0151 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/720 RPM	\$	\$
152	1.00	EA	0152 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/600 RPM	\$	\$
153	1.00	EA	0153 - Electric Motor, Stator Rewind, 200-575 Volts  150 HP/450 RPM	\$	\$
154	1.00	EA	0154 - Electric Motor, Stator Rewind, 200-575 Volts  200 HP/3600 RPM	\$	\$
155	1.00	EA	0155 - Electric Motor, Stator Rewind, 200-575 Volts  200 HP/1800 RPM	\$	\$
156	3.00	EA	0156 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
157	2.00	EA	200 HP/1200 RPM 0157 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
158	1.00	EA	200 HP/900 RPM 0158 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
159	1.00	EA	200 HP/720 RPM 0159 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
160	1.00	EA	200 HP/600 RPM 0160 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
161	1.00	EA	200 HP/450 RPM 0161 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
162	1.00	EA	250 HP/3600 RPM 0162 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
163	1.00	EA	250 HP/1800 RPM 0163 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
164	1.00	EA	250 HP/1200 RPM 0164 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
165	2.00	EA	250 HP/900 RPM 0165 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
166	1.00	EA	250 HP/720 RPM 0166 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
			250 HP/600 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
167	1.00	EA	0167 - Electric Motor, Stator Rewind, 200-575 Volts  250 HP/450 RPM	₹	₹
168	1.00	EA	0168 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/3600 RPM	₹	₹
169	1.00	EA	0169 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/1800 RPM	₹	₹
170	1.00	EA	0170 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/1200 RPM	₹	₹
171	1.00	EA	0171 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/900 RPM	₹	₹
172	1.00	EA	0172 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/720 RPM	₹	₹
173	1.00	EA	0173 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/600 RPM	₹	₹
174	1.00	EA	0174 - Electric Motor, Stator Rewind, 200-575 Volts  300 HP/450 RPM	₹	₹
175	1.00	EA	0175 - Electric Motor, Stator Rewind, 200-575 Volts  316 HP/3600 RPM	₹	₹
176	1.00	EA	0176 - Electric Motor, Stator Rewind, 200-575 Volts  316 HP/1800 RPM	₹	₹
177	1.00	EA	0177 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
178	1.00	EA	316 HP/1200 RPM 0178 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
179	1.00	EA	316 HP/900 RPM 0179 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
180	1.00	EA	316 HP/600 RPM 0180 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
181	1.00	EA	316 HP/450 RPM 0181 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
182	1.00	EA	350 HP/3600 RPM 0182 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
183	4.00	EA	350 HP/1800 RPM 0183 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
184	1.00	EA	350 HP/1200 RPM 0184 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
185	1.00	EA	350 HP/900 RPM 0185 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
186	1.00	EA	350 HP/720 RPM 0186 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
187	1.00	EA	350 HP/600 RPM 0187 - Electric Motor, Stator Rewind, 200-575 Volts	₹	₹
			350 HP/450 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
188	1.00	EA	0188 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/3600 RPM	\$	\$
189	1.00	EA	0189 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/1800 RPM	\$	\$
190	1.00	EA	0190 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/1200 RPM	\$	\$
191	1.00	EA	0191 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/900 RPM	\$	\$
192	1.00	EA	0192 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/720 RPM	\$	\$
193	1.00	EA	0193 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/600 RPM	\$	\$
194	1.00	EA	0194 - Electric Motor, Stator Rewind, 200-575 Volts  400 HP/450 RPM	\$	\$
195	1.00	EA	0195 - Electric Motor, Stator Rewind, 200-575 Volts  500 HP/3600 RPM	\$	\$
196	1.00	EA	0196 - Electric Motor, Stator Rewind, 200-575 Volts  500 HP/1800 RPM	\$	\$
197	1.00	EA	0197 - Electric Motor, Stator Rewind, 200-575 Volts  500 HP/1200 RPM	\$	\$
198	1.00	EA	0198 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
199	1.00	EA	500 HP/900 RPM 0199 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
200	1.00	EA	500 HP/720 RPM 0200 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
201	1.00	EA	500 HP/600 RPM 0201 - Electric Motor, Stator Rewind, 200-575 Volts	\$	\$
202	1.00	EA	500 HP/450 RPM 0202 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
203	1.00	EA	100 HP/1800 RPM 0203 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
204	1.00	EA	100 HP/900 RPM 0204 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
205	1.00	EA	100 HP/327 RPM 0205 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
206	1.00	EA	200 HP/1800 RPM 0206 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
207	1.00	EA	200 HP/1800 RPM 0207 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
208	1.00	EA	200 HP/900 RPM 0208 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			200 HP/900 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
209	1.00	EA	0209 - Electric Motor, Stator Rewind, 4160 Volts  200 HP/327 RPM	\$	\$
210	1.00	EA	0210 - Electric Motor, Stator Rewind, 2300 Volts  200 HP/327 RPM	\$	\$
211	1.00	EA	0211 - Electric Motor, Stator Rewind, 2300 Volts  225 HP/1800 RPM	\$	\$
212	1.00	EA	0212 - Electric Motor, Stator Rewind, 2300 Volts  225 HP/900 RPM	\$	\$
213	1.00	EA	0213 - Electric Motor, Stator Rewind, 2300 Volts  225 HP/327 RPM	\$	\$
214	1.00	EA	0214 - Electric Motor, Stator Rewind, 4160 Volts  300 HP/1800 RPM	\$	\$
215	1.00	EA	0215 - Electric Motor, Stator Rewind, 2300 Volts  300 HP/1800 RPM	\$	\$
216	1.00	EA	0216 - Electric Motor, Stator Rewind, 4160 Volts  300 HP/900 RPM	\$	\$
217	1.00	EA	0217 - Electric Motor, Stator Rewind, 2300 Volts  300 HP/900 RPM	\$	\$
218	1.00	EA	0218 - Electric Motor, Stator Rewind, 4160 Volts  300 HP/327 RPM	\$	\$
219	1.00	EA	0219 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
220	1.00	EA	300 HP/327 RPM		
			0220 - Electric Motor, Stator Rewind, 4160 Volts	₺	₺
221	1.00	EA	400 HP/1800 RPM		
			0221 - Electric Motor, Stator Rewind, 2300 Volts	₺	₺
222	1.00	EA	400 HP/1800 RPM		
			0222 - Electric Motor, Stator Rewind, 4160 Volts	₺	₺
223	1.00	EA	400 HP/900 RPM		
			0223 - Electric Motor, Stator Rewind, 2300 Volts	₺	₺
224	1.00	EA	400 HP/900 RPM		
			0224 - Electric Motor, Stator Rewind, 4160 Volts	₺	₺
225	1.00	EA	400 HP/327 RPM		
			0225 - Electric Motor, Stator Rewind, 2300 Volts	₺	₺
226	1.00	EA	500 HP/1800 RPM		
			0226 - Electric Motor, Stator Rewind, 4160 Volts	₺	₺
227	1.00	EA	500 HP/1800 RPM		
			0227 - Electric Motor, Stator Rewind, 2300 Volts	₺	₺
228	1.00	EA	500 HP/900 RPM		
			0228 - Electric Motor, Stator Rewind, 4160 Volts	₺	₺
229	1.00	EA	500 HP/900 RPM		
			0229 - Electric Motor, Stator Rewind, 2300 Volts	₺	₺

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
230	1.00	EA	0230 - Electric Motor, Stator Rewind, 4160 Volts  500 HP/327 RPM	₺	₺
231	1.00	EA	0231 - Electric Motor, Stator Rewind, 2300 Volts  500 HP/327 RPM	₺	₺
232	1.00	EA	0232 - Electric Motor, Stator Rewind, 4160 Volts  600 HP/1800 RPM	₺	₺
233	1.00	EA	0233 - Electric Motor, Stator Rewind, 2300 Volts  600 HP/1800 RPM	₺	₺
234	1.00	EA	0234 - Electric Motor, Stator Rewind, 4160 Volts  600 HP/900 RPM	₺	₺
235	1.00	EA	0235 - Electric Motor, Stator Rewind, 2300 Volts  600 HP/900 RPM	₺	₺
236	1.00	EA	0236 - Electric Motor, Stator Rewind, 4160 Volts  600 HP/327 RPM	₺	₺
237	1.00	EA	0237 - Electric Motor, Stator Rewind, 2300 Volts  600 HP/327 RPM	₺	₺
238	1.00	EA	0238 - Electric Motor, Stator Rewind, 4160 Volts  700 HP/1800 RPM	₺	₺
239	1.00	EA	0239 - Electric Motor, Stator Rewind, 2300 Volts  700 HP/1800 RPM	₺	₺
240	1.00	EA	0240 - Electric Motor, Stator Rewind, 4160 Volts	₺	₺

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
			700 HP/900 RPM		
241	1.00	EA	0241 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			700 HP/900 RPM		
242	1.00	EA	0242 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			700 HP/327 RPM		
243	1.00	EA	0243 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			700 HP/327 RPM		
244	1.00	EA	0244 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			800 HP/1800 RPM		
245	1.00	EA	0245 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			800 HP/1800 RPM		
246	1.00	EA	0246 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			800 HP/900 RPM		
247	1.00	EA	0247 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			800 HP/900 RPM		
248	1.00	EA	0248 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			800 HP/327 RPM		
249	1.00	EA	0249 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			800 HP/327 RPM		
250	1.00	EA	0250 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			900 HP/1800 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
251	1.00	EA	0251 - Electric Motor, Stator Rewind, 2300 Volts  900 HP/1800 RPM	\$	\$
252	1.00	EA	0252 - Electric Motor, Stator Rewind, 4160 Volts  900 HP/900 RPM	\$	\$
253	1.00	EA	0253 - Electric Motor, Stator Rewind, 2300 Volts  900 HP/900 RPM	\$	\$
254	1.00	EA	0254 - Electric Motor, Stator Rewind, 4160 Volts  900 HP/327 RPM	\$	\$
255	1.00	EA	0255 - Electric Motor, Stator Rewind, 2300 Volts  900 HP/327 RPM	\$	\$
256	1.00	EA	0256 - Electric Motor, Stator Rewind, 4160 Volts  1000 HP/1800 RPM	\$	\$
257	1.00	EA	0257 - Electric Motor, Stator Rewind, 2300 Volts  1000 HP/1800 RPM	\$	\$
258	1.00	EA	0258 - Electric Motor, Stator Rewind, 4160 Volts  1000 HP/900 RPM	\$	\$
259	1.00	EA	0259 - Electric Motor, Stator Rewind, 2300 Volts  1000 HP/900 RPM	\$	\$
260	1.00	EA	0260 - Electric Motor, Stator Rewind, 4160 Volts  1000 HP/327 RPM	\$	\$
261	1.00	EA	0261 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
			1000 HP/327 RPM		
262	1.00	EA	0262 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			2000 HP/1800 RPM		
263	1.00	EA	0263 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			2000 HP/1800 RPM		
264	1.00	EA	0264 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			2000 HP/900 RPM		
265	1.00	EA	0265 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			2000 HP/900 RPM		
266	1.00	EA	0266 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			2000 HP/327 RPM		
267	1.00	EA	0267 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			2000 HP/327 RPM		
268	1.00	EA	0268 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			2500 HP/1800 RPM		
269	1.00	EA	0269 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			2500 HP/1800 RPM		
270	1.00	EA	0270 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
			2500 HP/900 RPM		
271	1.00	EA	0271 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
			2500 HP/900 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
272	1.00	EA	0272 - Electric Motor, Stator Rewind, 4160 Volts  2500 HP/327 RPM	\$	\$
273	1.00	EA	0273 - Electric Motor, Stator Rewind, 2300 Volts  2500 HP/327 RPM	\$	\$
274	1.00	EA	0274 - Electric Motor, Stator Rewind, 4160 Volts  3000 HP/1800 RPM	\$	\$
275	1.00	EA	0275 - Electric Motor, Stator Rewind, 2300 Volts  3000 HP/1800 RPM	\$	\$
276	1.00	EA	0276 - Electric Motor, Stator Rewind, 4160 Volts  3000 HP/900 RPM	\$	\$
277	1.00	EA	0277 - Electric Motor, Stator Rewind, 2300 Volts  3000 HP/900 RPM	\$	\$
278	1.00	EA	0278 - Electric Motor, Stator Rewind, 4160 Volts  3000 HP/327 RPM	\$	\$
279	1.00	EA	0279 - Electric Motor, Stator Rewind, 2300 Volts  3000 HP/327 RPM	\$	\$
280	1.00	EA	0280 - Electric Motor, Stator Rewind, 4160 Volts  3600 HP/1800 RPM	\$	\$
281	1.00	EA	0281 - Electric Motor, Stator Rewind, 2300 Volts  3600 HP/1800 RPM	\$	\$
282	1.00	EA	0282 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
283	1.00	EA	3600 HP/900 RPM 0283 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
284	1.00	EA	3600 HP/900 RPM 0284 - Electric Motor, Stator Rewind, 4160 Volts	\$	\$
285	1.00	EA	3600 HP/327 RPM 0285 - Electric Motor, Stator Rewind, 2300 Volts	\$	\$
286	1.00	EA	3600 HP/327 RPM 0286 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase, 1/6 HP/3450 RPM	\$	\$
287	1.00	EA	0287 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase, 1/6 HP/1725 RPM	\$	\$
288	1.00	EA	0288 - Recondition Price for Complete Motors, 115-230 Volts Single Phase, 1/6 HP/1140 RPM	\$	\$
289	1.00	EA	0289 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase, 1/4 HP/3450 RPM	\$	\$
290	1.00	EA	0290 - Recondition Price for Complete Motors, 115-230/Volts, Single Phase, 1/4 HP/1725 RPM	\$	\$
291	1.00	EA	0291 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase, 1/4 HP/1140 RPM	\$	\$
292	1.00	EA	0292 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase, 1/3 HP/3450 RPM	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
293	1.00	EA	0293 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1/3 HP/1725 RPM	\$	\$
294	1.00	EA	0294 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1/3 HP/1140 RPM	\$	\$
295	1.00	EA	0295 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1/2 HP/3450 RPM	\$	\$
296	1.00	EA	0296 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1/2 HP/1725 RPM	\$	\$
297	1.00	EA	0297 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1/2 HP/1140 RPM	\$	\$
298	1.00	EA	0298 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  3/4 HP/3450 RPM	\$	\$
299	1.00	EA	0299 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  3/4 HP/1725 RPM	\$	\$
300	1.00	EA	0300 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  3/4 HP/1140 RPM	\$	\$
301	1.00	EA	0301 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1 HP/3450 RPM	\$	\$
302	1.00	EA	0302 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1 HP/1725 RPM	\$	\$
303	1.00	EA	0303 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
304	1.00	EA	1 HP/1140 RPM  0304 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1-1/2 HP/3450 RPM	\$	\$
305	1.00	EA	0305 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1-1/2 HP/1725 RPM	\$	\$
306	1.00	EA	0306 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  1-1/2 HP/1140 RPM	\$	\$
307	1.00	EA	0307 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  3 HP/3450 RPM	\$	\$
308	1.00	EA	0308 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  3 HP/1725 RPM	\$	\$
309	1.00	EA	0309 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  3 HP/1140 RPM	\$	\$
310	1.00	EA	0310 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  5 HP/3450 RPM	\$	\$
311	1.00	EA	0311 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  5 HP/1725 RPM	\$	\$
312	1.00	EA	0312 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  5 HP/1140 RPM	\$	\$
313	1.00	EA	0313 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  7-1/2 HP/3450 RPM	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
314	1.00	EA	0314 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  7-1/2 HP/1725 RPM	\$	\$
315	1.00	EA	0315 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  7-1/2 HP/1140 RPM	\$	\$
316	1.00	EA	0316 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  10 HP/3450 RPM	\$	\$
317	1.00	EA	0317 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  10 HP/1725 RPM	\$	\$
318	1.00	EA	0318 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  10 HP/1140 RPM	\$	\$
319	1.00	EA	0319 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase  15 HP/3450 RPM	\$	\$
320	1.00	EA	0320 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  15 HP/1725 RPM	\$	\$
321	1.00	EA	0321 - Recondition Price for Complete Motors, 115-230 Volts, Single Phase,  15 HP/1140 RPM	\$	\$
322	1.00	EA	0322 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1/6 HP/3450 RPM	\$	\$
323	1.00	EA	0323 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1/6 HP/1725 RPM	\$	\$
324	1.00	EA	0324 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
325	1.00	EA	1/6 HP/1140 RPM 0325 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
326	1.00	EA	1/4 HP/3450 RPM 0326 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
327	1.00	EA	1/4 HP/1725 RPM 0327 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
328	1.00	EA	1/4 HP/1140 RPM 0328 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
329	1.00	EA	1/3 HP/3450 RPM 0329 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
330	1.00	EA	1/3 HP/1725 RPM 0330 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
331	1.00	EA	1/3 HP/1140 RPM 0331 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
332	1.00	EA	1/2 HP/3450 RPM 0332 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
333	1.00	EA	1/2 HP/1725 RPM 0333 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
334	1.00	EA	1/2 HP/1140 RPM 0334 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
			3/4 HP/3450 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
335	1.00	EA	0335 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  3/4 HP/1725 RPM	\$	\$
336	1.00	EA	0336 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  3/4 HP/1140 RPM	\$	\$
337	1.00	EA	0337 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1 HP/3450 RPM	\$	\$
338	1.00	EA	0338 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1 HP/1725 RPM	\$	\$
339	1.00	EA	0339 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1 HP/1140 RPM	\$	\$
340	1.00	EA	0340 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1-1/2 HP/3450 RPM	\$	\$
341	1.00	EA	0341 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1-1/2 HP/1725 RPM	\$	\$
342	1.00	EA	0342 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  1-1/2 HP/1140 RPM	\$	\$
343	1.00	EA	0343 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  3 HP/3450 RPM	\$	\$
344	1.00	EA	0344 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  3 HP/1725 RPM	\$	\$
345	1.00	EA	0345 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
346	1.00	EA	3 HP/1140 RPM  0346 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
347	1.00	EA	5 HP/3450 RPM  0347 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
348	1.00	EA	5 HP/1725 RPM  0348 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
349	1.00	EA	5 HP/1140 RPM  0349 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
350	1.00	EA	7-1/2 HP/3450 RPM  0350 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
351	1.00	EA	7-1/2 HP/1725 RPM  0351 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
352	1.00	EA	7-1/2 HP/1140 RPM  0352 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
353	1.00	EA	10 HP/3450 RPM  0353 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
354	1.00	EA	10 HP/1725 RPM  0354 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
355	1.00	EA	10 HP/1140 RPM  0355 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,	\$	\$
			15 HP/3450 RPM		

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
356	1.00	EA	0356 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  15 HP/1725 RPM	\$ _____	\$ _____
357	1.00	EA	0357 - Rewind Price for Complete Motors, 115-230 Volts, Single Phase,  15 HP/1140 RPM	\$ _____	\$ _____
358	1.00	EA	0358 - Furnish and Install Nameplate	\$ _____	\$ _____
359	250.00	HR	0359 - Machinist, with Tools Hourly Labor Rates  The Above Unit Labor Rates shall be listed on Regular Time Basis. Overtime Rate shall be 1.5 Times the Regular Rate in Accordance with Section 7 of the Specifications.  Reference Specifications Section 8, A.	\$ _____	\$ _____
360	1.00	HR	0360 - Welder, with Tools and Materials, Hourly Labor Rates  The Above Unit labor Rates shall be listed on a Regular Time Basis. Overtime Rate shall be 1.5 Times the Regular Rate in Accordance with Section 7 of the Specifications.  Reference Specifications Section 8, A	\$ _____	\$ _____
361	4,000.00	HR	0361 - Electrician Technician Hourly Labor Rates  The Above Unit Labor Rates shall be listed on a Regular Time Basis. Overtime Rate shall be 1.5 Times the Regular Rate in Accordance with Section 7 of the Specifications.  Reference Specifications Section 8, A.	\$ _____	\$ _____
362	2,000.00	HR	0362 - General Labor Hourly Labor Rates  The Above Unit Labor Rates shall be	\$ _____	\$ _____

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
			<p>listed on a Regular Time Basis. Overtime Rate shall be 1.5 Times the Regular Rate in Accordance with Section 7 of the Specifications.</p> <p>Reference Specifications Section 8, A.</p>		
363	1.00	HR	<p>0363 - Additional Equipment (as per Section 11)</p> <p>Cherry Picker with Operator and Fuel</p>	₹	₹
364	1.00	HR	<p>0364 - Additional Equipment (as per Section 11)</p> <p>Bucket Truck with Operator and Fuel</p>	₹	₹
365	1.00	LO	<p>0365 - Parts/Materials for Third Party Invoice</p> <p>Parts/Materials/furnished by the Contractor will only be paid at the Contractor's actual cost and shipping. A copy of the Vendor's Supplier Invoice proving cost must be attached to the Vendor's Invoice Billing JP. Jefferson Parish has the option to furnish the Parts/Materials required to the Contractor.</p> <p>Note: This item shall not be included in the total Bid price of all items quoted and is to FBE used as a reference to process invoices by Purchasing Division upon the authorization by the Council via the Resolution prepared for the Bid award. The lump sum amount of this item is not given herein. However, this lump sum amount will be indicated in said Resolution.</p> <p>No quote is required and accordingly designated underline spaces for unit price and the corresponding total shall be left blank.</p>	₹	₹
366	1.00	HR	<p>0366 - Machinist with Tools - Overtime Rate of Time and a Half</p> <p>of Hourly Rate From Item 3020</p>	₹	₹
367	1.00	HR	<p>0367 - Welder with Tools - Overtime Rate of Time and a Half of</p> <p>Hourly Rate From Item 3030</p>	₹	₹

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
368	1.00	HR	0368 - Electrical Technician - Overtime Rate of Time and a Half of  Hourly Rate From Item 3040	\$ _____	\$ _____
369	1.00	HR	0369 - General Labor - Overtime Rate of Time and a Half of Hourly  Rate From Item 3050	\$ _____	\$ _____
370	1.00	DA	0370 - Storage Fee After 10 Day Written Notice of Estimate  Flat Fee of 5.00 dollars per Working Day	\$ _____	\$ _____
371	1.00	EA	0371 - TEFC Motor (Special Motor Adder)  A. The Maximum Final Invoice amount for item shall not exceed 10 Percent of the Standard Motor Base Rewind price.	\$ _____	\$ _____
372	1.00	EA	0372 - Explosion Proof Motor (Special Motor Adder)  A. The Maximum Final Invoice amount for item shall not exceed 15 Percent of the Standard Motor Base Rewind price.	\$ _____	\$ _____
373	1.00	EA	0373 - Vertical Motor (Special Motor Adder)  A. The Maximum Final Invoice amount for item shall not exceed 15 Percent of the Standard Motor Base Rewind price.	\$ _____	\$ _____
374	1.00	EA	0374 - U Frame (Special Motor Adder)  A. The Maximum Final Invoice amount for item shall not exceed 15 Percent of the Standard Motor Base Rewind price.	\$ _____	\$ _____
375	1.00	EA	0375 - Pre-U Frame (Special Motor Adder)  A. The Maximum Final Invoice amount for item shall not exceed 40 Percent of the	\$ _____	\$ _____

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
376	1.00	EA	<p>Standard Motor Base Rewind price.</p> <p>0376 - Pump, Gear Motor Plus Pump, Gear Assembly (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for Item shall not exceed 25 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
377	1.00	EA	<p>0377 - Submersible Pump (Complete), Re-Pour Pot - Head When Necessary (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for Item shall not exceed 30 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
378	1.00	EA	<p>0378 - Submersible Pump (Stator W/Housing), Re-Pour Pot Head When Necessary (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shall not exceed 20 Percent of the Standard Base Rewind price.</p>	\$ _____	\$ _____
379	1.00	EA	<p>0379 - Two Speed Motor (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shall not exceed 50 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
380	1.00	EA	<p>0380 - Form Coils (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shall not exceed 55 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
381	1.00	EA	<p>0381 - Epoxy Coil Coating (Special Motor Adder)</p> <p>A. the Maximum Final Invoice amount for item shall not exceed 12 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
382	1.00	EA	<p>0382 - Epoxy Encapsulation, Formed or Molded (Special Motor Adder)</p>	\$ _____	\$ _____

## INVITATION TO BID FROM JEFFERSON PARISH - continued

BID NO.: 50-00147735

SEALED BID

ITEM NUMBER	QUANTITY	U/M	DESCRIPTION OF ARTICLES	UNIT PRICE QUOTED	TOTALS
383	1.00	EA	<p>A. The Maximum Final Invoice amount for item shall not exceed 50 Percent of the Standard Motor Base Rewind price.</p> <p>0383 - Rewind Rotor of Wound Rotor Induction Motor (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shall not exceed 80 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
384	1.00	EA	<p>0384 - If Motor is T.E.F.C., Vertical and U-Frame (Specail Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shll not exceed 15 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
385	1.00	EA	<p>0385 - If Motor is T.E.F.C., and Vertical (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shall not exceed 15 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
386	1.00	EA	<p>0386 - If Motor is Explosion Proof and U-Frame (Special Motor Adder)</p> <p>A. The Maximum Final Invoice amount for item shall not exceed 15 Percent of the Standard Motor Base Rewind price.</p>	\$ _____	\$ _____
387	1.00	EA	<p>0387 - Overtime Work (Ea.) (Special Motor Adder)</p> <p>A. Overtime Work associated with Special Motors shall be bid at a Special Hourly Rate with the Maximum Final Invoice amount not exceeding 50 Percent of the Standard Motor Base Rewind price.</p> <p>Note: One (1) Special Motor item allowed per Motor Repair except for Overtime Item No. 3690 where applicable</p>	\$ _____	\$ _____

# **SPECIFICATIONS AND PROPOSAL GUIDE FOR ELECTRIC MOTOR REPAIRS**

## **A TWO (2) YEAR CONTRACT FOR ELECTRIC MOTOR REPAIRS FOR THE JEFFERSON PARISH DEPARTMENT OF PUBLIC WORKS - SEWERAGE AND ALL JEFFERSON PARISH AGENCIES AND MUNICIPALITIES**

### **BOND:**

#### **Surety Bond:**

A surety bond in the amount of \$500.00 of the total bid is required with bid submission.

#### **Performance Bond:**

A performance bond will be required for this bid. The performance bond in the amount of \$100,000.00 shall be supplied at the signing of the contract.

#### **Payment Bond:**

A Labor and Materials payment bond will be required for this bid. The payment bond in the amount of \$150,000.00 shall be supplied at the signing of the contract.

### **1. SCOPE**

This specification sets forth the requirements for inspection, testing, reconditioning, rewinding and related repair work of and for electric motors for all departments of Jefferson Parish.

### **2. GENERAL CONDITIONS AND REQUIREMENTS**

Firm bids are requested from qualified electric motor repair service contractors who are Underwriters Laboratories (UL) listed and who are competent with the electrical, mechanical and physical make up and operation of electric motors as may be required on motors owned by Jefferson Parish.

The performance bond shall be structured to cover and apply from the date of contract execution through the applicable end of warranty period.

The terms and conditions of resolution 136353, as amended, will be considered a part of the bid whether attached or not. A copy may be obtained from the office of the Parish Clerk, General Government Building, Suite 6700, Gretna, Louisiana 70053.

All prices quoted shall encompass pick-up and delivery of motors from the East and West Bank warehouses, except as noted in Section 11. Quotes shall also include the Estimate of Repair, all necessary repairs as needed, and the

preparation of all necessary repair and transmittal report forms as attached herewith.

The regular Jefferson Parish work day schedule shall be from 7:00 A.M. to 5:00 P.M., Monday through Friday. All work performed during the time period shall be performed on a straight time basis. Overtime will apply only when work is performed on weekends, Jefferson Parish legal holidays or before 7:00 A.M. and after 5:00 P.M. Authorization for overtime work shall be obtained by procedures established in Section 7.

Contractors should be aware that adherence to this specification at the time of bid opening is necessary, and that future changes in repair procedures and/or facilities will not be accepted in lieu of compliance at the time of bid opening.

Under no circumstances should contractors assume that there will be the opportunity for multiple motor repairs in a given H.P. / R.P.M. range. Such multiple repairs in a given H.P. / R.P.M. range cannot be anticipated or predicted and therefore any bid price discounts for such multiple motor repairs are not allowed nor acceptable. This is a unit price contract.

The cost of a motor repair shall be paid at the unit price of a listed motor in the nearest HP and RPM range.

Contractor must be able to respond to any request and be on site within one hour of said request.

### 3. WARRANTY AND PERFORMANCE BOND

The contractor shall warrant that all work performed under this contract shall be performed in a good and workmanlike manner, that all materials furnished shall be of good merchantable quality and that the contractor's performance shall be free of defects. All repair work shall be guaranteed for a period of one year from date of completion of repair. Any failure during the warranty period resulting from defective material and/or poor workmanship shall be repaired at the expense of the contractor, F.O.B. Jefferson Parish's facility.

### 4. AUDIT OF CONTRACT

Jefferson Parish, its employees, and/or its appointees reserve the right to audit the contractor's books at any time during the contract period for any matters relating to contractor's billing for payment by Jefferson Parish. Additionally, contractor agrees to maintain such books and records for a period of three years from the date such costs were incurred by Jefferson Parish and to make those books and records available to Jefferson Parish at any reasonable time within the three-year period.

### 5. TERMINATION AND BREACH OF CONTRACT

This section is in addition to any other termination rights in the bid or resolution No. 136353

Should the contractor breach any provision of this contract, Jefferson Parish reserves the right to notify the contractor of the deficiency or deficiencies in writing and contractor shall be given the opportunity to correct such deficiency or deficiencies within the time constraints as per Section 6. Time for performance under this provision shall begin upon certified mail notification. After notification of deficient performance, Jefferson Parish reserves the right to cancel this contract. Notice of contract cancellation shall be given to the contractor in writing. Jefferson Parish shall have the right to cease forwarding motors to the contractor for repair, and remove all motors currently in the contractor's possession at that time. The failure of Jefferson Parish to assert a breach of contract for the failure of the contractor to perform at any time shall not be construed to be a waiver of Jefferson Parish's rights hereunder.

## 6. REPAIR COMPLETION TIME AND LIQUIDATED DAMAGES

All motor repairs shall be completed within the following time periods subject to the provisions of Section 11:

Recondition:

1/2 H.P. – 75 H.P.	4 working days
100 H.P. and up	5 working days

Rewind:

1/2 H.P. – 75 H.P.	5 working days
100 H.P. and up	6 working days

For coil wound motors 10 working days

Contractor assumes all responsibility to ensure that repairs are completed within the above time periods. Any deviation shall be explained by the contractor in writing and attached to the billing invoice. Failure on the part of the contractor to provide justification for delay as well as poor explanation for delay, as determined by Jefferson Parish shall result in actions as outlined in Section 5.

Liquidated Damages will be assessed against the billing invoice in the amount of fifty dollars (\$50.00) per day for each and every working day beyond the repair completion times as listed above for unjustified delays in the completion on repairs.

## 7. OVERTIME

In the event of overtime, emergency, repairs are required, the contractor will be required 24 hours/day, seven days a week to repair the motor.

Overtime repair work shall be authorized in the event of severe weather conditions, threats to continuity of public utility service or other extraordinary circumstances as deemed necessary by Jefferson Parish. Under no circumstance shall the contractor assume overtime work without written authorization as indicated on the Electric Motor Repair Request Form, Attachment B (page 202), or verbal authorization by a representative of Jefferson Parish. Verbal authorization shall be noted on the Electronic Motor Repair Data Sheet, Attachment B (page 201), and attached to the contractor's billing invoice.

Overtime rate shall be paid in accordance with the percentage adder as indicated in Section 23 if the additional specs. The percentage of base rewind or recondition price shall be paid to the contractor for work performed during the normal business hours as well as Jefferson Parish legal holidays, weekdays, or before or after normal business hours in order to expedite repair work for justifiable reasons as noted previously. However, overtime labor rates shall be paid only for actual hours worked on holidays, weekends, or before or after normal business hours. The contractor assumes the responsibility to document overtime labor hours by submitting a copy of the relevant employee's shop time card, complete with the date and the employee's job title, as evidence of overtime. This documentation shall be attached to the contractor's billing invoice for payment by Jefferson Parish.

Under no circumstances will the contractor be paid overtime rates for the acquisition or procurement of repair materials.

## 8. SUBCONTRACTORS

The contractor may complete his bid by the utilization of subcontractors; however, no payment will be made by Jefferson Parish to the subcontractor for any work performed under the terms of this contract. The contractor assumes all responsibility for the work performed by his subcontractors. The cost of any incidental drayage between the contractor and his subcontractor shall be absorbed by the unit bid prices and the time required therefore will not be considered as work time for payment. Under the terms of this contract, subcontractor effort shall be limited to a maximum of thirty percent (30%) of total work performed. Additionally, all subcontract work shall be governed by all provisions of this contract.

Special circumstance: in the rare event that frame restacking becomes necessary as confirmed by the contractor, Jefferson Parish Inspector, and as evidenced by a core loss repair, then Jefferson Parish will direct the contractor to subcontract such restacking repair work to a third-party invoice. Inspection requirements for frame restacking subcontractors will be the same as those required elsewhere in this specification.

## 9. ESTIMATE OF REPAIR

Under the terms of this contract, contractor shall provide a written estimate of repairs for all motors which are sent to him. These estimates will be used as an input to Jefferson Parish's financial management system as well as to determine the economic feasibility of repairing a particular motor. A copy of this Motor Repair Estimate is attached herein, Attachment B (page 203). If the decision not to repair the motor is made, Jefferson Parish reserves the option to retain motors deemed not repairable. If the motor is to be repaired, the contractor will be paid according to his base unit repairs price for rewind or recondition. There will be no payment made to the contractor for the preparation and submittal of estimates.

Storage fees- the contractor will be allowed to charge storage fees for motors which have a written estimate of repair, Attachment B (page 203). The relevant departmental personnel have been contracted but authorization has not been given to repair the motor. Said charges shall begin ten working days after date of

estimate. Storage fees will be five dollars per working day and will be added to the contractors billing invoice as stated in line-item no. 0370.

Estimates shall be prepared utilizing the unit price of a motor in the nearest HP and RPM range.

#### 9.1 ESTIMATE OF REPAIR (WARRANTY)

Should a warranty repair request be necessary, the contractor will be required to provide a written estimate for repairs, documenting the nature of the failure and what will be done to remedy the failure. Additionally, the contractor must contact the relevant departmental personnel to arrange a meeting to discuss repairs prior to any work being done.

### 10. PAYMENTS TO CONTRACTORS

The contractor shall submit all invoices to the Jefferson Parish Engineering Department, c/o Contract Administrator, 1221 Elmwood Park Blvd., Suite 801, Harahan, LA 70123. Invoices will be checked and verified for accuracy and compliance with the terms of this contract. Any errors may be discussed via telephone with the contractor and corrections will be made either on the invoice received or by the submission of a new invoice by the contractor, whichever is agreeable to both Jefferson Parish and the contractor. All invoices shall contain the following:

- A. Contractor's invoice in triplicate
- B. Contractor's dray ticket
- C. Electric Motor Repair Request Form
- D. Electric Motor Data Sheet, completed in its entirety, signed by the contractor and Jefferson Parish inspector or superintendent
- E. Motor Repair Estimate Sheet
- F. Electric Motor Data Sheet and Mechanical Data sheet, pages 204 and 205, are to be completed whenever tests are indicated, specified, or performed
- G. Valid material invoices from third parties with verifiable tracking numbers for audit purposes, supply vendors, subcontractors, UL charges
- H. Copy of employee's time card, for overtime labor verification
- I. Service call time sheet or sheets for labor at field locations. The time sheet or sheets shall be signed by the appropriate Jefferson Parish authority for each contractor's employee for each day or partial day's work at each location. Multiple employees and/or multiple day sheets will not be allowed for payment.

Invoices which received without all proper documentation will be returned to the contractor or held until such documentation is received.

Invoices submitted covering work not addressed under the terms of this contract will not be paid and will be returned to the contractor.

Invoices for payment on complete and accepted work shall be submitted within or before thirty days from date of delivery or pick-up. There will be no partial payments made to the contractor for work in progress. Payment terms shall be net 60 days.

## 11. TRANSPORTATION

Contractor shall pick up motors from and deliver motors to the east and west bank warehouses. The pickup time shall be within four working hours from the time of notification. See Section 2 for normal working hours. The contractor shall be paid labor time for removal, pickup, delivery, and installation of large motors requiring lifting equipment at the field location of the motor in accordance with hourly rates quoted by the contractor in Bid Item Numbers 0359 and 0362.

Additionally, contractor shall list equipment rental rates necessary to remove and install large motors in the field, Bid Item Numbers 0363 and 0364. All equipment not listed which is utilized by the contractor shall be paid at the contractor's actual rental cost as a third-party invoice. In the event of emergency, overtime, or for convenience, Jefferson Parish personnel may deliver and/or pick up motors at contractor's repair facility.

## 12. INSPECTION

Jefferson Parish personnel, or their appointee, reserve the right to visit contractor's repair facility, without notice, to inspect any motor repair process in progress, at any time, during normal business hours or after hours, overtime repairs only, for the duration of the contract.

A Jefferson Parish Inspector will be visiting the contractor's shop on a regular basis to monitor work in progress on Jefferson Parish motors and to sign off on the Motor Repair Data Sheet, Attachment B (page 201), upon completion of repairs.

## 13. REPAIR VERIFICATION

Jefferson Parish reserves the right to appoint an independent motor repair shop to disassemble and verify that repairs performed by the contractor were done in proper fashion. At such time, the contractor, or his representative, shall have the opportunity to be present for such verification. Upon examination of discrepancies between the work which was claimed by the contractor to have been done, based on the information contained on the Electric Motor Data Sheet, and actual findings will be dealt with as outlined in Section 5.

## 14. REPAIR DOCUMENTATION AND TRANSMITTAL FORMS

The following forms/reports shall be completed as requested and/or needed in order to facilitate smooth and orderly work progression:

- A. Electric Motor Repair Request Form, Attachment B (page 202): to be completed by Jefferson Parish personnel, warehouse personnel or department superintendent, Section 15, at the time of motor failure. Contractor shall not begin repair of any motor until he has this request form in his possession.
- B. Motor Repair Estimate Sheet, Attachment (page 201): to be completed by the contractor in accordance with Section 9. Upon completion, contractor shall contact either the respective warehouse or superintendent listed in section 15 for authority to proceed with repair or not to repair the motor.

- C. Electric Motor Data Sheet, Attachment (page 201): to be completed and signed by the contractor and Jefferson Parish Inspector upon completion of repairs. One copy is to be returned with the repaired motor and a second copy is to be attached to the contractor's billing invoice.
- D. Electric Motor Data Sheet and Mechanical Data Sheet, Attachment (page 204 and 205): are to be completed whenever tests are indicated, specified or performed to verify that these tests have been performed. Additionally, the contract administrator may require the signature of the Jefferson Parish Inspector for verification purposes.
- E. Contractor's dray ticket: to be filled out by the contractor for his own use within his shop, with one copy attached to his billing invoice with acceptance signature of Jefferson Parish's representative.

## 15. CONTACT PERSONNEL

After contract award, the successful contractor will be given a list of contact personnel for the various departments within Jefferson Parish who will utilize this contract.

The contractor must appoint at least one contact person who will interface with Jefferson Parish personnel and who must be familiar with all aspects of this contract, including repair procedures, status of motors being repaired, paperwork submittals, and invoice billing. The contact person must be available at all times during normal business hours, as well as be able to be contacted for emergency situations after hours.

After contract award, contractor shall submit the name or names of their contact person or persons. Information submitted must include phone numbers, fax numbers, and e-mail addresses.

## 16. FACILITIES

The following equipment shall be available and properly maintained by the contractor or subcontractor, if used, in accordance with Section 8.

- A. Test facilities for 4160 voltages
- B. Two tank VPI system, vacuum pressure impregnation, for varnish resin systems only. For contractors utilizing DIP tank impregnating resin systems as manufactured by Epoxylite, Esterlite number 605, technical service bulletin number 605 shall be followed. Other manufacturer's product and procedures shall be on an approved equal basis. Both systems shall be capable of P to A 1000 H.P. motor.
- C. Electronic static and dynamic balancing equipment to accommodate motor size up to 700 H.P.
- D. Machinery for rebabbiting bearings
- E. Burning oven capable of maintaining constant burning temperature up to 800 degrees Fahrenheit max. Oven shall be equipped with water quenching device to prevent temperature runaway.
- F. Baking oven to accommodate motors up to 1000 H.P.
- G. Adequate Hi-Pot facility, surge tester, and core loss tester
- H. An FFT, Fast Fourier Transform, type vibration analyzer with 400 lines of resolution or greater and a frequency range of 0.4 x running speed to

2000 HZ the transducer shall be either the velocity type or the accelerometer type with a magnetic mount, hand held pickups are not acceptable.

## 17. REPAIR MATERIALS

Repair materials which are used on the job shall be paid at the contractor's wholesale unit cost without mark up or increase. These third-party invoices shall be attached to the contractor's billing invoice for payment. Materials approved for payment are items such as bearings, seals, in-line splice kits, gaskets, heater strips, etc. Items which will not be allowed for payment are shop supplies common to many motors such as O- Rings, glue, tape, nuts, bolts, oil, etc. This contract is a labor-intensive type contract; therefore, contractors should consider all matters of labor and overhead and build his or her necessary profit into his or her prices for rewinding and reconditioning of motors.

All repair materials used to replace worn or damaged parts shall be new, i.e., not used, and be of equal or better quality as original parts.

Jefferson Parish reserves the right to supply repair materials to the contractor when it is deemed to be in the best interest of Jefferson Parish.

All worn and damaged parts, including bearings, which are replaced shall be tagged and returned with the repaired motor and also be listed on the billing invoice as having been returned. If the contractor does not return the replaced parts, including bearings, he will not be paid for the replacement parts.

Additionally, the contractor agrees to tag and store the crown of every rewind job in a suitable location on his or her premises for 13 months from date of the invoice and allow Jefferson Parish employees or their appointees' access to these crowns. After this time period has expired, the crowns become the property of the contractor.

## 18. MOTOR RECONDITIONING

General:

Motor reconditioning, see Section 24 for percentage of rewind prices, shall be performed in accordance with the relevant manufacturer's specifications and procedures for each and every motor unless otherwise specified. Reconditioning shall include but not necessarily be limited to disassembly, cleaning, mechanical and electrical inspection, varnish treating windings, baking, replace bearings if necessary, check balancing, check coupling, greasing, assembly, testing and painting.

In the case of UL listed motors, the contractor shall contact relevant department for instructions as to whether or not to repair the motor in accordance with UL procedures. Jefferson Parish will pay to the contractor all usual and customary UL charges for inspection services.

Motor Preliminary Inspection and Testing:

Visually inspect all components, test stator for core loss, report stator damage and any core loss greater than 10 percent of original design.

The insulation resistance of all windings shall be measured and recorded as follows:

Use a 500-volt insulation resistance tester, megger for all 480-volt motors, and measure this insulation resistance turn to ground.

#### Rotor Reconditioning:

Steam clean, and dry by heating in oven.

If the rotor core laminations are found damaged, loose and/or shorted, they shall be repaired. Minor repair shall consist of separating the lamination and filling with mica and a class H varnish, etching, and hand filing. Major damage may require restacking of lamination. Hot spots shall be repaired. The hot spot temperature shall not be allowed to exceed 10 degrees Celsius above the average temperature.

Visually inspect for damage to air fans. If any exists, repair prior to varnishing the rotor.

Check rotor bars and resistance rings, for cage rotors, for open circuit by either a growler or a sonic test. Rotor bar movement, if minimal, shall be corrected by giving the rotor a bonding resin treatment and curing. Glass banding will also be considered for restricting bar movement.

At the conclusion of repairs, a dye penetrate shall be used over the short-circuiting ring to inspect for cracked bars.

Additional repairs, if required, shall be done prior to the rotor being sprayed with a coat of an air-drying varnish. If openings are found in an aluminum cast rotor, the rotor shall be replaced.

Collector rings shall be examined for pitting, roundness and burning. Perform repairs, if required, otherwise polish the rings by strapping. Do not use emery paper.

The end ring connections to the rotor bars must be of such quality that uniform resistance and continuity is maintained.

#### Stator Reconditioning:

The acceptable values for insulation resistance to ground are shown below:

Motor Voltage in Volts AC	Test Voltage in Volts DC	Resistance (1 min.) in Megohms
480	500	15
2300	2500	25
4160	5000	50

If the megger readings obtained from the stator are higher than the above minimum values and the polarization index (P.I.) is greater than 2, Hi-Pot test the winding to ground at 0.6 (2E plus 1000) volts AC for one minute.

Note: whenever a stator alone is to be high-potted prior to assembling the motor, the test shall be done either with the end windings wrapped with aluminum foil and the foil grounded.

Perform a three-phase balance test at about one-fifth rated voltage. Line currents should balance within 2-5 percent (depending on the motor size).

Steam clean to remove oil, grease, salt, and other unwanted deposits from windings. Do not pressure wash.

Dry the windings by heating it in an oven for 4-6 hours at about 200 degrees Fahrenheit. Visually inspect for signs of physical damage and/or deterioration to the winding, core lamination and other abnormalities. Inspect all machine and mating surfaces to make sure they are free of nicks, burrs, and all other foreign material.

Core lamination damage or shorts, if any exist, can be repaired either by etching, hand filing or separating lamination and filling the interspace with mica and a class H insulating varnish. Major damage may require restacking/replacing the lamination. A core test shall invariably be performed on all motors. A core loss in excess of ten percent shall be reported on the Motor Repair Estimate Sheet (page 203) and Motor Repair Data Sheet (page 201). Hot spot temperature shall not be allowed to exceed 10 degrees Celsius above the average core temperature.

All broken ties, blocks and wedges shall be replaced. The loose blocks and wedges shall be tightened using an approved adhesive with a filler material or replaced in kind.

Inspect and clean ventilation passages.

Inspect the terminal leads for damage.

Deterioration and/or burning. All leads shall be marked in accordance with NEMA standard and be EXAR or equal. Leads shall be a minimum of one foot long of stranded copper cable and shall be sufficient durability to withstand moist environment.

Connectors shall be inspected for damage and/or burning signs. The damaged and/or burnt connectors shall be replaced with those having the following characteristics:

Suitable for either aluminum and/or copper cables

Suitable for compression filled with Penetrox in their barrels. Solder type connectors shall not be used.

Have two holes in the tongue area.

Have inside diameter of the barrel equal to outside diameter of the lead.

Nicks and burrs from the machined surfaces shall be removed by carefully filing them. All the rust shall be removed from the motor body either by sanding, using an approved solvent or strapping.

Heaters and their wiring shall be checked for proper insulation level (a few megohms at 500-volt megger), tight connections and open circuiting of the heaters. Repair if damage or deterioration is present.

After the above work has been completed, treat the motor with a coat of baking type H varnish or class H impregnating resin as manufactured by Epoxylite (Esterlite number 605) as outlined in Epoxylite's technical bulletin number 605 or approved equal.

Retest the insulation resistance to ground together with P.I. test for the minimum acceptable values as listed previously.

If satisfactory values are attainable, perform a hi-pot test on assembled motor for one minute at 0.6 (2E plus 1000) volt AC and record the leakage currents. The hi-pot test on the assembled motor is required to ascertain the insulation was not damaged during the assembly.

If there is no significant insulation resistance improvement and if the reading remains less than the minimum values then the stator shall be rewound (see Section 19).

## 19. MOTOR REWINDING

### General:

Motor rewinding shall be performed in accordance with the relevant manufacturer's specifications and procedures for each and every motor unless otherwise specified. Rewinding shall include but not necessarily be limited to disassembly, cleaning, removal of old windings, mechanical and electrical inspection, rewinding with class H insulation, one dip and bake for 75 H.P. and smaller V.P.I. dip and bake for 100 H.P. and larger followed by a second dip and bake (including all form coil wound motors), machine work (if necessary) and other parts, greasing, new leads (included in rewinding price), assembly, testing and painting.

Nameplate: In the event of winding change, the original nameplate will remain on the motor and a new nameplate mounted adjacent to the original nameplate with the words REDESIGNED or CHANGED and then the new characteristics are to be stamped fully and completely on the new nameplate.

This new nameplate should also state the name of the company who originated or engineered the new characteristics.

In the event that a motor received by the contractor without a nameplate or with a nameplate with data which is not easily readable, then the contractor must replace said nameplate in accordance with the manufacturer's specifications and Bid Item 0358.

Nameplate data must reflect the motor characteristics as repaired, performed and delivered by the contractor and as reflected by the billing invoice and relevant documentation.

In the case of a UL listed motor, the contractor shall contact relevant department for instructions as to or not to repair the motor in accordance with UL procedures. Jefferson Parish will pay all usual and customary UL charges for inspection services. The existing winding shall be completely removed in such a manner that no damage is done to the laminations or frame and without impairing the magnetic characteristics of the core. No torches, chemical strippers, or burners that utilize a direct flame on the stator shall be used. Burning must be done in a temperature-controlled oven capable of maintaining constant burning temperature at no more than 800 degrees Fahrenheit.

The crown of the winding shall be cut for every rewind job and be tagged and stored in a suitable location for the warranty period.

The interior, exterior, and all parts of the motor made of cast iron or steel shall be thoroughly cleaned and sandblasted to white metal prior to rewinding.

All materials used shall be new and of first grade quality. Conductor shall be of the same size as the original or an equivalent cross-sectional area which will not increase the current density. Copper materials shall be the only materials used for rewinding and shall be Phelps Dodge Hapt or approved equal. Connections shall be silver brazed or copper welded. Dine leads may be high temperature soldered.

## 20. STATOR AND WOUND ROTOR REWINDING:

All winding data such as wire size, number of turns, throw of windings, connections, coil dimensions, end bell clearances and lead length etc. shall be recorded prior to stripping off the winding and such records shall be reported with the billing invoice.

The crown of the winding shall be cut for every rewind job and be tagged and stored in a suitable location for the warranty period.

The interior, exterior, and all parts of the motor made of cast Iron or steel shall be thoroughly cleaned and sandblasted to "white" metal prior to rewinding.

All materials used shall be new and of first grade quality. Conductor shall be of the same size as the original or an equivalent cross-sectional area which will not increase the current density. Copper materials shall be the only materials used for rewinding and shall be Phelps, Dodge, Hapt, or approved equal. Connections shall be silver brazed or copper welded. Fine leads may be high temperature soldered.

Old windings shall be roasted out of stator in an oven with adequate temperature controls to provide uniform heating and cooling to prevent warping and cracking of the frame and impairment of the magnetic quality of the core. The burn out shall be done by first maintaining at a temperature of 500 degrees F for 3-4 hours

and then slowly increasing to a temperature of 700 degrees F maximum. The burnout temperature of 700 degrees F shall not be exceeded. Other stripping methods such as water blast or cold strip will be permitted when necessary.

After the winding has been removed from the roasted stator, the laminations will be thoroughly cleaned blowing out with compressed air and removing any remaining foreign matter by hand. The slots shall be clean and free of sharp edges or particles.

All old windings shall be removed and bore frame thoroughly cleaned using bead blast. Use only glass beads.

Laminations shall be inspected for damage. Repairs can be performed either by separating the laminations and filling the interspaces with mica and a class "H" insulation, etching or hand filing. Major damage may require restacking/replacing of the laminations.

The repaired stator shall be ring checked when core damage has occurred, and hot spots corrected.

A core test shall be performed on all motors 50 hp and above prior to rewinding. Hot spot temperature shall not be allowed to exceed 10 degrees C above the average core temperature.

Remove all rust by sanding using an approved solvent or scraping.

Inspect and clean all ventilation passages.

Spray the stator bore area with an air-drying varnish.

Rewinding shall be done using copper wire coils designed for continuous duty. The copper size to be used shall conform to the motor manufacturer's latest specifications.

## 21. BALANCING, RUNNING VIBRATION AND MACHINE WORK

Electronic static and dynamic balancing and vibration testing shall be performed on all motors to assure acceptable vibration levels as specified hereafter. However, there will be no payment made for balancing and vibration testing under the terms of this contract.

Machine and welding work necessary to properly repair motors will be paid to the contractor on an hourly basis for actual work hours performed. The contractor shall quote hourly labor rates as listed in Bid Items 0359-0362. Work deemed by Jefferson parish to be excessive shall be justified in writing by the contractor prior to payment.

Each motor rotor shall be dynamically balanced on an appropriate balancing machine. The rotor balancing precision shall meet an assembled motor running vibration test noted in the next paragraph.

Complete motors shall be assembled and test run after repairs. The maximum

measured vibrational velocity shall not exceed the following:

#### MAXIMUM PERMISSIBLE VELOCITY OF VIBRATION - INCHES PER SECOND

MOTOR ON ELASTIC MOUNTING	MOTOR ON RIDGE MOUNTING	MOTOR SHAFT IN SLEEVE BRS.
OVERALL LEVEL		
0.1	0.15	0.15

#### MAXIMUM PERMISSIBLE VIBRATION LEVELS:

FREQUENCY RANGE	AMPLITUDE (IN/SEC)
1-10 HZ	.06
10-80 HZ	.10
80-150 HZ	.08
150-2000 HZ	.02

All vibration measurements will be made with an FFT (Fast Fourier Transform) analyzer utilizing 400 lines of resolution or greater and a frequency range of 0.4 x running speed of 2,000 hz. Each measurement will consist of 4 averages (linear, non-overlapping) using a hanning window. The transducer used during the test will be either a velocity transducer or accelerometer type transducer with a magnetic mount (hand-held pickups are not acceptable for measurement under this specification).

#### THE BALANCE FOR INTEGRAL HORSEPOWER MOTORS BUILT IN A 153 AND LARGER FRAME SHALL BE AS FOLLOWS:

SOURCE	MAXIMUM
SPEED, RPM*	INCHES+
3,000 - 4,000	0.001
1,500 - 2,999	0.0015
1,000 - 1,499	0.002
999 AND BELOW	0.0025

\* For ac motors use the highest synchronous speed + amplitude as used in this paragraph means total peak to peak displacement.

All rotors and armatures must be centralized laterally on the shaft so as to eliminate end thrust pressure against either bearing and should float between bearings.

Total end play in sleeve bearing motors must be approximately 1/16" per inch diameter of shaft.

## 22. GENERATORS

All generators shall be repaired as motors based on their equivalent horsepower

rating and are to be calculated according to the following formula:

Generator kw = kva x p.f (power factor)

Generator equivalent h.p. = kw x 1.34

The cost of repair of generator equivalent horsepower not listed in the motor bid forms shall be based on the closest motor horsepower listed on these forms.

## 23. INSURANCE

The responsibility of the contractor for damage, theft or loss of motors or generators while in the contractor's possession and/or control shall be as set forth in the Louisiana Civil Code and jurisprudence thereunder for compensated depositories.

Jefferson parish council resolution 136353 (09/16/2020) sets forth the insurance requirements for this contract. Copies are available at the council clerk's office.

## 24. REWINDING SPECIAL MOTORS

When the special motors listed below require repair, the appropriate special motor item shall be used in conjunction with the standard motor base rewind item. Special motor items shall be a percentage of the standard motor price as detailed below:

1. \*T.E.F.C. MOTOR (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 10% of the standard motor base rewind price.
2. \*EXPLOSION PROOF MOTOR (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 15% of the standard motor base rewind price.
3. \*VERTICAL MOTOR (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 15% of the standard motor base rewind price.
4. \*"U" FRAME (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 15% of the standard motor base rewind price.
5. \*PRE-"U" FRAME (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 40% of the standard motor base rewind price.
6. PUMP, GEAR MOTOR PLUS PUMP, GEAR ASSEMBLY (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 25% of the standard motor base rewind price.
7. SUBMERSIBLE PUMP (COMPLETE), RE-POUR POT HEAD WHEN NECESSARY (Special Motor Adder)

- a. The maximum final invoice amount for item shall not exceed 30% of the standard motor base rewind price.
- 8. SUBMERSIBLE PUMP (STATOR W/HOUSING), RE-POUR POT HEAD WHEN NECESSARY (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 20% of the standard motor base rewind price.
- 9. TWO SPEED MOTOR (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 50% of the standard motor base rewind price.
- 10. FORM COILS (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 55% of the standard motor base rewind price.
- 11. EPOXY COIL COATING (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 12% of the standard motor base rewind price.
- 12. EPOXY ENCAPSULATION, FORMED OR MOLDED (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 50% of the standard motor base rewind price.
- 13. REWIND ROTOR OF WOUND ROTOR INDUCTION MOTOR (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 80% of the standard motor base rewind price.
- 14. \*IF MOTOR IS T.E.F.C., VERTICAL AND U-FRAME (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 15% of the standard motor base rewind price.
- 15. \*IF MOTOR IS T.E.F.C. AND VERTICAL (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 15% of the standard motor base rewind price.
- 16. \*IF MOTOR IS EXPLOSION PROOF AND U-FRAME (Special Motor Adder)
  - a. The maximum final invoice amount for item shall not exceed 15% of the standard motor base rewind price.
- 17. OVERTIME WORK (EA) (Special Motor Adder)
  - a. Overtime work associated with special motors shall be bid at a special hourly rate with the maximum final invoice amount not exceeding 50% of the standard motor base rewind price.

NOTE: ONE (1) SPECIAL MOTOR ITEM ALLOWED PER MOTOR REPAIR EXCEPT FOR OVERTIME WORK WHERE APPLICABLE.

## 25. STATOR ONLY WORK

When motor repair work only involves the stator, the final invoice amount shall be 90% of the standard motor base rewind price.

## 26. RECONDITION PRICES

Recondition prices (includes disassembly, cleaning of all parts, sandblasting, dip in class "h" varnish, bake, reassembly and testing, bearings and parts extra) shall be priced as a percentage of rewind stator prices (Items 0001-0285) according to the following hp ranges:

1/3-20	HP	50%
25-125	HP	50%
150-300	HP	40%
350-500	HP	30%

JEFFERSON PARISH  
ELECTRIC MOTOR MECHANICAL DATA SHEET

DATE:	MAKE:	HORSEPOWER:
RPM:	FRAME:	VOLTAGE:
AMPS:	SERIAL NO.:	PHASE:

SHAFT DATA

	BEFORE	AFTER		BEFORE	AFTER
O.E. BEARING FIT			D.E. BEARING FIT		
SHAFT RUNOUT			FAN FIT		
ROTOR FIT			FAN BORE		

REMARKS:

CORRECTIONS:

ROTOR DATA

	BEFORE	AFTER		BEFORE	AFTER
CONDITION OF ROTOR BARS			CONDITION OF END RINGS		
CONDITION OF ROTOR BARS			BALANCE OF ASSEMBLY		

REMARKS:

CORRECTIONS:

BEARING HOUSING

	BEFORE	AFTER		BEFORE	AFTER
O.E. BEARING HOUSING FIT			D.E. BEARING HOUSING FIT		
O.E. BEARING CAP BORE			D.E. BEARING CAP BORE		
O.E. BEARING O.D.			D.E. BEARING O.D.		
O.E. BEARING I.D.			D.E. BEARING I.D.		
O.E. OIL RING I.D. x O.D. x W			D.E. OIL RING I.D. x O.D. x W		
O.E. BEARING No.			D.E. BEARING No.		
ROTOR AXIAL MOVEMENT			END BELL FACE RUNOUT		

REMARKS:

CORRECTIONS:

O.E. Opposite End

D.E.: Drive End



MAKE \_\_\_\_\_ HP/KW/KVA \_\_\_\_\_ RPM \_\_\_\_\_  
CUSTOMER JEPPERSON PARISH MOTOR DATA SHEET JOB NO. \_\_\_\_\_ DATE \_\_\_\_\_

VOLTS \_\_\_\_\_ AMPS \_\_\_\_\_ FRAME \_\_\_\_\_ TYPE \_\_\_\_\_ S/N \_\_\_\_\_

MODEL \_\_\_\_\_ STYLE \_\_\_\_\_ CODE \_\_\_\_\_ FORM \_\_\_\_\_ DESIGN \_\_\_\_\_

SVC. FACTOR \_\_\_\_\_ PHASE \_\_\_\_\_ HERTZ \_\_\_\_\_ °C RISE \_\_\_\_\_ INS. CLASS \_\_\_\_\_

SLOTS _____	GROUPING _____
SPAN _____	NO. LEADS _____
CONN. _____ TOP/SIDE _____	LENGTH OF LEADS _____
TURNS _____	WIRE SIZE & TYPE OF LEADS _____
WIRE SIZE _____	LEAD POSITION INDICATED _____
NO. WIRES _____	_____
STATOR BORE _____	_____
CORE LENGTH _____	HIGH POT @ _____ VOLTS AC/DC _____
COIL TO CORE CONN. END _____	CURRENT READING _____
COIL TO CORE OFF. C/E _____	BALL TEST @ _____ VOLTS _____ AMPS _____



MATERIALS		
Date	Description	Qty.
	Magnet Wire	
	Magnet Wire	
	Wedge	
	Wedge	
	Wedge	
	Wedge	
	Lead Wire	
	Lead Wire	
	Surge Rope	
	Surge Rope	
	Sleeving	
	Sleeving	
	No.	
	No.	
	No.	

JEFFERSON PARISH  
DEPARTMENT OF PUBLIC WORKS

MOTOR REPAIR ESTIMATE

Date\_\_\_\_\_

Time\_\_\_\_\_

Division Dept. \_\_\_\_\_

Motor Location \_\_\_\_\_

Manufacturer \_\_\_\_\_ H.P. \_\_\_\_\_

Serial No. \_\_\_\_\_ R.P.M. \_\_\_\_\_

Model No. \_\_\_\_\_ Volts \_\_\_\_\_

Frame \_\_\_\_\_ Amps \_\_\_\_\_

Phase \_\_\_\_\_

Type (Circle):      Vertical      Horizontal      Submersible

A). Major Repair Procedure:      Rewind      \$ \_\_\_\_\_

Recondition      \$ \_\_\_\_\_

B). Materials: (List) \_\_\_\_\_ \$ \_\_\_\_\_

\_\_\_\_\_ \$ \_\_\_\_\_

\_\_\_\_\_ \$ \_\_\_\_\_

\_\_\_\_\_ \$ \_\_\_\_\_

C). Machine Work:      \_\_\_\_\_ Hrs.      \$ \_\_\_\_\_

Description: \_\_\_\_\_

\_\_\_\_\_

NOTE: If authority to repair motor  
if given, invoice price must  
not exceed estimate

TOTAL \$ \_\_\_\_\_

Contacted: \_\_\_\_\_

Telephone: \_\_\_\_\_

Date: \_\_\_\_\_

Time: \_\_\_\_\_

Estimate Prepared By: \_\_\_\_\_

(Signature)

## ELECTRIC MOTOR REPAIR DATA SHEET

Sig. of J.P. Parish Inspector or Supt.

TABLE 1  
INVENTORY  
SQUIRREL CAGE NAME FRAME MOTORS  
200-575 VOLTS-3 PHASE-60 HERTZ  
COMPLETE MOTOR

H.P.	3600 RPM	1800 RPM	1200 RPM	900 RPM	720 RPM	600 RPM	450 RPM
	N	N	N	N	N	N	N
1/2	0	23	2	0	0	0	0
3/4	1	10	10	3	0	0	0
1	1	15	10	1	0	0	0
1.5	2	13	34	21	1	0	0
2	1	19	20	26	5	2	0
3	1	53	75	14	0	0	0
5	77	100	3	3	0	0	0
7.5	5	59	67	4	0	1	0
10	0	2	39	3	0	0	0
15	2	35	26	9	2	0	0
20	0	37	11	18	6	0	0
25	0	39	15	2	2	0	0
30	0	60	16	4	0	0	0
40	0	2	12	2	0	0	0
50	0	10	1	1	0	0	0
60	0	0	6	3	7	0	0
75	0	7	6	11	4	1	0
100	0	2	10	9	0	0	0
125	0	2	3	5	1	0	0
150	0	0	2	5	2	1	0
200	0	8	10	0	3	2	1
250	0	1	0	0	3	1	0
300	0	0	1	0	0	0	0
350	0	2	8	0	0	0	0
400	0	0	2	0	0	0	0
500	0	0	1	0	0	0	0



# JEFFERSON PARISH

## PURCHASING DEPARTMENT

CYNTHIA LEE SHENG  
PARISH PRESIDENT

RENNY SIMNO  
DIRECTOR



May 2025

### **Changes to Jefferson Parish Bidding Information**

The Jefferson Parish Purchasing Department would like to make vendors aware of the following changes that are now effective:

➤ **Additional Requirements for Bid Instructions:**

The Additional Requirements for Bid Instructions have been revised. The numbers correlating with the instructions may not be the same number as past bids. **Please read ALL instructions and bid documents carefully and thoroughly prior to bid submission.**

➤ **Affidavits:**

There is a new affidavit for all bids named "Generic Bid Affidavit". The Public Works Bid Affidavit and Non-Public Works Bid Affidavit are no longer valid. **The "Generic Bid Affidavit" must be submitted with ALL bid submissions.**

➤ **Insurance Requirements:**

**Within ten (10) days of bid opening, the apparent low bidder will be required to provide FINAL insurance certificates evidencing the insurance coverages of the subject bid (please refer to each individual bid specifications requirements) to Jefferson Parish which shall name "the Parish of Jefferson, its Districts, Departments, and Agencies under the direction of the Parish President and the Parish Council" as additional insured on the Commercial General Liability and the Comprehensive Automobile Liability policies to protect against negligence by the contractor, as provided by contract.**

**Failure to provide your certificate of insurance within the ten (10) days of bid opening shall result in the Parish rejecting your bid as non-responsive and moving on to the next apparent lowest bidder.**

You may still opt to send in your insurance certificates with your bid submission, however, if the provided certificates are not in FINAL form, if you are the apparent low bidder, then you will still be required to send in a FINAL certificate within 10 days of bid opening.

## **STANDARD INSURANCE REQUIREMENTS FOR BIDDING PURPOSES**

All required insurance under this bid shall conform to Jefferson Parish Resolution No. 136353 or No. 141125, as applicable. Contractors may not commence any work under any ensuing contract unless and until all required insurance and associated evidentiary requirements thereto have been met, along with any additional specifications contained in the **Invitation to Bid**. Except as where otherwise precluded by law, the Parish Attorney or her designee, with the concurrence of the Director of Risk Management or her designee, may agree on a case-by-case basis, to deviate from Jefferson Parish's standard insurance requirements, as provided in this Section. **Vendors requesting deviation therefrom shall submit such requests in writing, along with compelling substantiation, to the Purchasing Department prior to the bid's due date.** Any changes to the insurance requirements will be reflected in the bid specifications and addenda. Prior to contract execution and at all times thereafter during the term of such contract, contractors must provide and continuously maintain all coverages as required by the foregoing Resolutions, and the contract documents. Failure to do so shall be grounds for suspension, discontinuation or termination of the contract.

---

**Within ten (10) days of bid opening, the apparent low bidder will be required to provide final insurance certificates to the Parish which shall name the Parish of Jefferson, its Districts Departments and Agencies under the direction of the Parish President and the Parish Council as additional insured on the Commercial General Liability, and the Comprehensive Automobile Liability policies to protect against negligence by the contractor as provided by contract. Failure to provide your certificate of insurance within the ten (10) days, shall result in the Parish rejecting your bid and moving on to the next lowest bidder.** Additionally, said certificates should reflect the name of the Parish Department receiving goods and services and reference the respective Jefferson Parish bid number.

---

### **JEFFERSON PARISH REQUIRED STANDARD INSURANCE**

#### **☒ WORKER'S COMPENSATION INSURANCE**

As required by Worker's Compensation Law of the State of the Contractor's headquarters. Employer's Liability is included, with minimum limits of \$500,000 per occurrence, except it shall be \$1,000,000 per occurrence when Work is to be overwater and involves maritime exposures to cover all employees not covered under the State Worker's Compensation Act.

Waiver of Subrogation endorsement in favor of **the Parish of Jefferson, its Districts Departments and Agencies under the direction of the Parish President and the Parish Council.**

**Note: If your company is not required by law to carry worker's compensation insurance, i.e. sole employee of the company, then bidders must request a**

worker's compensation insurance declaration affidavit prior to the bid opening date. This insurance declaration affidavit must be fully completed, signed, properly notarized within ten (10) days of the bid opening. A scanned copy may be submitted initially; however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.

☒ **COMMERCIAL GENERAL LIABILITY**

Commercial General Liability Form CG 00 01, or pre-approved equivalent; Minimal acceptable limits: \$1,000,000 per occurrence; \$1,000,000 personal & advertising injury; \$2,000,000 general aggregate; and \$2,000,000 products/completed operations aggregate.

Waiver of Transfer of Rights of Recovery Against Others endorsement in favor of the Parish of Jefferson, its Districts, Departments, Agencies and Employees under the direction of the Parish President and the Parish Council.

☒ **BUSINESS AUTOMOBILE LIABILITY**

Minimal acceptable limit for bodily injury and property damage liability: \$1,000,000 Combined Single Limit.

Liability coverage to be provided for Any Auto OR for ALL Owned Autos and Hired and Non-owned Autos. **If contractor owns no vehicles, then a Hired and Non-owned Auto Liability policy is required.**

Waiver of Transfer of Rights of Recovery Against Others to Us endorsement in favor of the Parish of Jefferson, its Districts, Departments, Agencies and Employees under the direction of the Parish President and the Parish Council.

**Note: This category may be omitted if bidders do not/will not utilize vehicles for the project AS DETERMINED BY Risk Management and Parish Attorney's Office after properly requesting a deviation as discussed above. Bidder must request a deviation prior to bid opening and may be given an automobile insurance declaration affidavit to execute. This insurance declaration affidavit must be fully completed, signed, properly notarized and submitted within ten (10) days of the bid opening. A scanned copy of the completed, signed and properly notarized affidavit may be submitted initially; however, the successful bidder must submit the original affidavit in its original format and without material alteration upon contract execution. Failure to comply will result in the bid submission being rejected as non-responsive. The Parish reserves the right to award bid to the next lowest responsive and responsible bidder in this event.**

**DEDUCTIBLES** - The Parish Attorney with concurrence of the Director of Risk Management have waived the deductible section of the Terms and Conditions for all Invitations to Bid, until further notice.

**UMBRELLA LIABILITY COVERAGE** - An umbrella policy or excess may be used to meet minimum requirements. If you are purporting to use an umbrella policy or excess to meet minimum requirements, then you must provide the Umbrella Schedule of Underlying Policies with the Certificate of Insurance evidencing which policies the Umbrella sits over.

**FOR CONSTRUCTION AND RENOVATION PROJECTS:** The following are required if selected below. Such insurance is due upon contract execution.

☐ **OWNER'S PROTECTIVE LIABILITY**

To be for the same limits of liability for bodily injury and property damage liability established for commercial general liability.

☐ **BUILDER'S RISK INSURANCE**

The contractor shall maintain Builder's Risk Insurance at his own expense to insure both the owner (Parish of Jefferson) and contractor as their interest may appear.

## **Generic Bid Affidavit Instructions**

This affidavit is supplied as a courtesy to Affiant. It is the responsibility of the affiant to insure the affidavit submitted to Jefferson Parish complies, in both form and content, with federal, state and parish laws. It is the responsibility of the Affiant to submit a new affidavit if any additional campaign contributions are made after the affidavit is executed but prior to the time the council acts on the matter.

**The Affidavit MUST comply with the following requirements to be accepted.**

- Must be signed by an authorized representative of the entity.
- Must be notarized by a notary with proper jurisdiction who must sign and print name, and include bar/notary number.
- Location where the notarization is taking place should be filled in at the top of the affidavit – not the location of the contract services.
- MUST select either Choice A or B when required.
- If choice A is selected, it must include an attachment.

**Affidavits with the following WILL NOT be accepted.**

- If both choice A and B are selected, the affidavit will not be accepted.
- An affidavit marked N/A will not be accepted.
- An affidavit missing attachment(s) when required will not be accepted.
- An affidavit that is notarized by a notary who does not have jurisdiction in the place where notarized or is not active will not be accepted.
- Affidavits that are older than six (6) months will not be accepted.

*Instruction sheet may be omitted when submitting the affidavit.*

**Generic Bid**

**AFFIDAVIT**

STATE OF \_\_\_\_\_

PARISH/COUNTY OF \_\_\_\_\_

BEFORE ME, the undersigned authority, personally came and appeared:

\_\_\_\_\_ (Affiant) who after being duly sworn by me, deposed and  
said that he/she is the fully authorized \_\_\_\_\_ of  
\_\_\_\_\_ (Entity), who submitted a bid to the Parish of Jefferson.

Affiant further said:

Campaign Contribution Disclosures

**(Choose A or B, if option A is indicated please include the required attachment):**

**Choice A** \_\_\_\_\_ Attached hereto is a list of all campaign contributions, including the date and amount of each contribution, made to current or former elected officials of the Parish of Jefferson by Entity, Affiant, and/or officers, directors and owners, including employees, owning 25% or more of the Entity during the two-year period immediately preceding the date of this affidavit. Further, Entity, Affiant, and/or Entity Owners have not made any contributions to or in support of current or former members of the Jefferson Parish Council or the Jefferson Parish President through or in the name of another person or legal entity, either directly or indirectly.

**Choice B** \_\_\_\_\_ There are **NO** campaign contributions made which would require disclosure under Choice A of this section.

Affiant further said:

Debt Disclosures

**(Choose A or B, if option A is indicated please include the required attachment):**

**Choice A** \_\_\_\_\_ Attached hereto is a list of all debts owed by the affiant to any elected or appointed official of the Parish of Jefferson, and any and all debts owed by any elected or appointed official of the Parish of Jefferson to the Affiant.

**Choice B** \_\_\_\_\_ There are **NO** debts which would require disclosure under Choice A of this section.

Affiant further said:

That Affiant has employed no person, corporation, firm, association, or other organization, either directly or indirectly, to secure the public contract under which he received payment, other than persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project or in securing the public contract were in the regular course of their duties for Affiant; and

That no part of the contract price received by Affiant was paid or will be paid to any person, corporation, firm, association, or other organization for soliciting the contract, other than the payment of their normal compensation to persons regularly employed by the Affiant whose services in connection with the construction, alteration or demolition of the public building or project were in the regular course of their duties for Affiant.

Affiant further said:

Affiant personally has not been convicted of, nor has he/she entered into a plea of guilty or nolo contendere to any of the crimes or equivalent federal crimes listed below. No individual partner, incorporator, director, manager, officer, organizer, or member, who has a minimum of a ten percent ownership in the Bidding Entity, has been convicted of or has entered a plea of guilty or nolo contendere to any of the crimes or equivalent federal crimes listed below. A conviction of or plea of guilty or nolo contendere to the following state crimes or equivalent federal crimes shall permanently bar any person or the bidding entity from bidding on public projects:

- (a) Public bribery (R.S. 14:118)
- (b) Corrupt influencing (R.S. 14:120)
- (c) Extortion (R.S. 14:66)
- (d) Money laundering (R.S. 14:230)

A conviction of or plea of guilty or nolo contendere to the following state crimes or equivalent federal crimes shall bar any person or the bidding entity from bidding on public projects for a period of five years from the date of conviction or from the date of the entrance of the plea of guilty or nolo contendere:

- (a) Theft (R.S. 14:67)
- (b) Identity Theft (R.S. 14:67.16)
- (c) False accounting (R.S. 14:70)
- (d) Issuing worthless checks (R.S. 14:71)
- (e) Bank fraud (R.S. 14:71.1)
- (f) Forgery (R.S. 14:72)
- (g) Contractors; misapplication of payments prohibited (R.S. 14:202)
- (h) Malfeasance in office (R.S. 14:134)

The five-year prohibition provided for in this section shall apply only if the crime was committed during the solicitation or execution of a contract or bid awarded pursuant to these provisions. If evidence is submitted substantiating that a false attestation has been made and the project must be readvertised or the contract canceled, the awarded entity

making the false attestation shall be responsible to the public entity for the costs of rebidding, additional costs due to increased costs of bids and any and all delay costs due to the rebid or cancellation of this project.

Affiant further said:

- (1) Entity is registered and participates in a status verification system to verify that all employees in the State of Louisiana are legal citizens of the United States or are legal aliens.
- (2) Entity shall continue, during the term of the contract, to utilize a status verification system to verify the legal status of all new employees in the State of Louisiana.
- (3) Entity shall require all subcontractors to submit to the Entity a sworn affidavit verifying compliance with statements (1) and (2) above.

\_\_\_\_\_  
Signature of Affiant

\_\_\_\_\_  
Printed Name of Affiant

SWORN AND SUBSCRIBED TO BEFORE ME,  
NOTARY PUBLIC ON THE \_\_\_\_\_ DAY  
OF \_\_\_\_\_, 20\_\_\_\_\_.

\_\_\_\_\_  
Notary Public

\_\_\_\_\_  
Printed Name of Notary

\_\_\_\_\_  
Notary/Bar Roll Number

My commission expires \_\_\_\_\_.

## **Evidence of Authority Instructions**

**Only an authorized Agent shall sign this proposal. Each Proposer is required to provide satisfactory evidence of the authority of the person signing for the agency, corporation, partnership or other legal entity, which shall be attached to the proposal.**

**The following page is a sample Corporate Resolution. This sample is supplied as a courtesy to Proposers, but it is the responsibility of the Proposer to ensure the evidence of authority they submit to Jefferson Parish complies, in both form and content, with federal, state and Parish laws. Additionally, a sample Sole Proprietorship Certification may be found at <https://www.jeffparish.gov/466/Document-Library>.**

*Instruction sheet may be omitted when submitting.*

## **CORPORATE RESOLUTION**

Excerpt from minutes of meeting of the Board of Directors of

---

Incorporated.

At the meeting of Directors of \_\_\_\_\_  
Incorporated, duly noticed and held on \_\_\_\_\_,  
A quorum being there present, on motion duly made and seconded. It was:

Resolved that \_\_\_\_\_, be and is hereby appointed, constituted and designated as agent and Attorney-In-Fact of the corporation with full power and authority to act on behalf of this corporation in all negotiations, bidding, concerns and transactions with the Parish of Jefferson or any of its agencies, departments, employees or agents, including but not limited to, the execution of all bids, papers, documents, affidavits, bonds, sureties, contracts and acts and to receive all purchase orders and notices issued pursuant to the provisions of any such bid or contract, this corporation hereby ratifying, approving, confirming, and accepting each and every such act performed by said agent and Attorney-In-Fact.

I hereby certify the foregoing to be a true and correct copy of an excerpt of the minutes of the above dated meeting of the Board of Directors of said corporation, and the same has not been revoked or rescinded.

---

**Secretary-Treasurer**

---

**Date**

# Bid Bond

An Electronic Bid Bond must be submitted with this bid, through one of the respective clearing houses at [www.jeffparish.net](http://www.jeffparish.net) or [www.centralbidding.com](http://www.centralbidding.com). To access the bonding companies on Central Bidding, hover over the “Central Bidding” link at the top of the page and select the “Bid Bonds” link.

The electronic bid bond number is to be placed in the required section listed on the standard envelope. Scanned copies of bid bonds will not be accepted with your submission.

The screenshot shows the Central Bidding website interface. The browser address bar displays <https://www.centralauctionhouse.com>. The website header includes the Central Bidding logo and navigation links: ABOUT US, TESTIMONIALS, CENTRAL BIDDING, and ePROCUREMENT SOLUTIONS. A dropdown menu is open under CENTRAL BIDDING, showing options: Bids by Agency, Search Bids, Bid Bonds, and Contact Us. The main banner features the text: "Central Bidding is the leading provider of online bidding services to local agencies." Below the banner are three buttons: CENTRAL BIDDING, SURPLUS SALES, and REGISTER NOW!. The statistics section on the left lists: \$41.6 Billion, 38,136 Bid Opportunities, 18,123 Vendors, and 568 Agencies. The right section is titled "Browse Thousands of Public Bids today!" and contains a paragraph about Central Bidding's services, followed by a "Learn More" button.

**\$41.6 Billion**

**38,136 Bid Opportunities**

**18,123 Vendors**

**568 Agencies**

Browse Thousands of Public Bids today!

Central Bidding, founded in 2007, is one of the largest providers of electronic bidding services to public and private buying entities. Vendors have trusted Central Bidding to securely deliver more than \$31.2 Billion worth of electronic bids for more than 450 buying entities since their founding. Central Bidding works under exclusive contract with each of these buying entities and in each instance Central Bidding is the only official electronic location to receive the bid documents, the automated updates and allowance of electronic bids.

[Learn More](#)

<https://www.centralauctionhouse.com/central-bidding/bid-bonds>