



JEFFERSON PARISH

PURCHASING DEPARTMENT

CYNTHIA LEE SHENG
PARISH PRESIDENT

RENNY SIMNO
DIRECTOR



June 25, 2025
ADDENDUM # 1

Bid Number: 50-00147778

Bid Opening Date: July 1, 2025 at 2:00 PM

Purchase of Pre-Assembled Wash Water Booster Pump for the Jefferson Parish Department of Sewerage

QUESTIONS & ANSWERS

Question #1: Will these units be installed inside or outside?

Answer: The department stated the units will be housed inside.

Question #2: If inside, will the controls still need to be furnished with a NEMA 4-x enclosure?

Answer: The department stated that: yes, the controls will need to be furnished with a NEMA 4-x enclosure.

Question #3: To clarify, will this booster pump system be pumping wastewater or clean water?

Answer: The booster pump system will be pumping clean water.

***** PLEASE REMEMBER TO ACKNOWLEDGE THIS ADDENDUM BY NUMBER ON BID FORM*****

Sincerely,

Sean Dumas

Sean Dumas

Purchasing Specialist, II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.