



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

**June 26, 2025**

Please find the following addendum to the below-mentioned QUOTE.

**Addendum No.: 2**

**Quote#:** 25-40-1

**Project Name:** Sludge Removal from Cross Gates# 1

**Quote Due Date:** Wednesday, July 2, 2025

### **QUESTIONS & ANSWERS:**

---

Question 1. Does the Parish have a recent TCLP of the sludge.

**Answer 1.** No, this “sludge” is the remaining grit and solids in the treatment unit of a treatment plant in the process of being decommissioned.

Question 2. 2.2 of RFQ references section 5.30 of Terms and Conditions but that was not attached to the document.

**Answer 2.** Please refer to section “4.23 – Termination” for the referenced Terms and Conditions stated in section 2.2.

Question 3. Is this a haul and dispose of only contract? If yes see subpart below. If it includes dredging, dewatering, haul and disposal, go to questions number 3 and so forth.

Question 3a. Will it be done in 1 mobilization or will it be a call as needed?

**Answer 3a.** Yes, this is a removal from the plant, haul away, and disposal at a permitted disposal site. Theoretically, this is one mobilization as once the NTP is issued, the material will be removed, hauled, and disposed of, which would complete the scope of this contract.



## ST. TAMMANY PARISH

MICHAEL B. COOPER  
PARISH PRESIDENT

Question 4. If this scope includes dredging and dewatering then:

Question 4a. Which plant does the Parish want to pull from first?

**Answer 4a. The sludge will only be removed from Cross Gates Treatment Unit #1.**

Question 4b. Is there a designated laydown area for use of our equipment?

**Answer 4b. No, the contractor will have to work with the plant operators and the onsite construction crew in shared space to remove material from the treatment unit #1. A site visit is recommended.**

Question 4c. What are allowable work hours?

**Answer 4c. The work hours allowed will be 7:00 AM to 4:00 PM.**

**End of Addendum # 2**