



# **The Sewerage & Water Board OF NEW ORLEANS**

625 ST. JOSEPH STREET  
NEW ORLEANS, LA 70165  
504.529.2837 OR 52.WATER  
[www.swbno.org](http://www.swbno.org)

**June 26, 2025**

## **Addendum No. 2**

Your reference is directed to the Invitation to Bid for: **2025-SWB-53 Steel Piping Materials** for the Sewerage and Water Board of New Orleans which proposals are due on **June 25, 2025**, at **11:00 a.m.** CST.

**This addendum provides for the following:**

1. Revision to Question 2b.

*2b. The bid says the pipe must be epoxy lined and coated but give no specification for the product or mils required. Can we get clarification, or should we just stipulate what we are using.*

- *Epoxy conforming to the requirements of AWWA C210. Thickness is 2X manufacturer recommendation.*

*The changes, additions, and/or deletions included herein are hereby made part of the solicitation documents for 2025-SWB-53 Steel Piping Materials as fully and completely as if the same were set forth therein. The bidder shall be responsible for having knowledge of all addenda issued for this ITB.*

This addendum consists of one (1) page.

**\*\*\* END OF ADDENDUM \*\*\***