



Attachment B – Specifications

RFx # 3000025032

Title: *Mand Site*Fax Bid* Water Treatment Svcs

Specifications for Water/Wastewater Treatment at Iota

- Must be certified in Water/Wastewater Treatment
- Check chlorine residual daily
- Check chlorine cylinders, change as needed
- Collect water samples monthly take to lab/drop off point
- Periodically flush water lines as needed
- Inspect well pump, booster pump, and chlorination equipment daily, service as needed
- Inspect wastewater treatment plant, clean daily
- Refill chlorinator daily
- Clean ultra-violet bulbs monthly
- Inspect/service lift stations daily
- Back-up well pump needs to be pulled and screen at the bottom of well casing serviced/repaired



Highway 98

Not to scale

